TTK06.V2


170±1
166±1
116±1
120±1
4×R2
4×R4
POWER
L
N
BN(BK)
BU
YEGN
XT1
TERMINAL BLOCK
21BN
22BU
9YEGN
LINE
LOAD
FILTER
L1
11BN
10BU
12YEGN
PE
AC-L1
N1
E(PE)
AP2: MAIN BOARD
AC-L2
N2
L2
AC-L
HIGH PRESSURE SWITCH HP
HPP
L3
5BU
1BN
INDOOR UNIT A
XTA
INDOOR UNIT B
XTB
6BU
2BN
L4
BK
GY
BU
COM-INNER
FA
FB
REACTOR
WH
OG
LX1-1
LX1-2
LX2-2
LX2-1
COMPRESSOR BAND HEATER
EH
23RD
24RD
HEAT-C
AP1: MAIN BOARD
OFAN
CAP.
C1
FAN MOTOR
TUBE-A
TUBE-B
GAS VALVE TEMP. SENSOR
LIQUID VALVE TEMP. SENSOR
RT1
RT2
RT3
RT4
RT5
RT6
RT7
T-SENSOR
EXHAUST TEMP. SENSOR
OUTROOM TEMP. SENSOR
OUTTUBE TEMP. SENSOR
4V
VT
4YV
4-WAY VALVE
X1
L5
13BU
14YE
15RD
CONNECTOR
U
V
W
OVC-COMP
18WH
17WH
SAT
OVERLOAD PROTECTOR
COMP
COMP.
16YEGN
WARNING
Please don't touch any terminal when the voltage of terminal P(DC+) and N(DC-) at AP1 is higher than 36V to prevent the risk of electrical shock!
OUTDOOR UNIT
63633382


170±1
166±1
116±1
120±1
4×R2
4×R4
POWER
XT1
TERMINAL BLOCK
FILTER
AP2: MAIN BOARD
HIGH PRESSURE SWITCH HP
HPP
INDOOR UNIT A
INDOOR UNIT B
COM-INNER
REACTOR
AP1: MAIN BOARD
OFAN
CAP.
FAN MOTOR
TUBE-A
TUBE-B
T-SENSOR
EXHAUST TEMP. SENSOR
OUTROOM TEMP. SENSOR
OUTTUBE TEMP. SENSOR
CONNECTOR
OVC-COMP
OVERLOAD PROTECTOR
COMP.
WARNING
OUTDOOR UNIT
6363338201

序号	物料编码	图号	备注
00	63633382	GWCD(24)NK3AO.XL	冷暖、有压缩机电加热带
01	6363338201	GWCD(24)NK3AO.XL(01)	单冷、无压缩机电加热带

印刷图的技术要求

1. 严格按图幅比例，图文正确，线条清晰，图幅为白底黑字；
2. 材料为符合RoHS的0.05mm光白PET，背面涂不干胶；
3. 线的颜色要正着写，颜色旁的数字及线号不要印刷出来；
4. 印刷品符合QJ/GD 41.12.001的检验要求；

发放单位		
13	标管	
201	家工	
22	质检	✓
24	采购	✓
29	出口	
361	商工	
43	钣金	
44	喷塑	
46	两器	
47	管一	
48	模具	
49	制造	✓
50	控制	
51	空调	
55	管二	
58	试制	
61	巴西	
62	重庆	
63	合肥	

是否属于客户化物料	
是	
否	✓
使用范围	
通用	
出口	✓
内销	

地点		状态	
管一		是否需再加工	
管二		是否需再加工	

借通用登记

物料状态		
	钣金	
	喷塑	
	两器	
	管路	
	机加件	
	采购	✓
	注塑	
	喷涂	
	丝印	
	控制	
	包装	
	下料	
	发泡	
	流管	

幅面: A2

标记	处数	分区	更改文件号	签名	年月日
设计	袁振开	110903	标准化		
审核			数据审核		
工艺			审定		
会签			批准		

材料:PET

GREE

产品型号:GWCD(24)NK3AO

线路图

图样标记	重量	比例
		1:1

物料编码:见附表

共 1 张 第 1 张

GWCD(24)NK3AO.XL

Все каталоги и инструкции здесь: http://splitoff.ru/tehn-doc.html