

MHI

TECHNICAL MANUAL

INVERTER WALL MOUNTED TYPE RESIDENTIAL AIR-CONDITIONERS (Split system, air to air heat pump type)

SRK63ZK-S

71ZK-S

80ZK-S

 **MITSUBISHI HEAVY INDUSTRIES, LTD.**




Большая библиотека технической документации
<http://splitoff.ru/tehn-doc.html>
каталоги, инструкции, сервисные мануалы, схемы.

CONTENTS

1. SPECIFICATIONS	3
2. EXTERIOR DIMENSIONS	6
(1) Indoor units	6
(2) Outdoor units	7
(3) Remote controller	8
3. ELECTRICAL WIRING	10
(1) Indoor units	10
(2) Outdoor units	11
4. NOISE LEVEL	12
5. PIPING SYSTEM	24
6. RANGE OF USAGE & LIMITATIONS	25
7. CAPACITY TABLES	27
8. APPLICATION DATA	28
(1) Installation of indoor unit	28
(2) Installation of outdoor unit	32
9. OUTLINE OF OPERATION CONTROL BY MICROCOMPUTER	39
(1) Operation control function by remote controller	39
(2) Unit ON/OFF button	40
(3) Auto restart function	40
(4) Custom cord switching procedure	40
(5) Selection of the annual cooling function	41
(6) Flap and louver control	41
(7) Timer operation	42
(8) Outline of heating operation	43
(9) Outline of cooling operation	44
(10) Outline of automatic operation	44
(11) Protective control function	45
10. MAINTENANCE DATA	52
(1) Cautions	52
(2) Items to check before troubleshooting	52
(3) Troubleshooting procedure (If the air conditioner does not run at all)	52
(4) Troubleshooting procedure (If the air conditioner runs)	53
(5) Self-diagnosis table	54
(6) Service mode (Trouble mode access function)	55
(7) Inspection procedures corresponding to detail of trouble	63

(8) Phenomenon observed after shortcircuit, wire breakage on sensor	67
(9) Checking the indoor electrical equipment	68
(10) How to make sure of wireless remote controller	69
(11) Outdoor unit inspection points	70
11. OPTIONAL PARTS	72
11.1 Instullation of wired remote controller (RC-E4)	72
11.2 Interface kit (SC-BIKN-E)	78
11.3 Super link E board (SC-ADNA-E)	82


■ How to read the model name



1. SPECIFICATIONS


Adapted to RoHS directive

Item		Model		SRK63ZK-S				
				Indoor unit SRK63ZK-S		Outdoor unit SRC63ZK-S		
Cooling capacity (1)		W		6300 (2150 (Min.) ~ 7100 (Max.))				
Heating capacity (1)		W		7100 (1700 (Min.) ~ 9500 (Max.))				
Power supply				1 Phase, 220 ~ 240 V, 50Hz				
Operation data (1)	Power consumption	Cooling	kW	1.76 (0.54 ~ 2.30)				
		Heating		1.79 (0.37 ~ 3.30)				
	Running current	Cooling	A	8.3 / 8.0 / 7.6 (220/ 230/ 240 V)				
		Heating		8.5 / 8.1 / 7.8 (220/ 230/ 240 V)				
	Inrush current			8.5 / 8.1 / 7.8 (220/ 230/ 240 V)				
	Max current			17				
	COP	Cooling	3.58					
		Heating	3.97					
	Noise level	Cooling	Sound level	dB(A)		Hi: 47 Me: 43 Lo: 37 ULo: 26	49	
			Power level	dB		59	62	
Heating		Sound level	dB(A)		Hi: 44 Me: 41 Lo: 36 ULo: 33	50		
		Power level	dB		60	63		
Exterior dimensions (Height x Width x Depth)		mm		318 x 1098 x 248		750 x 880(+88) x 340		
Exterior appearance (Munsell color)				Fine snow (8.0Y 9.3/0.1) near equivalent		Stucco white (4.2Y 7.5/1.1) near equivalent		
Net weight		kg		15		57		
Refrigerant equipment	Compressor type & Q'ty				—		RMT5118MDE2 (Twin Rotary type) x 1	
	Motor (Starting method)		kW		—		1.40 (Line starting)	
	Refrigerant oil		ℓ		0.675 (DIAMOND FREEZE MA68)			
	Refrigerant (3)		kg		R410A 1.8 (Pre-Charged up to the piping length of 15m)			
	Heat exchanger				Louver fins & inner grooved tubing		M fins & inner grooved tubing	
	Refrigerant control				Capillary tubes + Electronic expansion valve			
Deice control				Microcomputer control				
Air handling equipment	Fan type & Q'ty				Tangential fan x 1		Propeller fan x 1	
	Motor		W		56		86	
	Air flow	Cooling	CMM	Hi: 18.5 Me: 16.0 Lo: 13.0 ULo: 8.0				48.5
		Heating		Hi: 20.5 Me: 18.0 Lo: 14.5 ULo: 12.5				43.5
	Fresh air intake				Not possible			
Air filter, Quality / Quantity				Polypropylene net (washable) x 2				
Shock & vibration absorber				—		Cushion rubber (for compressor)		
Electric heater				—		—		
Operation control	Operation switch				Wireless-Remote control		—	
	Room temperature control				Microcomputer thermostat		—	
	Operation Display				RUN: Green , TIMER: Yellow , HI POWER: Green , ECONO: Orange			
Safety devices				Compressor overheat protection, Overcurrent protection Frost protection, Serial signal error protection, Indoor fan motor error protection, Heating overload protection(High pressure control), Cooling overload protection				
Installation data	Refrigerant piping size (O.D)		mm		Liquid line: ø6.35 (1/4") Gas line: ø15.88 (5/8")			
	connecting method				Flare connecting			
	Attached length of piping		m		Liquid line : 0.70		—	
					Gas Line : 0.63			
	Insulation for piping				Necessary (Both sides), independent			
Refrigerant line (one way)length				Max.30				
Vertical height difference between outdoor unit and indoor unit		m		Max.20(Outdoor unit is higher)		Max.20 (Outdoor unit is lower)		
Drain hose				Connectable (VP 16)		—		
Power cable				—				
Recommended breaker size		A		20				
Connection wiring	Size x Core number				1.5mm ² x 4 cores (Including earth cable)			
	Connecting method				Terminal block (Screw fixing type)			
Accessories (included)				Mounting kit, Clean filter (Allergen clear filter x 1, Photocatalytic washable deodorizing filter x 1)				
Optional parts				Interface kit (SC-BIKN-E)				
Note (1) The data are measured at the following conditions.				The pipe length is 7.5m.				
Operation	Item	Indoor air temperature		Outdoor air temperature		Standards		
		DB	WB	DB	WB			
	Cooling	27°C	19°C	35°C	24°C	ISO-T1 , JIS C 9612		
Heating	20°C	—	7°C	6°C				
(2) This air-conditioner is manufactured and tested in conformity with the ISO.								
(3) The operation data are applied to the 220/230/240V districts respectively.								
(4) The refrigerant quantity to be charged includes the refrigerant in 15 m connecting piping.(Purging is not required even for the short piping.) If the piping length is longer, when it is 15 to 30 m , add 25 g refrigerant per meter.								




Adapted to RoHS directive

Item			Model		SRK71ZK-S																												
					Indoor unit SRK71ZK-S		Outdoor unit SRC71ZK-S																										
Cooling capacity (1)			W	7100 (2150 (Min.) ~ 8000 (Max.))																													
Heating capacity (1)			W	8000 (1600 (Min.) ~ 10000 (Max.))																													
Power supply				1 Phase, 220 ~ 240 V, 50Hz																													
Operation data (1)	Power consumption	Cooling	kW	2.16 (0.54 ~ 2.80)																													
		Heating		2.14 (0.37 ~ 3.40)																													
	Running current	Cooling	A	10.1 / 9.7 / 9.3 (220/ 230/ 240 V)																													
		Heating		10.1 / 9.7 / 9.3 (220/ 230/ 240 V)																													
	Inrush current			10.1 / 9.7 / 9.3 (220/ 230/ 240 V)																													
	Max current			17																													
	COP	Cooling		3.29																													
		Heating		3.74																													
	Noise level	Cooling	Sound level	dB(A)	Hi: 49 Me: 45 Lo: 39 ULo: 26		53																										
			Power level		60		66																										
Heating		Sound level	dB(A)	Hi: 46 Me: 43 Lo: 38 ULo: 35		51																											
		Power level		61		63																											
Exterior dimensions (Height x Width x Depth)			mm	318 x 1098 x 248		750 x 880(+88) x 340																											
Exterior appearance (Munsell color)				Fine snow (8.0Y 9.3/0.1) near equivalent		Stucco white (4.2Y 7.5/1.1) near equivalent																											
Net weight			kg	15		57																											
Refrigerant equipment	Compressor type & Q'ty			—		RMT5118MDE2 (Twin Rotary type) x 1																											
	Motor (Starting method)		kW	—		1.40 (Line starting)																											
	Refrigerant oil		ℓ	0.675 (DIAMOND FREEZE MA68)																													
	Refrigerant (3)		kg	R410A 1.8 (Pre-Charged up to the piping length of 15m)																													
	Heat exchanger			Louver fins & inner grooved tubing		M fins & inner grooved tubing																											
	Refrigerant control			Capillary tubes + Electronic expansion valve																													
Deice control				Microcomputer control																													
Air handling equipment	Fan type & Q'ty			Tangential fan x 1		Propeller fan x 1																											
	Motor		W	56		86																											
	Air flow	Cooling	CMM	Hi: 19.5 Me: 17.5 Lo: 14.0 ULo: 8.0		55.0																											
		Heating		Hi: 21.5 Me: 19.5 Lo: 15.5 ULo: 14.0		43.5																											
	Fresh air intake			Not possible																													
Air filter, Quality / Quantity			Polypropylene net (washable) x 2																														
Shock & vibration absorber				—		Cushion rubber (for compressor)																											
Electric heater				—																													
Operation control	Operation switch			Wireless-Remote control																													
	Room temperature contro			Microcomputer thermostat																													
	Operation Display			RUN: Green , TIMER: Yellow , HI POWER: Green , ECONO: Orange																													
Safety devices				Compressor overheat protection, Overcurrent protection Frost protection, Serial signal error protection, Indoor fan motor error protection, Heating overload protection(High pressure control), Cooling overload protection																													
Installation data	Refrigerant piping size (O.D)		mm	Liquid line: ø6.35 (1/4") Gas line: ø15.88 (5/8")																													
	connecting method			Flare connecting																													
	Attached length of piping		m	Liquid line : 0.70		—																											
	Insulation for piping			Necessary (Both sides), independent																													
	Refrigerant line (one way)length			Max.30																													
Vertical height difference between outdoor unit and indoor unit		m	Max.20(Outdoor unit is higher) Max.20 (Outdoor unit is lower)																														
Drain hose				Connectable (VP 16)		—																											
Power cable				—																													
Recommended breaker size			A	20																													
Connection wiring	Size x Core number			1.5mm ² x 4 cores (Including earth cable)																													
	Connecting method			Terminal block (Screw fixing type)																													
Accessories (included)				Mounting kit, Clean filter (Allergen clear filter x 1, Photocatalytic washable deodorizing filter x 1)																													
Optional parts				Interface kit (SC-BIKN-E)																													
<p>Note (1) The data are measured at the following conditions. The pipe length is 7.5m.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th rowspan="2">Item</th> <th colspan="2">Indoor air temperature</th> <th colspan="2">Outdoor air temperature</th> <th rowspan="2">Standards</th> </tr> <tr> <th>DB</th> <th>WB</th> <th>DB</th> <th>WB</th> </tr> </thead> <tbody> <tr> <td>Operation</td> <td></td> <td></td> <td></td> <td></td> <td rowspan="3">ISO-T1 , JIS C 9612</td> </tr> <tr> <td>Cooling</td> <td>27°C</td> <td>19°C</td> <td>35°C</td> <td>24°C</td> </tr> <tr> <td>Heating</td> <td>20°C</td> <td>—</td> <td>7°C</td> <td>6°C</td> </tr> </tbody> </table> <p>(2) This air-conditioner is manufactured and tested in conformity with the ISO. (3) The operation data are applied to the 220/230/240V districts respectively. (4) The refrigerant quantity to be charged includes the refrigerant in 15 m connecting piping.(Purging is not required even for the short piping.) If the piping length is longer, when it is 15 to 30 m , add 25 g refrigerant per meter.</p>								Item	Indoor air temperature		Outdoor air temperature		Standards	DB	WB	DB	WB	Operation					ISO-T1 , JIS C 9612	Cooling	27°C	19°C	35°C	24°C	Heating	20°C	—	7°C	6°C
Item	Indoor air temperature		Outdoor air temperature		Standards																												
	DB	WB	DB	WB																													
Operation					ISO-T1 , JIS C 9612																												
Cooling	27°C	19°C	35°C	24°C																													
Heating	20°C	—	7°C	6°C																													



Adapted to RoHS directive

Item		Model		SRK80ZK-S																												
				Indoor unit SRK80ZK-S		Outdoor unit SRC80ZK-S																										
Cooling capacity (1)		W	8000 (2150 (Min.) ~ 8500 (Max.))																													
Heating capacity (1)		W	9000 (1700 (Min.) ~ 10500 (Max.))																													
Power supply			1 Phase, 220 ~ 240 V, 50Hz																													
Operation data (1)	Power consumption	Cooling	kW	2.65 (0.54 ~ 3.00)																												
		Heating		2.55 (0.37 ~ 3.65)																												
	Running current	Cooling	A	12.4 / 11.9 / 11.4 (220/ 230/ 240 V)																												
		Heating		11.9 / 11.4 / 11.0 (220/ 230/ 240 V)																												
	Inrush current			12.4 / 11.9 / 11.4 (220/ 230/ 240 V)																												
	Max current			17																												
	COP	Cooling		3.02																												
		Heating		3.53																												
	Noise level	Cooling	Sound level	dB(A)	Hi: 51 Me: 47 Lo: 41 ULo: 26	56																										
			Power level		64	69																										
Heating		Sound level	dB(A)	Hi: 48 Me: 45 Lo: 40 ULo: 37	54																											
		Power level		62	66																											
Exterior dimensions (Height x Width x Depth)		mm	318 x 1098 x 248		750 x 880(+88) x 340																											
Exterior appearance (Munsell color)			Fine snow (8.0Y 9.3/0.1) near equivalent		Stucco white (4.2Y 7.5/1.1) near equivalent																											
Net weight		kg	15		57																											
Refrigerant equipment	Compressor type & Q'ty			—		RMT5118MDE2 (Twin Rotary type) x 1																										
	Motor (Starting method)		kW	—		1.40 (Line starting)																										
	Refrigerant oil		ℓ	0.675 (DIAMOND FREEZE MA68)																												
	Refrigerant (3)		kg	R410A 1.8 (Pre-Charged up to the piping length of 15m)																												
	Heat exchanger			Louver fins & inner grooved tubing		M fins & inner grooved tubing																										
	Refrigerant control			Capillary tubes + Electronic expansion valve																												
Deice control			Microcomputer control																													
Air handling equipment	Fan type & Q'ty			Tangential fan x 1		Propeller fan x 1																										
	Motor		W	56		86																										
	Air flow	Cooling	CMM	Hi: 21.0 Me: 18.5 Lo: 15.0 ULo: 8.0		63.0																										
		Heating		Hi: 23.5 Me: 20.5 Lo: 17.0 ULo: 15.0		49.5																										
	Fresh air intake			Not possible		—																										
Air filter, Quality / Quantity			Polypropylene net (washable) x 2		—																											
Shock & vibration absorber			—		Cushion rubber (for compressor)																											
Electric heater			—		—																											
Operation control	Operation switch			Wireless-Remote control		—																										
	Room temperature contro			Microcomputer thermostat		—																										
	Operation Display			RUN: Green , TIMER: Yellow , HI POWER: Green , ECONO: Orange																												
Safety devices			Compressor overheat protection, Overcurrent protection Frost protection, Serial signal error protection, Indoor fan motor error protection, Heating overload protection(High pressure control), Cooling overload protection																													
Installation data	Refrigerant piping size (O.D)		mm	Liquid line: ø6.35 (1/4") Gas line: ø15.88 (5/8")																												
	connecting method			Flare connecting																												
	Attached length of piping		m	Liquid line : 0.70		—																										
	Insulation for piping			Gas Line : 0.63																												
	Refrigerant line (one way)length			Necessary (Both sides), independent																												
Vertical height difference between outdoor unit and indoor unit		m	Max.30																													
Drain hose			Connectable (VP 16)		—																											
Power cable			—																													
Recommended breaker size		A	20																													
Connection wiring	Size x Core number		1.5mm ² x 4 cores (Including earth cable)																													
	Connecting method		Terminal block (Screw fixing type)																													
Accessories (included)			Mounting kit, Clean filter (Allergen clear filter x 1, Photocatalytic washable deodorizing filter x 1)																													
Optional parts			Interface kit (SC-BIKN-E)																													
<p>Note (1) The data are measured at the following conditions. The pipe length is 7.5m.</p> <table border="1"> <thead> <tr> <th rowspan="2">Item</th> <th colspan="2">Indoor air temperature</th> <th colspan="2">Outdoor air temperature</th> <th rowspan="2">Standards</th> </tr> <tr> <th>DB</th> <th>WB</th> <th>DB</th> <th>WB</th> </tr> </thead> <tbody> <tr> <td>Operation</td> <td>27°C</td> <td>19°C</td> <td>35°C</td> <td>24°C</td> <td rowspan="3">ISO-T1 , JIS C 9612</td> </tr> <tr> <td>Cooling</td> <td>27°C</td> <td>19°C</td> <td>35°C</td> <td>24°C</td> </tr> <tr> <td>Heating</td> <td>20°C</td> <td>—</td> <td>7°C</td> <td>6°C</td> </tr> </tbody> </table> <p>(2) This air-conditioner is manufactured and tested in conformity with the ISO. (3) The operation data are applied to the 220/230/240V districts respectively. (4) The refrigerant quantity to be charged includes the refrigerant in 15 m connecting piping.(Purging is not required even for the short piping.) If the piping length is longer, when it is 15 to 30 m , add 25 g refrigerant per meter.</p>							Item	Indoor air temperature		Outdoor air temperature		Standards	DB	WB	DB	WB	Operation	27°C	19°C	35°C	24°C	ISO-T1 , JIS C 9612	Cooling	27°C	19°C	35°C	24°C	Heating	20°C	—	7°C	6°C
Item	Indoor air temperature		Outdoor air temperature		Standards																											
	DB	WB	DB	WB																												
Operation	27°C	19°C	35°C	24°C	ISO-T1 , JIS C 9612																											
Cooling	27°C	19°C	35°C	24°C																												
Heating	20°C	—	7°C	6°C																												







2. EXTERIOR DIMENSIONS

(1) Indoor units


Models SRK63ZK-S, 71ZK-S, 80ZK-S

Все каталоги и инструкции здесь: <http://splitoff.ru/ehd-doc.html>


Symbol	Content	
A	Gas piping	φ 15.88 (5/8") (Flare)
B	Liquid piping	φ 6.35 (1/4") (Flare)
C	Hole on wall for right rear piping	(φ 65)
D	Hole on wall for left rear piping	(φ 65)
E	Drain hose	VP16
F	Outlet for wiring	
G	Outlet for piping (on both side)	



Wireless remote controller



Wired Remote controller
(Option)



Note (1) The model name label is attached on the underside of the panel.


Unit:

RKW000Z401

(2) Outdoor units
 Models SRC63ZK-S, 71ZK-S, 80ZK-S

Note

- (1) It must not be surrounded by walls on four sides.
- (2) The unit must be fixed with anchor bolts. An anchor bolt must not protrude more than 15mm.
- (3) Where the unit is subjected to strong winds, lay it in such a direction that the blower outlet faces perpendicularly to the dominant wind direction.
- (4) Leave 1m or more space above the unit.
- (5) A wall in front of the blower outlet must not exceed the unit's height.
- (6) The model name label is attached on the rear panel.






Minimum installation space

Dimensions	Examples of installation		
	I	II	III
L1	Open	Open	500
L2	300	250	Open
L3	100	150	100
L4	250	250	250



Unit:mm

Symbol	Content	
A	Service valve connection (gas side)	φ 15.88 (5/8") (Flare)
B	Service valve connection (liquid side)	φ 6.35 (1/4") (Flare)
C	Pipe/cable draw-out hole	
D	Drain discharge hole	φ 20 x 3 places
E	Anchor bolt hole	M10 x 4 places




(3) Remote controller
(a) Wireless remote controller

Unit: mm




(b) Wired remote controller (option parts)


Interface kit (SC-BIKN-E) is required to use the wired remote controller.



Embedded mounting



Remote control installation dimensions



(1) Installation screw for remote control
M4 Screw (2 pieces)

Unit:mm

Wiring specifications

(1) If the prolongation is over 100m, change to the size below.
But, wiring in the remote controller case should be under 0.5mm². Change the wire size outside of the case according to wire connecting. Waterproof treatment is necessary at the wire connecting section. Be careful about contact failure.

Length	Wiring thickness
100 to 200m	0.5mm ² ×2 cores
Under 300m	0.75mm ² ×2 cores
Under 400m	1.25mm ² ×2 cores
Under 600m	2.0mm ² ×2 cores

PJZ000Z274

3. ELECTRICAL WIRING


(1) Indoor units

Models SRK63ZK-S, 71ZK-S, 80ZK-S


Всe каталоги и инструкции здесь: <http://splitoff.ru/ehh-doc.html>

Item	Description
CNE-CNX2	Connector
FMI	Fan motor
SM ₁	Flap motor
LM _{1,2}	Louver motor
Th1	Room temp. sensor
Th _{2,1,2}	Heat exch. sensor
Th3	Humidity sensor
DS	Diode stack
F	Fuse
T	Terminal block
Va	Varistor

Mark	Color
BK	Black
BL	Blue
RD	Red
WH	White
Y	Yellow
Y/G	Yellow/Green



(2) Outdoor units
 Models SRC63ZK-S, 71ZK-S, 80ZK-S



Power cable, indoor-outdoor connecting wires

Model	MAX running current (A)	Power cable size (mm ²)	Power cable length (m)	indoor-outdoor wire size x number	Earth wire size (mm)
63	17	2.5	30	1.5mm ² x 4	1.5mm ²
71					
80					

- The specifications shown in the above table are for units without heaters. For units with heaters, refer to the installation instructions or the construction instructions of the indoor unit.
- Switchgear of Circuit breaker capacity which is calculated from MAX. over current should be chosen along the regulations in each country.
- The cable specifications are based on the assumption that a metal or plastic conduit is used with no more than three cables contained in a conduit and a voltage drop is 2%. For an installation falling outside of these conditions, please follow the internal cabling regulations. Adapt it to the regulation in effect in each country.

Item	Description
CM	Compressor motor
CN205	Connector
CNTH	
CNEEV	
CNFAN	
EEV	Electric expansion valve (coil)
FMo	Fan motor
L	Reactor
T1,2	Terminal block
TH1	Heat exchanger sensor (outdoor unit)
TH2	Outdoor air temp.sensor
TH3	Discharge pipe temp.sensor
20S	Solenoid valve for 4 way valve

Mark	Color
BK	Black
BR	Brown
OR	Orange
RD	Red
WH	White
Y	Yellow
Y/G	Yellow/Green

RWC000Z240

4. NOISE LEVEL

(1) Model SRK63ZK-S

(a) Max value in Hi MODE

(Indoor Unit)


Model	SRK63ZK-S	
Noise Level	Cooling	47 dB(A)
	Heating	44 dB(A)

Condition ISO-T1,JIS C9612

●Mike position as below



× Cooling ○ — Heating




(Outdoor Unit)

Model	SRC63ZK-S	
Noise Level	Cooling	49 dB(A)
	Heating	50 dB(A)

●Mike position: at highest noise level in position as mentined below
Distance from front side 1m

× Cooling ○ — Heating



ISC10097


(b) Max value in Me MODE

Condition	ISO-T1, JIS C9612
-----------	-------------------

(Indoor Unit)

Model	SRK63ZK-S	
Noise Level	Cooling	43 dB(A)
	Heating	41 dB(A)


● Mike position as below



(Outdoor Unit)

Model	SRC63ZK-S	
Noise Level	Cooling	49 dB(A)
	Heating	56 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m



ISC10097


(c) Max value in Lo MODE

Condition ISO-T1, JIS C9612

(Indoor Unit)

Model	SRK63ZK-S	
Noise Level	Cooling	37 dB(A)
	Heating	36 dB(A)


● Mike position as below



(Outdoor Unit)

Model	SRC63ZK-S	
Noise Level	Cooling	49 dB(A)
	Heating	54 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m



ISC10097


(d) Max value in ULo MODE

Condition	ISO-T1, JIS C9612
-----------	-------------------

(Indoor Unit)

Model	SRK63ZK-S	
Noise Level	Cooling	26 dB(A)
	Heating	33 dB(A)

● Mike position as below




(Outdoor Unit)

Model	SRC63ZK-S	
Noise Level	Cooling	41 dB(A)
	Heating	41 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m

x Cooling o — Heating



ISC10097

(2) Model SRK71ZK-S

(a) Max value in Hi MODE

(Indoor Unit)


Model	SRK71ZK-S	
Noise	Cooling	49 dB(A)
Level	Heating	46 dB(A)

Condition ISO-T1,JIS C9612

●Mike position as below



x Cooling ○ — Heating




(Outdoor Unit)

Model	SRC71ZK-S	
Noise	Cooling	53 dB(A)
Level	Heating	51 dB(A)

●Mike position: at highest noise level in position as mentined below
Distance from front side 1m

x Cooling ○ — Heating



ISC10097

(b) Max value in Me MODE

(Indoor Unit)


Model	SRK71ZK-S	
Noise	Cooling	45 dB(A)
Level	Heating	43 dB(A)

Condition ISO-T1, JIS C9612

● Mike position as below



x Cooling ○ — Heating




(Outdoor Unit)

Model	SRC71ZK-S	
Noise	Cooling	52 dB(A)
Level	Heating	56 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m

x Cooling ○ — Heating



ISC10097

(c) Max value in Lo MODE

(Indoor Unit)


Model	SRK71ZK-S	
Noise Level	Cooling	39 dB(A)
	Heating	38 dB(A)

Condition ISO-T1, JIS C9612

●Mike position as below




x Cooling ○ — Heating



(Outdoor Unit)

Model	SRC71ZK-S	
Noise Level	Cooling	49 dB(A)
	Heating	56 dB(A)

●Mike position: at highest noise level in position as mentined below
Distance from front side 1m



ISC10097

(d) Max value in ULo MODE

(Indoor Unit)


Model	SRK71ZK-S	
Noise Level	Cooling	26 dB(A)
	Heating	35 dB(A)

Condition ISO-T1, JIS C9612

● Mike position as below




x Cooling ○ — Heating



(Outdoor Unit)

Model	SRC71ZK-S	
Noise Level	Cooling	41 dB(A)
	Heating	42 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m



ISC10097

(3) Model SRK80ZK-S

(a) Max value in Hi MODE

(Indoor Unit)


Model	SRK80ZK-S	
Noise Level	Cooling	51 dB(A)
	Heating	48 dB(A)

Condition ISO-T1, JIS C9612

● Mike position as below



x Cooling ○ — Heating




(Outdoor Unit)

Model	SRC80ZK-S	
Noise Level	Cooling	56 dB(A)
	Heating	54 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m

x Cooling ○ — Heating



ISC10097


(b) Max value in Me MODE

Condition ISO-T1, JIS C9612

(Indoor Unit)

● Mike position as below


Model	SRK80ZK-S	
Noise Level	Cooling	47 dB(A)
	Heating	45 dB(A)



(Outdoor Unit)

Model	SRC80ZK-S	
Noise Level	Cooling	52 dB(A)
	Heating	56 dB(A)

● Mike position: at highest noise level in position as mentined below
Distance from front side 1m



ISC10097


(c) Max value in Lo MODE

Condition ISO-T1,JIS C9612

(Indoor Unit)

Model	SRK80ZK-S	
Noise Level	Cooling	41 dB(A)
	Heating	40 dB(A)


●Mike position as below



(Outdoor Unit)

Model	SRC80ZK-S	
Noise Level	Cooling	49 dB(A)
	Heating	56 dB(A)

●Mike position: at highest noise level in position as mentined below
Distance from front side 1m



ISC10097

(d) Max value in ULo MODE

Condition ISO-T1,JIS C9612


(Indoor Unit)

Model	SRK80ZK-S	
Noise Level	Cooling	26 dB(A)
	Heating	37 dB(A)

●Mike position as below



x Cooling ○ — Heating




(Outdoor Unit)

Model	SRC80ZK-S	
Noise Level	Cooling	41 dB(A)
	Heating	43 dB(A)

●Mike position: at highest noise level in position as mentined below
Distance from front side 1m


x Cooling ○ — Heating



ISC10097

5. PIPING SYSTEM

Models SRK63ZK-S, 71ZK-S, 80ZK-S



6. RANGE OF USAGE & LIMITATIONS


Models	SRK63ZK-S,71ZK-S,80ZK-S
Item	
Indoor return air temperature (Upper, lower limits)	Cooling operation : Approximately 18 to 32°C D.B. Heating operation : Approximately 10 to 27°C D.B. (Refer to the selection chart)
Outdoor air temperature (Upper, lower limits)	Cooling operation : Approximately -15 to 46°C D.B. Heating operation : Approximately -15 to 21°C D.B. (Refer to the selection chart)
Refrigerant line (one way) length	Max. 30m
Vertical height difference between outdoor unit and indoor unit	Max. 20m (Outdoor unit is higher) Max. 20m (Outdoor unit is lower)
Power source voltage	Rating ±10%
Voltage at starting	Min. 85% of rating
Frequency of ON-OFF cycle	Max. 4 times/h (Inching prevention 10 minutes)
ON and OFF interval	Min. 3 minutes

Selection chart

Correct the cooling and heating capacity in accordance with the conditions as follows. The net cooling and heating capacity can be obtained in the following way.

$$\text{Net capacity} = \text{Capacity shown on specification} \times \text{Correction factors as follows.}$$

(1) Coefficient of cooling and heating capacity in relation to temperatures



(2) Correction of cooling and heating capacity in relation to one way length of refrigerant piping

It is necessary to correct the cooling and heating capacity in relation to the one way piping length between the indoor and outdoor units.

Piping length [m]	7	10	15	20	25	30
Cooling	1.0	0.99	0.975	0.965	0.95	0.935
Heating	1.0	1.0	1.0	1.0	1.0	1.0

(3) Correction relative to frosting on outdoor heat exchanger during heating

In additions to the foregoing corrections (1), (2) the heating capacity needs to be adjusted also with respect to the frosting on the outdoor heat exchanger.

Air inlet temperature of outdoor unit in °CWB	-15	-10	-9	-7	-5	-3	-1	1	3	5 or more
Adjustment coefficient	0.95	0.95	0.94	0.93	0.91	0.88	0.86	0.87	0.92	1.00

How to obtain the cooling and heating capacity

Example : The net cooling capacity of the model SRK63ZK-S with the piping length of 15m, indoor wet-bulb temperature at 19.0°C and outdoor dry-bulb temperature 35°C is Net cooling capacity =

$$\begin{array}{ccccccc}
 \overline{6300} & \times & \overline{0.975} & \times & \overline{1.0} & = & 6143 \text{ W} \\
 \uparrow & & \uparrow & & \uparrow & & \\
 \text{SRK63ZK-S} & & \text{Length 15m} & & \text{Factor by air} & & \\
 & & & & \text{temperatures} & &
 \end{array}$$

7. CAPACITY TABLES

Model SRK63ZK-S

Cool Mode

Air flow	Outdoor air temp.	Indoor air temp																									
		21°CDB		23°CDB		26°CDB		27°CDB		28°CDB		31°CDB		33°CDB													
		14°CWB	16°CWB	18°CWB	19°CWB	20°CWB	22°CWB	24°CWB	TC	SHC	TC	SHC	TC	SHC	TC	SHC											
Hi 18.5 (m³/min)	10	7.10	5.45	7.43	5.35	7.70	5.53	7.83	5.45	7.97	5.38	8.20	5.52	8.42	5.33	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	12	6.97	5.38	7.30	5.29	7.59	5.48	7.73	5.41	7.87	5.34	8.11	5.49	8.34	5.30	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	14	6.84	5.31	7.18	5.23	7.48	5.43	7.62	5.36	7.77	5.29	8.02	5.43	8.26	5.27	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	16	6.70	5.24	7.04	5.16	7.37	5.38	7.52	5.32	7.66	5.25	7.93	5.40	8.17	5.25	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	18	6.56	5.17	6.91	5.09	7.25	5.32	7.40	5.26	7.55	5.18	7.83	5.36	8.08	5.22	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	20	6.42	5.09	6.77	5.03	7.12	5.25	7.29	5.20	7.43	5.14	7.73	5.33	7.98	5.19	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	22	6.28	5.02	6.62	4.95	6.99	5.20	7.17	5.15	7.31	5.10	7.62	5.29	7.88	5.16	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	24	6.12	4.94	6.47	4.89	6.86	5.15	7.04	5.11	7.19	5.05	7.51	5.25	7.77	5.12	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	26	5.97	4.86	6.32	4.82	6.73	5.09	6.92	5.06	7.06	5.00	7.40	5.21	7.67	5.08	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	28	5.81	4.79	6.16	4.74	6.59	5.04	6.79	5.01	6.93	4.96	7.28	5.17	7.55	5.05	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	30	5.65	4.71	6.00	4.67	6.44	4.97	6.65	4.95	6.80	4.90	7.16	5.13	7.44	5.01	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	32	5.49	4.63	5.83	4.59	6.30	4.91	6.51	4.89	6.66	4.85	7.03	5.08	7.32	4.97	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	34	5.32	4.55	5.66	4.51	6.15	4.84	6.37	4.83	6.52	4.79	6.90	5.03	7.19	4.93	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	35	5.23	4.51	5.57	4.48	6.07	4.81	6.30	4.80	6.45	4.76	6.84	5.01	7.13	4.91	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	36	5.14	4.46	5.49	4.44	5.99	4.78	6.23	4.78	6.38	4.73	6.77	4.99	7.06	4.88	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	38	4.97	4.38	5.31	4.36	5.83	4.71	6.08	4.71	6.23	4.67	6.64	4.93	6.93	4.84	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	39	4.88	4.33	5.22	4.32	5.75	4.68	6.00	4.68	6.15	4.65	6.57	4.91	6.87	4.82	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC

Heat Mode

Air flow	Outdoor air temp.	Indoor air temp				
		16°CDB	18°CDB	20°CDB	22°CDB	24°CDB
Hi 20.5 (m³/min)	-15°CWB	4.37	4.27	4.17	4.09	4.00
	-10°CWB	4.94	4.86	4.79	4.67	4.57
	-5°CWB	5.35	5.28	5.17	5.11	5.03
	0°CWB	5.61	5.53	5.43	5.37	5.29
	5°CWB	7.15	7.07	7.03	6.89	6.79
	6°CWB	7.27	7.18	7.10	7.01	6.93
	10°CWB	7.72	7.65	7.60	7.50	7.42
	15°CWB	8.40	8.33	8.27	8.18	8.10
20°CWB	9.03	8.96	8.92	8.81	8.74	

Model SRK71ZK-S

Cool Mode

Air flow	Outdoor air temp.	Indoor air temp																									
		21°CDB		23°CDB		26°CDB		27°CDB		28°CDB		31°CDB		33°CDB													
		14°CWB	16°CWB	18°CWB	19°CWB	20°CWB	22°CWB	24°CWB	TC	SHC	TC	SHC	TC	SHC	TC	SHC											
Hi 19.5 (m³/min)	10	8.00	5.98	8.37	5.88	8.68	6.04	8.83	5.95	8.98	5.87	9.24	6.00	9.49	5.81	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	12	7.86	5.90	8.23	5.80	8.56	5.98	8.71	5.91	8.87	5.83	9.15	5.97	9.40	5.78	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	14	7.71	5.82	8.09	5.72	8.43	5.93	8.59	5.86	8.75	5.77	9.04	5.92	9.31	5.74	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	16	7.55	5.74	7.94	5.65	8.30	5.87	8.47	5.80	8.63	5.73	8.93	5.88	9.21	5.71	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	18	7.40	5.66	7.78	5.58	8.17	5.80	8.34	5.74	8.51	5.67	8.82	5.84	9.10	5.66	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	20	7.24	5.57	7.62	5.51	8.03	5.74	8.21	5.69	8.38	5.61	8.71	5.80	8.99	5.63	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	22	7.07	5.49	7.46	5.42	7.88	5.68	8.08	5.63	8.24	5.56	8.59	5.74	8.88	5.58	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	24	6.90	5.40	7.29	5.34	7.73	5.61	7.94	5.56	8.10	5.50	8.46	5.69	8.76	5.55	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	26	6.73	5.31	7.12	5.26	7.58	5.54	7.79	5.50	7.96	5.44	8.33	5.65	8.64	5.50	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	28	6.55	5.22	6.94	5.17	7.42	5.47	7.65	5.44	7.81	5.38	8.20	5.59	8.51	5.46	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	30	6.37	5.13	6.76	5.08	7.26	5.40	7.50	5.37	7.66	5.32	8.07	5.55	8.38	5.39	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	32	6.18	5.04	6.57	4.99	7.10	5.32	7.34	5.31	7.51	5.25	7.92	5.47	8.25	5.35	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	34	5.99	4.94	6.38	4.91	6.93	5.25	7.18	5.24	7.35	5.19	7.78	5.42	8.11	5.30	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	35	5.90	4.88	6.28	4.86	6.84	5.20	7.10	5.20	7.27	5.16	7.71	5.40	8.03	5.28	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	36	5.80	4.84	6.18	4.80	6.75	5.16	7.02	5.15	7.19	5.11	7.63	5.37	7.96	5.26	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	38	5.60	4.74	5.98	4.72	6.58	5.09	6.85	5.09	7.02	5.05	7.48	5.32	7.81	5.22	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	39	5.50	4.70	5.88	4.67	6.48	5.06	6.76	5.06	6.93	5.02	7.40	5.30	7.74	5.19	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC

Heat Mode

Air flow	Outdoor air temp.	Indoor air temp				
		16°CDB	18°CDB	20°CDB	22°CDB	24°CDB
Hi 21.5 (m³/min)	-15°CWB	4.92	4.82	4.70	4.61	4.50
	-10°CWB	5.57	5.47	5.40	5.26	5.15
	-5°CWB	6.03	5.94	5.82	5.76	5.67
	0°CWB	6.32	6.23	6.12	6.05	5.96
	5°CWB	8.06	7.96	7.92	7.76	7.65
	6°CWB	8.19	8.09	8.00	7.90	7.80
	10°CWB	8.70	8.62	8.56	8.45	8.36
	15°CWB	9.47	9.38	9.32	9.21	9.13
20°CWB	10.17	10.09	10.05	9.93	9.85	

Model SRK80ZK-S

Cool Mode

Air flow	Outdoor air temp.	Indoor air temp																									
		21°CDB		23°CDB		26°CDB		27°CDB		28°CDB		31°CDB		33°CDB													
		14°CWB	16°CWB	18°CWB	19°CWB	20°CWB	22°CWB	24°CWB	TC	SHC	TC	SHC	TC	SHC	TC	SHC											
Hi 21.0 (m³/min)	10	9.01	6.77	9.43	6.65	9.78	6.85	9.95	6.75	10.12	6.64	10.42	6.81	10.70	6.59	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	12	8.85	6.68	9.28	6.57	9.64	6.77	9.82	6.68	9.99	6.59	10.30	6.77	10.59	6.55	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	14	8.68	6.59	9.11	6.49	9.50	6.71	9.68	6.63	9.86	6.55	10.19	6.72	10.49	6.52	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	16	8.51	6.50	8.94	6.41	9.35	6.65	9.54	6.57	9.72	6.49	10.07	6.67	10.37	6.47	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	18	8.34	6.40	8.77	6.31	9.20	6.58	9.40	6.51	9.58	6.43	9.94	6.63	10.25	6.43	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	20	8.15	6.31	8.59	6.23	9.04	6.51	9.25	6.45	9.44	6.37	9.81	6.57	10.13	6.38	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	22	7.97	6.22	8.41	6.15	8.88	6.44	9.10	6.38	9.29	6.31	9.68	6.52	10.00	6.34	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	24	7.78	6.12	8.22	6.05	8.71	6.36	8.94	6.31	9.13	6.24	9.54	6.47	9.87	6.29	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC	TC	SHC
	26	7.58	6.02	8.02	5.96	8.54	6.28	8.78	6.24	8.97	6.17	9.39	6.41														

8. APPLICATION DATA

RKW012A400

(1) Installation of indoor unit

Models SRK63ZK-S, 71ZK-S, 80ZK-S

- This installation manual illustrates the method of installing an indoor unit.
- For electrical wiring work, please see instructions set out on the backside.
- For outdoor unit installation and refrigerant piping, please refer to page 23.





- A wired remote control unit is supplied separately as an optional part.
- When install the unit, be sure to check whether the selection of installation place, power supply specifications, usage limitation (piping length, height differences between indoor and outdoor units, power supply voltage and etc.) and installation spaces.

SAFETY PRECAUTIONS

- Read the "SAFETY PRECAUTIONS" carefully first of all and strictly follow it during the installation work in order to protect yourself.
- The precautionary items mentioned below are distinguished into two levels, **WARNING** and **CAUTION**.
 - **WARNING**: Wrong installation would cause serious consequences such as injuries or death.
 - **CAUTION**: Wrong installation might cause serious consequences depending on circumstances.
- Both mentions the important items to protect your health and safety so strictly follow them by any means.
- Be sure to confirm no anomaly on the equipment by commissioning after completed installation and explain the operating methods as well as the maintenance methods of this equipment to the user according to the owner's manual.

- Keep the installation manual together with owner's manual at a place where any user can read at any time. Moreover if necessary, ask to hand them to a new user.
- For installing qualified personnel, take precautions in respect to themselves by using suitable protective clothing, gloves, etc., and then perform the installation works.
- Please pay attention not to fall down the tools, etc. when installing the unit at the high position.
- If unusual noise can be heard during operation, consult the dealer.
- The meanings of "Marks" used here are as shown on the right:

	Never do it under any circumstances.			Always do it according to the instruction.
---	--------------------------------------	---	---	--

⚠ WARNING	
	<ul style="list-style-type: none"> • Do not run the unit with removed panels or protections. Touching rotating equipments, hot surfaces or high voltage parts can cause personal injury due to entrapment, burn or electric shocks. • Do not perform any change of protective device itself or its setup condition. The forced operation by short-circuiting protective device of pressure switch and temperature controller or the use of non specified component can cause fire or burst.
⚠ CAUTION	
	<ul style="list-style-type: none"> • Carry out the electrical work for ground lead with care. Do not connect the ground lead to the gas line, water line, lightning conductor or telephone line's ground lead. Incorrect grounding can cause unit faults such as electric shocks due to short-circuiting.
	<ul style="list-style-type: none"> • Use the circuit breaker of correct capacity. Circuit breaker should be the one that disconnect all poles under over current. Using the incorrect one could cause the system failure and fire. • Earth leakage breaker must be installed. If the earth leakage breaker is not installed, it can cause electric shocks. • Install isolator or disconnect switch on the power supply wiring in accordance with the local codes and regulations. • Be sure to install indoor unit properly according to the installation manual in order to run off the drainage smoothly. Improper installation of indoor unit can cause dropping water into the room and damaging personal property. • Install the drainage pipe to run off drainage securely according to the installation manual. Incorrect installation of the drainage pipe can cause dropping water into the room and damaging personal property. • Be sure to install the drainage pipe with descending slope of 1/100 or more, and not to make traps and air-bleedings. Check if the drainage runs off securely during commissioning and ensure the space for inspection and maintenance. • Secure a space for installation, inspection and maintenance specified in the manual. Insufficient space can result in accident such as personal injury due to falling from the installation place.
	<ul style="list-style-type: none"> • Do not install the unit in the locations listed below. <ul style="list-style-type: none"> • Locations where carbon fiber, metal powder or any powder is floating. • Locations where any substances that can affect the unit such as sulphide gas, chloride gas, acid and alkaline can occur. • Vehicles and ships. • Locations where cosmetic or special sprays are often used. • Locations with direct exposure of oil mist and steam such as kitchen and machine plant. • Locations where any machines which generate high frequency harmonics are used. • Locations with salty atmospheres such as coastlines. • Locations with heavy snow (If installed, be sure to provide base flame and snow hood mentioned in the manual). • Locations where the unit is exposed to chimney smoke. • Locations at high altitude (more than 1000m high). • Locations with ammoniac atmospheres. • Locations where heat radiation from other heat source can affect the unit. • Locations without good air circulation. • Locations with any obstacles which can prevent inlet and outlet air of the unit. • Locations where short circuit of air can occur (in case of multiple units installation). • Locations where strong air blows against the air outlet of outdoor unit. It can cause remarkable decrease in performance, corrosion and damage of components, malfunction and fire. • Do not install the indoor unit in the locations listed below (Be sure to install the indoor unit according to the installation manual for each model because each indoor unit has each limitation). <ul style="list-style-type: none"> • Locations with any obstacles which can prevent inlet and outlet air of the unit. • Locations where vibration can be amplified due to insufficient strength of structure. • Locations where the infrared receiver is exposed to the direct sunlight or the strong light beam (in case of the infrared specification unit), • Locations where an equipment affected by high harmonics is placed (TV set or radio receiver is placed within 1m). • Locations where drainage cannot run off safely. • It can affect performance or function and etc. • Do not install the unit near the location where leakage of combustible gases can occur.

Be KataroTH и инcTpyкциH Зpеc: <http://splitoff.ru/ehh-doc.html>

BEFORE INSTALLATION

- Before installation check that the power supply matches the air conditioner.

Standard accessories (Installation kit) Accessories for indoor unit		Q'ty
①	Installation board (Attached to the rear of the indoor unit)	1
②	Wireless remote control	1
③	Remote control holder	1
④	Tapping screws (for installation board ø4 X 25mm)	10
⑤	Wood screws (for remote control switch holder ø3.5 X 16mm)	2
⑥	Battery [R03 (AAA, Micro) 1.5V]	2
⑦	Air-cleaning filters	2
⑧	Filter holders (Attached to the front panel of indoor unit)	2
⑨	Insulation (#486 50 x 100 t3)	1

Option parts		Q'ty
a	Sealing plate	1
b	Sleeve	1
c	Inclination plate	1
d	Putty	1
e	Drain hose (extension hose)	1
f	Piping cover (for insulation of connection piping)	1

Necessary tools for the installation work	
1	Plus headed driver
2	Knife
3	Saw
4	Tape measure
5	Hammer
6	Spanner wrench
7	Torque wrench (14.0 ~ 82.0N·m (1.4 ~ 8.2kgf·m))
8	Hole core drill (65mm in diameter)
9	Wrench key (Hexagon) [4m/m]
10	Flaring tool set (Designed specifically for R410A)
11	Gas leak detector (Designed specifically for R410A)
12	Gauge for projection adjustment (Used when flare is made by using conventional flare tool)
13	Pipe bender

SELECTION OF INSTALLATION LOCATION

(Install at location that meets the following conditions, after getting approval from the customer)

Indoor unit

- Where there is no obstructions to the air flow and where the cooled and heated air can be evenly distributed.
- A solid place where the unit or the wall will not vibrate.
- A place where there will be enough space for servicing. (Where space mentioned below can be secured)
- Where wiring and the piping work will be easy to conduct.
- The place where receiving part is not exposed to the direct rays of the sun or the strong rays of the street lighting.
- A place where it can be easily drained.
- A place separated at least 1m away from the television or the radio. (To prevent interference to images and sounds.)
- Places where this unit is not affected by the high frequency equipment or electric equipment.
- Avoid installing this unit in place where there is much oil mist.
- Places where there is no electric equipment or household under the installing unit.


Wireless remote control

- A place where the air conditioner can be received the signal surely during operating the wireless remote control.
- Places where there is no affected by the TV and radio etc.
- Do not place where exposed to direct sunlight or near heat devices such as a stove.


INSTALLATION OF INDOOR UNIT

Installation of Installation board

Look for the inside wall structures (Intermediates support or pillar and firmly install the unit after level surface has been checked.)




- Adjustment of the installation board in the horizontal direction is to be conducted with eight screws in a temporary tightened state.
- Adjust so the board will be level by turning the board with the standard hole as the center.



Drilling of holes and fixture of sleeve (Option parts)


When drilling the wall that contains a metal lath, wire lath or metal plate, be sure to use pipe hole sleeve sold separately.



- Drill a hole with whole core drill.
- In case of rear piping draw out, cut off the lower and the right side portions of the sleeve collar.

Installing the support of piping

In case of piping in the right rear direction




- Hold the bottom of the piping and fix direction before stretching it and shaping it.
- Tape only the portion that goes through the wall.
- Always tape the wiring with the piping.





Sufficient care must be taken not to damage the panel when connecting pipes.

• Matters of special notice when piping from left or central/rear of the unit.

[Top view]




Piping is possible in the rear, left, left rear, left downward, right or downward direction.




Relation between setting plate and indoor unit


INSTALLATION SPACE (INDOOR UNIT) (FRONT VIEW)



[Drain hose changing procedures]




- Remove the screw and drain hose, making it rotate.
- Remove it with hand or pliers.



- Insert the drain cap which was removed at procedure "2" securely using a hexagonal wrench etc.
Note: Be careful that if it is not inserted securely, water leakage may occur.
- Insert the drain hose securely, making rotate. And install the screw.
Note: Be careful that if it is not inserted securely, water leakage may occur.


Fixing of indoor unit




- Installation Steps**
- Pass the pipe through the hole in the wall, and hook the upper part of the indoor unit to the installation board.
 - Gently push the lower part to secure the unit.

How to remove the indoor unit from the installation board

- Push up at the marked portion of the indoor unit base lower latch, and slightly pull it toward you, (both right and left hand sides) (The indoor unit base lower latch can be removed from the installation board)
- Push up the indoor unit upward. So the indoor unit will be removed from the installation board.




Since this air conditioner has been designed to collect dew drops on the rear surface to the drain pan, do not attach the power cord above the gutter.



Drainage

- Arrange the drain hose in a downward angle.
 - Avoid the following drain piping.
- CAUTION** Go through all installations and check if the drainage is all right and check if the water leak may occur.




- Pour water to the drain pan located under the heat exchanger, and ensure that the water is drained out of the drain pan.
- When the extended drain hose is indoor, always use a shield pipe (to be arranged by thermally insulated).

CONNECTION OF REFRIGERANT PIPINGS

Preparation Keep the openings of the pipes covered with tapes etc. to prevent dust, sand, etc. from entering them.




- Remove the flared nuts. (on both liquid and gas sides)



- Install the removed flared nuts to the pipes to be connected, then flared the pipes.

CAUTION
Do not apply refrigerating machine oil to the flared surface.


Flaring work



Copper pipe diameter	Measurement B (mm)		
	Clutch type flare tool for R410A	Conventional (R22) flare tool	
	Clutch type	Wing nut type	
ø6.35	0.0 - 0.5	1.0 - 1.5	1.5 - 2.0
ø9.52	0.0 - 0.5	1.0 - 1.5	1.5 - 2.0
ø12.7	0.0 - 0.5	1.0 - 1.5	2.0 - 2.5
ø15.88	0.0 - 0.5	1.0 - 1.5	2.0 - 2.5

Use a flare tool designed for R410A or a conventional flare tool.
Please note that measurement B (protrusion from the flaring block) will vary depending on the type of a flare tool in use.
If a conventional flare tool is used, please use a copper pipe gauge or a similar instrument to check protrusion so that you can keep measurement B to a correct value.


Connection




- Connect the pipes on both liquid and gas sides.
- Tighten the nuts to the following torque.
Liquid side (ø6.35): 14.0 - 18.0 N·m (1.4 - 1.8 kgf·m)
Gas side (ø9.52): 34.0 - 42.0 N·m (3.4 - 4.2 kgf·m)
(ø12.7): 49.0 - 61.0 N·m (4.9 - 6.1 kgf·m)
(ø15.88): 68.0 - 82.0 N·m (6.8 - 8.2 kgf·m)

CAUTION
Do not apply excess torque to the flared nuts. Otherwise, the flared nuts may check depending.

Insulation of the connection portion




Finishing work and fixing




Open/close and detachment/attachment of the air inlet panel

- To open, pull the panel at both ends of lower part and release latches, then pull up the panel until you feel resistance. (The panel stops at approx. 60° open position)
- To close, hold the panel at both ends of lower part to lower downward and push it slightly until the latch works.
- To remove, pull up the panel to the position shown in right illustration and pull it toward you.
- To install, insert the panel arm into the slot on the front panel from the position shown in right illustration, hold the panel at both ends of lower part, lower it downward slowly, then push it slightly until the latch works.



How to remove and install the front panel

- Removing
 - Remove the air inlet panel.
 - Remove the screw (A) 2pcs / screw (B) 3pcs fixing to the front panel.
 - Remove the 3 latches in the upper section of the front panel and then remove the front panel from the unit.
- Installing
 - Remove the air filter.
 - Cover the unit with the front panel.
 - Tighten the screw (A) 2pcs / screw (B) 3pcs to fix the front panel.
 - Install the air filter.
 - Install the air inlet panel.



ELECTRICAL WIRING WORK

Preparation of indoor unit

Mounting of connecting wires

- ① Open the air inlet panel.
- ② Remove the lid.
- ③ Remove the wiring clamp.
- ④ Connect the connecting wire securely to the terminal block.
 - 1) Connect the connection wire securely to the terminal block. If the wire is not affixed completely, contact will be poor, and it is dangerous as the terminal block may heat up and catch fire.
 - 2) Take care not to confuse the terminal numbers for indoor and outdoor connections.
- ⑤ Fix the connecting wire by wiring clamp.
- ⑥ Attach the lid.
- ⑦ Close the air inlet panel.


CAUTION

In case of faulty wiring connection, the indoor unit stops, and then the run lamp turns on and the timer lamp blinks.

Use cables for interconnection wiring to avoid loosening of the wires.
CENELEC code for cables Required field cables.


H05RN4G1.5 (example) or 245IEC57

H	Harmonized cable type
05	300/500 volts
R	Natural-and/or synth, rubber wire insulation
N	Polychloroprene rubber conductors insulation
R	Stranded core
4or5	Number of conductors
G	One conductor of the cable is the earth conductor (yellow/green)
1.5	Section of copper wire (mm ²)



Installing the air-cleaning filters

1. Open the air inlet panel and remove the air filters.
2. Install the filter holders, with the air-cleaning filters installed in the holders. In the air conditioner.
 - Each air-cleaning filter can be installed in the left or right filter holder.
3. Install the air filters and close the inlet panel.




INSTALLATION OF WIRELESS CONTROL

Mounting method of battery

- Uncover the wireless remote control, and mount the batteries [R03 (AAA, Micro), ×2 pieces] in the body regularly. (Fit the poles with the indication marks, ⊕ & ⊖ without fail)


CAUTION

Do not use new and old batteries together.



Fixing to pillar or wall

- Conventionally, operate the wireless remote control by holding in your hand.
- Avoid installing it on a clay wall etc.



INSTALLATION TEST CHECK POINTS

Check the following points again after completion of the installation, and before turning on the power. Conduct a test run again and ensure that the unit operates properly. At the same time, explain to the customer how to use the unit and how to take care of the unit following the user's manual.

After installation

- The power supply voltage is correct as the rating.
- No gas leaks from the joints of the operation valve.
- Power cables and crossover wires are securely fixed to the terminal board.
- Operation valve is fully open.
- The pipe joints for indoor and outdoor pipes have been insulated.

Test run

- Air conditioning operation is normal.
- No abnormal noise.
- Water drains smoothly.
- Protective functions are not working.
- The remote control is normal.
- Operation of the unit has been explained to the customer. (Three-minutes restart preventive timer)
When the air conditioner is restarted or when changing the operation, the unit will not start operating for approximately 3 minutes. This is to protect the unit and it is not a malfunction.

HOW TO RELOCATE OR DISPOSE OF THE UNIT


- In order to protect the environment, be sure to pump down (recovery of refrigerant).
- Pump down is the method of recovering refrigerant from the indoor unit to the outdoor unit when the pipes are removed from the unit.

• Forced cooling operation

Turn on a power supply again after a while after turn off a power supply. Then press continually the ON/OFF button 5 seconds or more.

<How to pump down>

- ① Connect charge hose to check joint of outdoor unit.
- ② Liquid side : Close the liquid valve with hexagon wrench key.
Gas side : Fully open the gas valve.
Carry out cooling operation. (If indoor temperature is low, operate forced cooling operation.)
- ③ After low pressure gauge become 0.01MPa, stop cooling operation and close the gas valve.




CONCERNING TERMINAL CONNECTION FOR AN INTERFACE

- ① Remove the air inlet panel, lid and front panel.
- ② Remove the control cover. (Remove the screw.)
- ③ There is a terminal (respectively marked with CNS) for the indoor control board.

In connecting an interface, connect to the respective terminal securely with the connection harness supplied with an optional "Interface connection kit SC-BIKN-E" and fasten the connection harness onto the indoor control box with the clamp supplied with the kit.

For more details, please refer to the user's manual of your "Interface connection kit SC-BIKN-E".



(2) Installation of outdoor unit
Models SRC63ZK-S, 71ZK-S, 80ZK-S




RCR012A001

R410A REFRIGERANT USED

- This installation manual deals with outdoor units and general installation specifications only. For indoor units, refer to page 19.
- When install the unit, be sure to check whether the selection of installation place, power supply specifications, usage limitation (piping length, height differences between indoor and outdoor units, power supply voltage and etc.) and installation spaces.

SAFETY PRECAUTIONS

- Read the "SAFETY PRECAUTIONS" carefully first of all and strictly follow it during the installation work in order to protect yourself.
- The precautionary items mentioned below are distinguished into two levels, **⚠ WARNING** and **⚡ CAUTION**.
 - ⚠ WARNING** : Wrong installation would cause serious consequences such as injuries or death.
 - ⚡ CAUTION** : Wrong installation might cause serious consequences depending on circumstances.
- Both mentions the important items to protect your health and safety so strictly follow them by any means.
- Be sure to confirm no anomaly on the equipment by commissioning after completed installation and explain the operating methods as well as the maintenance methods of this equipment to the user according to the owner's manual.
- Keep the installation manual together with owner's manual at a place where any user can read at any time. Moreover if necessary, ask to hand them to a new user.
- For installing qualified personnel, take precautions in respect to themselves by using the protective clothing, gloves, etc., and then perform the installation works.
- Please pay attention not to fall down the tools, etc. when installing the unit at the installation location.
- If unusual noise can be heard during operation, consult the dealer.
- The meanings of "Marks" used here are as shown on the right:

	Never do it under any circumstances.			Always do it according to the instruction.
---	--------------------------------------	---	---	--

⚠ WARNING	
<p>⚠</p> <ul style="list-style-type: none"> • Installation must be carried out by the qualified installer. If you install the system by yourself, it may cause serious trouble such as water leaks, electric shocks, fire and personal injury, as a result of a system malfunction. • Install the system in full accordance with the installation manual. Incorrect installation may cause bursts, personal injury, water leaks, electric shocks and fire. • Be sure to use only for household and residence. If this appliance is installed in inferior environment such as machine shop and etc., it can cause malfunction. • When installing in small rooms, take prevention measures not to exceed the density limit of refrigerant in the event of leakage, referred by the formula (accordance with ISO5149). If the density of refrigerant exceeds the limit, please consult the dealer and install the ventilation system, otherwise lack of oxygen can occur, which can cause serious accident. • Use the original accessories and the specified components for installation. If parts other than those prescribed by us are used, it may cause water leaks, electric shocks, fire and personal injury. • Install the unit in a location with good support. Unsuitable installation locations can cause the unit to fall and cause material damage and personal injury. • Ensure the unit is stable when installed, so that it can withstand earthquakes and strong winds. Unsuitable installation locations can cause the unit to fall and cause material damage and personal injury. 	<ul style="list-style-type: none"> • Ventilate the working area well in the event of refrigerant leakage during installation. If the refrigerant comes into contact with naked flames, poisonous gas is produced. • Use the prescribed pipes, flare nuts and tools for R410A. Using existing parts (for R22 or R407C) can cause the unit failure and serious accidents due to burst of the refrigerant circuit. • Tighten the flare nut by torque wrench with specified method. If the flare nut were tightened with excess torque, this may cause burst and refrigerant leakage after a long period. • Do not open the operation valves for liquid line and gas line until completed refrigerant piping work, air tightness test and evacuation. If the compressor is operated in state of opening operation valves before completed connection of refrigerant piping work, air can be sucked into refrigerant circuit, which can cause burst or personal injury due to anomalously high pressure in the refrigerant. • The electrical installation must be carried out by the qualified electrician in accordance with "the norm for electrical work" and "national wiring regulation", and the system must be connected to the dedicated circuit. Power supply with insufficient capacity and incorrect function done by improper work can cause electric shocks and fire. • Be sure to shut off the power before starting electrical work. Failure to shut off the power can cause electric shocks, unit failure or incorrect function of equipment. • Be sure to use the cables conformed to safety standard and cable ampacity for power distribution work. Unconformable cables can cause electric leak, anomalous heat production or fire.
<p>⊘</p> <ul style="list-style-type: none"> • Ensure that no air enters in the refrigerant circuit when the unit is installed and removed. If air enters in the refrigerant circuit, the pressure in the refrigerant circuit becomes too high, which can cause burst and personal injury. • Do not processing, splice the power cord, or share a socket with other power plugs. This may cause fire or electric shock due to defecting contact, defecting insulation and over-current etc. 	<ul style="list-style-type: none"> • Do not bundling, winding or processing for the power cord. Or, do not deforming the power plug due to tread it. This may cause fire or heating. • Do not run the unit with removed panels or protections. Touching rotating equipments, hot surfaces or high voltage parts can cause personal injury due to entrapment, burn or electric shocks. • Do not perform any change of protective device in any condition. The forced operation by short-circuiting protective device, temperature controller or the use of non specified device can cause fire or explosion.

Без каталога и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

⚠ CAUTION

	<ul style="list-style-type: none"> • Carry out the electrical work for ground lead with care. Do not connect the ground lead to the gas line, water line, lightning conductor or telephone line's ground lead. Incorrect grounding can cause unit faults such as electric shocks due to short-circuiting.
	<ul style="list-style-type: none"> • Use the circuit breaker for all pole correct capacity. Circuit breaker should be the one that disconnect all poles under over current. Using the incorrect circuit breaker, it can cause the unit malfunction and fire. • Earth leakage breaker must be installed. If the earth leakage breaker is not installed, it can cause electric shocks. • Install isolator or disconnect switch on the power supply wiring in accordance with the local codes and regulations. The isolator should be locked in OFF state in accordance with EN60204-1. • After maintenance, all wiring, wiring ties and the like, should be returned to their original state and wiring route, and the necessary clearance from all metal parts should be secured.
	<ul style="list-style-type: none"> • Do not install the unit in the locations listed below. <ul style="list-style-type: none"> • Locations where carbon fiber, metal powder or any powder is floating. • Locations where any substances that can affect the unit such as sulphide gas, chloride gas, acid and alkaline can occur. • Vehicles and ships. • Locations where cosmetic or special sprays are often used. • Locations with direct exposure of oil mist and steam such as kitchen and machine plant. • Locations where any machines which generate high frequency harmonics are used. • Locations with salty atmospheres such as coastlines. • Locations with heavy snow (If installed, be sure to provide base flame and snow hood mentioned in the manual). • Locations where the unit is exposed to chimney smoke. • Locations at high altitude (more than 1000m high). • Locations with ammoniac atmospheres. • Locations where heat radiation from other heat source can affect the unit. • Locations without good air circulation. • Locations with any obstacles which can prevent inlet and outlet air of the unit. • Locations where short circuit of air can occur (in case of multiple units installation). • Locations where strong air blows against the air outlet of outdoor unit. It can cause remarkable decrease in performance, corrosion and damage of components, malfunction and fire. • Do not install the outdoor unit in the locations listed below. <ul style="list-style-type: none"> • Locations where discharged hot air or operating sound of the outdoor unit can bother neighborhood. • Locations where outlet air of the outdoor unit blows directly to an animal or plants. The outlet air can affect adversely to the plant etc. • Locations where vibration can be amplified and transmitted due to insufficient strength of structure. • Locations where vibration and operation sound generated by the outdoor unit can affect seriously (on the wall or at the place near bed room). • Locations where an equipment affected by high harmonics is placed (TV set or radio receiver is placed within 1m). • Locations where drainage cannot run off safely. It can affect surrounding environment and cause a claim. • Do not install the unit near the location where leakage of combustible gases can occur. If leaked gases accumulate around the unit, it can cause fire. • Do not install the unit where corrosive gas (such as sulfurous acid gas etc.) or combustible gas (such as thinner and petroleum gases) can accumulate or collect, or where volatile combustible substances are handled. Corrosive gas can cause corrosion of heat exchanger, breakage of plastic parts and etc. And combustible gas can cause fire. • Do not install nor use the system close to the equipment that generates electromagnetic fields or high frequency harmonics. Equipment such as inverters, standby generators, medical high frequency equipments and telecommunication equipments can affect the system, and cause malfunctions and breakdowns. The system can also affect medical equipment and telecommunication equipment, and obstruct its function or cause jamming.

Check before installation work

- Model name and power source
- Refrigerant piping length
- Piping, wiring and miscellaneous small parts
- Indoor unit installation manual

Accessories for outdoor unit	Q'ty
① Grommet (Heat pump type only)	2
② Drain elbow (Heat pump type only)	1

Option parts	Q'ty
Ⓐ Sealing plate	1
Ⓑ Sleeve	1
Ⓒ Inclination plate	1
Ⓓ Putty	1
Ⓔ Drain hose (extension hose)	1
Ⓕ Piping cover (for insulation of connection piping)	1

Necessary tools for the installation work	Q'ty
9 Wrench key (Hexagon) [4m/m]	10
10 Vacuum pump	11
1 Plus headed driver	12
2 Knife	13
3 Saw	14
4 Tape measure	15
5 Hammer	16
6 Spanner wrench	1
7 Torque wrench [14.0~82.0N·m (1.4~8.2kgf·m)]	1
8 Hole core drill (65mm in diameter)	1

Notabilia as a unit designed for R410A


- Do not use any refrigerant other than R410A. R410A will rise to pressure about 1.6 times higher than that of a conventional refrigerant. A cylinder containing R410A has a pink indication mark on the top.
- A unit designed for R410A has adopted a different size indoor unit operation valve charge port and a different size check joint provided in the unit to prevent the charging of a wrong refrigerant by mistake. The processed dimension of the flared part of a refrigerant pipe and a flare nut's parallel side measurement have also been altered to raise strength against pressure. Accordingly, you are required to arrange dedicated R410A tools listed in the table on the right before installing or servicing this unit.
- Do not use a charge cylinder. The use of a charge cylinder will cause the refrigerant composition to change, which results in performance degradation.
- In charging refrigerant, always take it out from a cylinder in the liquid phase.
- All indoor units must be models designed exclusively for R410A. Check connectable indoor unit models in a catalog, etc. (A wrong indoor unit, if connected into the system, will impair proper system operation)

1. HAULAGE AND INSTALLATION (Take particular care in carrying in or moving the unit, and always perform such an operation with two or more persons.)

CAUTION When a unit is hoisted with slings for haulage, take into consideration the offset of its gravity center position. If not properly balanced, the unit can be thrown off-balance and fall.


1) Delivery

- Deliver the unit as close as possible to the installation site before removing it from the packaging.
- When you have to unpack the unit for a compelling reason before you haul it to the installation point, hoist the unit with nylon slings or ropes and protection pads so that you may not damage the unit.



2) Portage

- The right hand side of the unit as viewed from the front (diffuser side) is heavier. A person carrying the right hand side must take heed of this fact. A person carrying the left hand side must hold with his right hand the handle provided on the front panel of the unit and with his left hand the corner column section.



3) Selecting the installation location



Be careful of the following conditions and choose an installation place.

- Where air is not trapped.
- Where the installation fittings can be firmly installed.
- Where wind does not hinder the intake and outlet pipes.
- Out of the heat range of other heat sources.
- A place where stringent regulation of electric noises is applicable.
- Where it is safe for the drain water to be discharged.
- Where noise and hot air will not bother neighboring residents.
- Where snow will not accumulate.
- Where strong winds will not blow against the outlet pipe.
- A place where no TV set or radio receiver is placed within 1m. (If electrical interference is caused, seek a place less likely to cause the problem)
- If a operation is conducted when the outdoor air temperature is $-5\text{ }^{\circ}\text{C}$ lower, the outdoor unit should be installed at a place where it is not influenced by natural wind.
- Where it is likely that the unit is subjected to strong winds, provide wind guards according to the following guidelines. Strong winds can cause performance degradation, an accidental stop due to a rise of high pressure and a broken fan.

4) Caution about selection of installation location

- (1) If the unit is installed in the area where the snow will accumulate, following measures are required. The bottom plate of unit and intake, outlet may be blocked by snow.


- 1 Install the unit on the base so that the bottom is higher than snow cover surface.
- 2 Install the unit under eaves or provide the roof on site.



- Since drain water generated by defrost control may freeze, following measures are required.
- Do not execute drain piping work by using a drain elbow and drain grommets (optional parts). [Refer to Drain piping work.]

- (2) If the unit can be affected by strong wind, following measures are required. Strong wind can cause damage of fan (fan motor), or can cause performance degradation, or can trigger anomalous stop of the unit due to rising of high pressure.


- 1 Place the unit outlet side is turned to the wall.
- 2 Install so the direction of the air from the blowing outlet will be perpendicular to the direction of the wind.



5) Installation space


- Walls surrounding the unit in the four sides are not acceptable.
- There must be a 1-meter or larger space in the above.
- When more than one unit are installed side by side, provide a 250mm or wider interval between them as a service space. In order to facilitate servicing of controllers, please provide a sufficient space between units so that their top plates can be removed easily.
- Where a danger of short-circuiting exists, install guide louvers.
- When more than one unit are installed, provide sufficient intake space consciously so that short-circuiting may not occur.
- Where piling snow can bury the outdoor unit, provide proper snow guards.

Example inst		(mm)	
Size		II	III
L1		500	Open
L2		250	Open
L3		150	100
L4		250	250




6) Installation

- ① Anchor bolt fixed position



- ② Notabilia for installation



- In installing the unit, fix the unit's legs with bolts specified on the left.
- The protrusion of an anchor bolt on the front side must be kept within 15mm.
- Securely install the unit so that it does not fall over during earthquakes or strong
- Refer to the above illustrations for information regarding concrete foundations.
- Install the unit in a level area. (With a gradient of 5mm or less.) Improper installation can cause compressor failure, broken piping within the unit and abnormal noise generation.


Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

2. REFRIGERANT PIPING WORK

1) Restrictions on unit installation and use

- Check the following points in light of the indoor unit specifications and the installation site.
- Observe the following restrictions on unit installation and use. Improper installation can result in a compressor failure or performance degradation.

Restrictions		Dimensional restrictions	Marks appearing in the drawing on the right
Main pipe length		30m or less	L
Elevation difference between indoor and outdoor units	When the outdoor unit is positioned higher,	20m or less	H
	When the outdoor unit is positioned lower,	20m or less	H



CAUTION The use restrictions appearing in the table above are applicable to the standard pipe size combinations shown in the table below.

2) Determination of pipe size

Determine refrigerant pipe size pursuant to the following guidelines based on the indoor unit specifications.


	Gas pipe	Liquid pipe
Outdoor unit connected	ø15.88 Flare	ø6.35 Flare
Refrigerant piping (branch pipe L)	ø15.88	ø6.35
Indoor unit connected	ø15.88	ø6.35

When pipe is brazing.

About brazing

Brazing must be performed under a nitrogen gas flow.

Without nitrogen gas, a large quantity of foreign matters (oxidized film) are created, causing a critical failure from capillary tube or expansion valve clogging.



3) Refrigerant pipe wall thickness and material

- Select refrigerant pipes of the table shown on the right wall thickness and material as specified for each pipe size.

NOTE Select pipes having a wall thickness larger than the specified minimum pipe thickness.

Pipe diameter [mm]	ø6.35	ø15.88
Minimum pipe wall thickness [mm]	0.8	1.0
Pipe material*	O-type pipe	O-type pipe


*Phosphorus deoxidized seamless copper pipe ICS 23.040.15, ICS 77.150.30

4) On-site piping work

IMPORTANT Take care so that installed pipes may not touch components within a unit. If touching with an internal component, it will generate abnormal sounds and/or vibrations.

How to remove the side cover Please remove the screw of a side cover and remove to the front.

- Carry out the on site piping work with the operation valve fully closed.
- Give sufficient protection to a pipe end (compressed and blazed, or with an adhesive tape) so that water or foreign matters may not enter the piping.
- Bend a pipe to a radius as large as practical (R100~R150). Do not bend a pipe repeatedly to correct its form.
- Flare connection is used between the unit and refrigerant pipe. Flare a pipe after engaging a flare nut onto it. Flare dimensions for R410A are different from those for conventional R407C. Although we recommend the use of flaring tools designed specifically for R410A, conventional flaring tools can also be used by adjusting the measurement of protrusion B with a protrusion control gauge.
- The pipe should be anchored every 1.5m or less to isolate the vibration.
- Tighten a flare joint securely.




Flared pipe end : A (mm)	
Copper pipe outer diameter	A -04
ø6.35	9.1
ø15.88	19.7

Copper pipe protrusion for flaring : B (mm)		
Copper pipe outer diameter	In the case of a rigid (clutch) type	
	With an R410A tool	With a conventional tool
ø6.35	0~0.5	1.0~1.5
ø15.88	0~0.5	1.0~1.5


CAUTION Do not apply force beyond proper fastening torque in tightening the flare nut.

Fix both liquid and gas operation valves at the valve main bodies as illustrated on the right, and then fasten them, applying appropriate fastening torque.

Operation valve size (mm)	Tightening torque (N·m)	Tightening angle (°)	Recommended length of a tool handle (mm)
ø6.35 (1/4")	14~18	45~60	150
ø15.88 (5/8")	68~82	15~20	300



6) Evacuation



Pay attention to the following points in addition to the above for the R410A and compatible machines.

- To prevent a different oil from entering, assign dedicated tools, etc. to each refrigerant type. Under no circumstances must a gauge manifold and a charge hose in particular be shared with other refrigerant types (R22, R407C, etc.).
- Use a counterflow prevention adapter to prevent vacuum pump oil from entering the refrigerant system.

7) Additional refrigerant charge

(1) Calculate a required refrigerant charge volume from the following table.

Additional charge volume (kg) per meter of refrigerant piping (liquid pipe ø6.35)	Refrigerant volume charged for shipment at the factory (kg)	Installation's pipe length (m) covered without additional refrigerant charge
0.025	1.80	15

- This unit contains factory charged refrigerant covering 15m of refrigerant piping and additional refrigerant charge on the installation site is not required for an installation with up to 15m refrigerant piping. When refrigerant piping exceeds 15m, additionally charge an amount calculated from the pipe length and the above table for the portion in excess of 15m.


Formula to calculate the volume of additional refrigerant required

$$\text{Additional charge volume (kg)} = \{ \text{Main length (m)} - \text{Factory charged volume 15 (m)} \} \times 0.025 \text{ (kg/m)}$$

- * When an additional charge volume calculation result is negative, it is not necessary to charge refrigerant additionally.
- For an installation measuring 15m or shorter in pipe length, please charge the refrigerant volume charged for shipment at the factory, when you recharge refrigerant after servicing etc.

8) Heating and condensation prevention

- Dress refrigerant pipes (both gas and liquid pipes) for heat insulation and prevention of dew condensation.
 - Improper heat insulation/anti-dew dressing can result in a water leak or dripping causing damage to household effects, etc.
- Use a heat insulating material that can withstand 120 C or a higher temperature. Poor heat insulating capacity can cause heat insulation problems or cable deterioration.
 - All gas pipes must be securely heat insulated in order to prevent damage from dripping water that comes from the condensation formed on them during a cooling operation or personal injury from burns because their surface can reach quite a high temperature due to discharged gas flowing inside during a heating operation.
 - Wrap indoor units' flare joints with heat insulating parts (pipe cover) for heat insulation (both gas and liquid pipes).
 - Give heat insulation to both gas and liquid side pipes. Bundle a heat insulating material and a pipe tightly together so that no gaps may be left between them and wrap them together with a connecting cable by a dressing tape.
 - Both gas and liquid pipes need to be dressed with 20mm or thicker heat insulation materials above the ceiling where relative humidity exceeds 70%.**




Securely tighten the operation valve cap and the check joint blind nut after a

Operation valve size (mm)	Operation valve cap tightening torque (N·m)	Check joint blind nut tightening torque (N·m)
ø6.35 (1/4")	20~30	10~15
ø15.88 (5/8")	30~40	

(2) Charging refrigerant


- Since R410A refrigerant must be charged in the liquid phase, you should charge the refrigerant cylinder upside down or using a refrigerant cylinder equipped with a siphon tube.
- Charge refrigerant always from the liquid side service port with the operation valve. When the cylinder valve is throttled down or a dedicated conversic phase refrigerant into mist is used to protect the compressor, however, adjust the cylinder valve so that the refrigerant will gasify upon entering the unit.
- In charging refrigerant, always charge a calculated volume by using a scale to measure the volume.
- When refrigerant is charged with the unit being run, complete a charge operation. Running the unit with an insufficient quantity of refrigerant for a long time can cause compressor failure.

NOTE Put down the refrigerant volume calculated from the pipe length onto the service panel.




3. DRAIN PIPING WORK

- Execute drain piping by using a drain elbow and drain grommets supplied separately as optional parts, where water drained from the outdoor unit is a problem.
- Water may drip where there is a larger amount of drain water. Seal around the drain elbow and drain grommets with putty or adequate caulking material.
- Condensed water may flow out from vicinity of operation valve or connected pipes.
- Where you are likely to have several days of sub-zero temperatures in a row, do not use a drain elbow and drain grommets. (There is a risk of drain water freezing inside and blocking the drain.)



- When condensed water needs to be led to a drain, etc., install the unit on a flat base (supplied separately as an optional part) or concrete blocks. Then, please secure space for the drain elbow and the drain hose.



4. ELECTRICAL WIRING WORK For details of electrical cabling, refer to the indoor unit installation manual.

Electrical installation work must be performed by an electrical installation service provider qualified by a power provider of the country. Electrical installation work must be executed according to the technical standards and other regulations applicable to electrical installations in the country.


- Do not use any supply cord lighter than one specified in parentheses for each type below.
 - braided cord (code designation 60245 IEC 51)
 - ordinary tough rubber sheathed cord (code designation 60245 IEC 53)
 - flat twin tinsel cord (code designation 60227 IEC 41)
- Use polychloroprene sheathed flexible cord (code designation 60245 IEC57) for supply cords of parts of appliances for outdoor use.
- Ground the unit. Do not connect the grounding wire to a gas pipe, water pipe, lightning rod or telephone grounding wire. If improperly grounded, an electric shock or malfunction may result.
- A grounding wire must be connected before connecting the power cable. Provide a grounding wire longer than the power cable.
- The installation of an impulse withstanding type earth leakage breaker is necessary. A failure to install an earth leakage breaker can result in an accident such as an electric shock or a fire.
- Do not turn on the power until the electrical work is completed.
- Do not use a condensive capacitor for power factor improvement under any circumstances. (It does not improve power factor, while it can cause an abnormal overheat accident)
- For power supply cables, use conduits.
- Do not lay electronic control cables (remote control and signaling wires) and other cables together outside the unit. Laying them together can result in the malfunctioning or a failure of the unit due to electric noises.
- Fasten cables so that they may not touch the piping, etc.
- When cables are connected, make sure that all electrical components within the electrical component box are free of loose connector coupling or terminal connection and then attach the cover securely. (Improper cover attachment can result in malfunctioning or a failure of the unit, if water penetrates into the box.)
- Always use a three-core cable for an indoor-outdoor connecting cable. Never use a shield cable.

CAUTION

In case of faulty wiring connection, the indoor unit stops, and then the run lamp turns on and the timer lamp blinks.

Use cables for interconnection wiring to avoid loosening of the wires. CENELEC code for cables Required field cables.

H05RNR4G1.5 (Example) or 245IEC57	
H	Harmonized cable type
05	300/500 volts
R	Natural-and/or synth. rubber wire insulation
N	Polychloroprene rubber conductors insulation
R	Stranded core
4or5	Number of conductors
G	One conductor of the cable is the earth conductor (yellow/green)
1.5	Section of copper wire (mm ²)



Power supply terminal block

Cable clamp

- It holds cables in place and protect the terminal connection from external force.
- This clamp is for the cable in the outside diameter 9~15mm. Please adjust it when not suitable.


Cable name plate

- It has stuck on the lid of a control box.

Grounding terminal

- Please be sure to carry out D-type (type III) grounding work.

Power cable, indoor-outdoor connecting wires



CAUTION Always use an earth leakage circuit breaker designed for inverters to prevent a faulty operation.

Phase	Earth leakage breaker	Switchgear or Circuit Breaker		Power source (minimum)
		Switch breaker	Over current protector rated capacity	
Single-phase	20A, 30mA, 0.1sec or less	30A	20A	2.5mm ²

CAUTION Please connect the earthed line of indoor and outdoor connecting wire to a bracket part of the illustration.

INSTALLATION TEST CHECK POINTS

Check the following points again after completion of the installation, and before turning on the power. Conduct a test run again and ensure that the unit operates properly. Explain to the customer how to use the unit and how to take care of the unit following the installation manual.

After installation

<input type="checkbox"/> Power cables and connecting wires are securely fixed to the terminal block.	<input type="checkbox"/> The pipe joints for indoor and outdoor pipes have been insulated.
<input type="checkbox"/> The power supply voltage is correct as the rating.	<input type="checkbox"/> The reverse flow check cap is attached.
<input type="checkbox"/> The drain hose is fixed securely.	<input type="checkbox"/> The cover of the pipe cover (A) faces downward to prevent rain from entering.
<input type="checkbox"/> Operation valve is fully open.	<input type="checkbox"/> Gaps are properly sealed between the pipe covers (A) (B) and the wall surface / pipes.
<input type="checkbox"/> No gas leaks from the joints of the operation valve.	

9 OUTLINE OF OPERATION CONTROL BY MICROCOMPUTER


(1) Operation control function by remote controller

◆ Operation section


Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

display is switched over in turn.

select button
pressed, the
er in turn.



Unit display section



(2) Unit ON/OFF button


When the remote controller batteries become weak, or if the remote controller is lost or malfunctioning, this button may be used to turn the unit on and off.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

(b) Details of operation

The unit will go into the automatic mode in which it automatically determines, from indoor temperature (as detected by sensor), whether to go into the cooling, thermal dry or heating modes.

Function operation mode	Indoor temperature setting	Fan speed	Flap/Louver	Timer Switch
Cooling	About 24°C	Auto	Auto	Continuous
Thermal dry	About 25°C			
Heating	About 26°C			




(3) Auto restart function

(a) Auto restart function records the operational status of the air-conditioner immediately prior to be switched off by a power cut, and then automatically resumes operations after the power has been restored.

(b) The following settings will be cancelled:

- 1) Timer settings
- 2) HIGH POWER operations

- Notes
- (1) Auto restart function is set at on when the air-conditioner is shipped from the factory. Consult with your dealer if this function needs to be switched off.
 - (2) When power failure occurs, the timer setting is cancelled. Once power is resumed, reset the timer.
 - (3) If the jumper wire (J170) "AUTO RESTART" is cut, auto restart is disabled. (See the diagram at right)



(4) Custom cord switching procedure

If two wireless remote controller are installed in one room, in order to prevent wrong operation due to mixed signals, please modify the printed circuit board in the indoor unit's control box and the remote controller using the following procedure. Be sure to modify both boards. If only one board is modified, receiving (and operation) cannot be done.



(a) Modifying the indoor printed circuit board

Take out the printed circuit board from the control box and cut off jumper wire (J171) using wire cutters.

After cutting of the jumper wire, take measures to prevent contact with the other the lead wires, etc.

(b) Modifying the wireless remote controller

- 1) Remove the battery.
- 2) Cut the jumper wire shown in the figure at right.



(5) Selection of the annual cooling function

(a) The annual cooling function can be enabled or disabled by means of the jumper wire (J172) on the indoor unit PCB and the dip switch (SW2-4) on the indoor unit PCB.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>


Jumper wire (J172)	(SC-BIKN-E) SW2-4	Function
Shorted	ON	Enabled
Shorted	OFF	Disabled
Open	ON	Disabled
Open	OFF	Disabled

Note: (1) Default states of the jumper wire (J172) and the interface kit at the shipping from factory – On the PCB, the dip switch (SW2-4) is set to enable the annual cooling function.

(2) To cancel the annual cooling setting, consult your dealer.

(b) Content of control

- 1) If the outdoor air temperature sensor (TH2) detects below 5°C, the indoor unit speed is switched to 9th step. (It is not possible to change.)
- 2) If the outdoor air temperature sensor (TH2) detects higher than 7°C, the indoor unit speed is changed to the normal control speed.




(6) Flap and louver control

Control the flap and louver by AIR FLOW \blacklozenge (UP/DOWN) and \blacktriangleleft (LEFT/RIGHT) button on the wireless remote controller.

(a) Flap

Each time when you press the AIR FLOW \blacklozenge (UP/DOWN) button the mode changes as follows.




• Angle of Flap from Horizontal

Remote controller display					
COOL, DRY, FAN	Approx. 5°	Approx. 25°	Approx. 35°	Approx. 55°	Approx. 80°
HEAT	Approx. 25°	Approx. 40°	Approx. 50°	Approx. 60°	Approx. 80°

(b) Louver

Each time when you press the AIR FLOW \blacktriangleleft (LEFT/RIGHT) button the mode changes as follows.



• Angle of Louver

Remote controller display					
Center installation	Left Approx. 50°	Left Approx. 20°	Center	Right Approx. 20°	Right Approx. 50°

(c) Swing


1) Swing flap

Flap moves in upward and downward directions continuously.

2) Swing louver

Louver moves in left and right directions continuously.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



(c) Memory flap (Flap or Louver stopped)


When you press the AIR FLOW (UP/DOWN or LEFT/RIGHT) button once while the flap or louver is operating, it stops swinging at the position. Since this angle is memorized in the microcomputer, the flap or louver will automatically be set at this angle when the next operation is started.

(d) When not operating

The flap returns to the position of air flow directly below, when operation has stopped.

(e) Multi-directional Air Flow (up/down air scroll and left/right air scroll)

■ Activating both up/down air swing and left/right air swing at the same time results in a multi-directional air flow.



(7) Timer operation

(a) Comfortable timer setting (ON timer)

If the timer is set at ON when the operation select switch is set at the cooling or heating, or the cooling or heating in auto mode operation is selected, the comfortable timer starts and determines the starting time of next operation based on the initial value of 15 minutes and the relationship between the indoor temperature at the setting time (temperature of room temperature sensor) and the setting temperature.

(b) Sleep timer operation

Pressing the SLEEP button causes the temperature to be controlled with respect to the set temperature.

(c) OFF timer operation

The Off timer can be set at a specific time (in 10-minute units) within a 24-hour period.

(8) Outline of heating operation

(a) Operation of major functional components in heating mode

	Heating		
	Thermostat ON	Thermostat OFF	Failure
Outdoor fan motor	ON	OFF (few minutes ON)	OFF
4-way valve	ON	ON	OFF (3 minutes ON)

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

(b) Details of control at each operation mode (pattern)

1) Fuzzy operation

Deviation between the indoor temperature setting correction temperature and the return air temperature is calculated in accordance with the fuzzy rule, and used for control of the air capacity and the compressor speed.

Fan speed \ Model	SRK63ZK-S	SRK71ZK-S	SRK80ZK-S
Auto	20~106rps	20~116rps	20~120rps
HI	20~106rps	20~116rps	20~120rps
MED	20~106rps	20~116rps	20~120rps
LO	20~88rps	20~98rps	20~96rps
ULO	20~52rps	20~58rps	20~60rps

When the defrosting, protection device, etc. is actuated, operation is performed in the corresponding mode.


2) Hot keep operation

If the hot keep operation is selected during the heating operation, the indoor blower is controlled based on the temperature of the indoor heat exchanger (Th2) to prevent blowing of cool wind.

(c) Defrosting operation

1) Starting conditions (Defrosting operation can be started only when all of the following conditions are met.)

- a) After start of heating operation
When it elapsed 35 minutes. (Accumulated compressor operation time)
- b) After end of defrosting operation
When it elapsed 35 minutes. (Accumulated compressor operation time)
- c) Outdoor heat exchanger sensor (TH1) temperature
When the temperature has been below -5°C for 3 minutes continuously.
- d) The difference between the outdoor air sensor temperature and the outdoor heat exchanger sensor temperature
 - The outdoor air temperature $\geq -2^{\circ}\text{C} : 7^{\circ}\text{C}$ or higher
 - $-15^{\circ}\text{C} \leq$ The outdoor air temperature $< -2^{\circ}\text{C} : 4/15 \times$ The outdoor air temperature $+ 7^{\circ}\text{C}$ or higher
 - The outdoor air temperature $< -15^{\circ}\text{C} : -5^{\circ}\text{C}$ or higher




- e) During continuous compressor operation

In addition, when the speed command from the indoor controller of the indoor unit during heating operation has counted 0 rps 10 times or more and all conditions of a), b), c) and e) above and the outdoor air temperature is 3°C or less are satisfied (note that when the temperature for outdoor heat exchanger sensor (TH1) is -5°C or less: 62 rps or more,

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

- a) Outdoor heat exchanger sensor (TH1) temperature: 13°C or higher
- b) Continued operation time of defrosting → For more than 16 minutes and 50 seconds.



※Depends on an operation condition, the time can be longer than 7 minutes.

(9) Outline of cooling operation

(a) Operation of major functional components in Cooling mode

	Cooling		
	Thermostat ON	Thermostat OFF	Failure
Compressor	ON	OFF	OFF
Indoor fan motor	ON	ON	OFF
Outdoor fan motor	ON	OFF (few minutes ON)	OFF (few minutes ON)
4-way valve	OFF	OFF	OFF

(b) Detail of control in each mode (Pattern)

1) Fuzzy operation


During the fuzzy operation, the air flow and the compressor speed are controlled by calculating the difference between the indoor temperature setting correction temperature and the return air temperature.

Model	SRK63ZK-S	SRK71ZK-S	SRK80ZK-S
Fan speed			
Auto	20~78rps	20~90rps	20~98rps
HI	20~78rps	20~90rps	20~98rps
MED	20~61rps	20~74rps	20~78rps
LO	20~50rps	20~56rps	20~56rps
ULO	20~36rps	20~36rps	20~36rps

(10) Outline of automatic operation

(a) Determination of operation mode

The unit checks the indoor air temperature and setting temperature and the outdoor air temperature, determines the operation mode, and then begins in the automatic operation.



- (b) The unit checks the temperature every hour after the start of operation and, if the result of check is not same as the previous operation mode, changes the operation mode.
- 1) If the setting temperature is changed with the remote controller, the operation mode is judged immediately.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

- 3) When the operation mode has been judged following the change of setting temperature with the remote controller, the hourly judgment of operation mode is cancelled.
- (c) When the unit is started again within one hour after the stop of automatic operation or when the automatic operation is selected during heating, cooling or dehumidifying operation, the unit is operated in the previous operation mode.
- (d) Setting temperature can be adjusted within the following range. There is the relationship as shown below between the signals of the wireless remote controller and the setting temperature.

		Signals of wireless remote controller (Display)												
		-6	-5	-4	-3	-2	-1	±0	+1	+2	+3	+4	+5	+6
Setting temperature	Cooling	18	19	20	21	22	23	24	25	26	27	28	29	30
	Dehumidifying	19	20	21	22	23	24	25	26	27	28	29	30	31
	Heating	20	21	22	23	24	25	26	27	28	29	30	31	32

Unit : °C

- (e) When the unit is operated automatically with the wired remote controller connected, the cooling operation is controlled according to the display temperatures while the setting temperature is compensated by +1°C during dehumidifying or by +2°C during heating.

(11) Protection control function

- (a) **Dew prevention control [Cooling]: Prevents dewing on the indoor unit.**


- 1) **Operating conditions:** When the following conditions have been met for more than 30 minutes after starting operation
- Compressor's command speed is 28 rps or higher.
 - Detected value of humidity is 68% or higher.

2) **Contents of operation**

- a) Air capacity control

Item		Model	SRK63ZK-S	SRK71ZK-S	SRK80ZK-S
ULo	Upper limit of compressor's command speed ⁽¹⁾		Range A: As per following table, Range B: 40 rps		
	Indoor fan		4th speed		
Hi, Me, Lo	Upper limit of compressor's command speed ⁽¹⁾		Range A: As per following table, Range B: 40 rps		
	Indoor fan		Adaptable to compressor's command speed (4th to 9th speed)		

Note (1) Ranges A and B are as shown below.



● **Condition for range A**

Compressor's command rps is controlled according to the indoor unit heat exchanger temperature (Th2) and the indoor unit room temperature (Th1).

Condition	Compressor's command rps
$Th2 \leq Th1 - 10$	<ul style="list-style-type: none"> Decreases the compressor's target max speed by 4 rps. If the condition is met still 20 seconds later, the speed is decreased further by 4 rps. This process is repeated further so far as the condition is met. (Lower limit is 30 rps.)
$Th1 - 10 < Th2 \leq Th1 - 6$	Compressor's target max. speed or changed value of the same is maintained.
$Th2 - 6 < Th1$	Changed compressor's target max. speed is increased at a rate of 1 rps/20 seconds.

- b) When this control has continued for more than 30 minutes continuously, the following wind direction control is performed.
 - i) When the vertical wind direction is set at other than the vertical swing, the flaps change to the horizontal position.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

3) Resetting condition: When any of followings is met

- a) Compressor's command speed is less than 28 rps.
- b) Detected value of humidity is less than 63%.


(b) Frost prevention control (During cooling or dehumidifying)

1) Operating conditions

- a) Indoor heat exchanger temperature (Th2) is lower than 5°C.
- b) 5 minutes after reaching the compressor command speed except 0 rps.

2) Detail of anti-frost operation

Item	Indoor heat exchanger temperature	
	5°C or lower	2.5°C or lower
Lower limit of compressor command speed	22 rps	0 rps
Indoor fan	Depends on operation mode	Protects the fan tap just before frost prevention control
Outdoor fan	Depends on command speed	Depends on stop mode
4-way valve	OFF	



- Notes
- (1) When the indoor heat exchanger temperature is in the range of 2.5~5°C, the speed is reduced by 4 rps at each 20 seconds.
 - (2) When the temperature is lower than 2.5°C, the compressor is stopped.
 - (3) When the indoor heat exchanger temperature is in the range of 5~8°C, the compressor command speed is been maintained.

3) Reset conditions: When either of the following condition is satisfied.

- a) The indoor heat exchanger temperature (Th2) is 8°C or higher.
- b) The compressor command speed is 0 rps.

(c) Cooling overload protective control

- 1) Operating conditions:** When the outdoor air temperature (TH2) has become continuously for 30 seconds at 41°C or more, or 47°C or more with the compressor running, the lower limit speed of compressor is brought up.

Item	Model	
	SRK63, 71, 80ZK-S	
Outdoor air temperature	41°C or more	47°C or more
Lower limit speed	30 rps	40 rps

2) Detail of operation

The lower limit of compressor command speed is set to 30 or 40 rps and even if the calculated result becomes lower than that after fuzzy calculation, the speed is kept to 30 or 40 rps. However, when the thermo becomes OFF, the speed is reduced to 0 rps.


3) Reset conditions: When either of the following condition is satisfied.

- a) The outdoor air temperature is lower than 40°C or 46°C.
- b) The compressor command speed is 0 rps.

(d) Cooling high pressure control

- 1) **Purpose:** Prevents anomalous high pressure operation during cooling.
- 2) **Detector:** Outdoor heat exchanger sensor (TH1)
- 3) **Detail of operation:**

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>




- Notes
- (1) When the outdoor heat exchanger temperature is in the range of 58~60°C, the speed is reduced by 6 rps at each 20 seconds.
 - (2) When the temperature is 60°C or higher, the compressor is stopped.
 - (3) When the outdoor heat exchanger temperature is in the range of 53~58°C, if the compressor command speed is been maintained and the operation has continued for more than 30 seconds at the same speed, it returns to the normal cooling operation.

(e) Cooling low outdoor air temperature protective control

- 1) **Operating conditions:** When the outdoor air temperature (TH2) is 22°C or lower continues for 20 seconds while the compressor command speed is other than 0 rps.
- 2) **Detail of operation:**
 - a) The lower limit of the compressor command speed is set to 40 (30) rps and even if the speed becomes lower than 40 (30) rps, the speed is kept to 40 (30) rps. However, when the thermo becomes OFF, the speed is reduced to 0 rps.
 - b) The upper limit of the compressor command speed is set to 60 (75) rps and even if the calculated result becomes higher than that after fuzzy calculation, the speed is kept to 60 (75) rps.

- Notes (1) Values in () are for outdoor air temperature is 22°C or 25°C



● Values of A, B, C, D, E, F


	Outdoor air temperature (°C)			
	A	B	C	D
First time	0	3	22	25
Since the seconds times	0	3	22	25

- 3) **Reset conditions:** When either of the following condition is satisfied
 - a) The outdoor air temperature (TH2) is D °C or higher.
 - b) The compressor command speed is 0 rps.

(f) Heating high pressure control

- 1) **Purpose:** Prevents anomalous high pressure operation during heating.
- 2) **Detector:** Indoor heat exchanger sensor (Th2)
- 3) **Detail of operation:**

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



- Notes
- (1) When the indoor heat exchanger temperature is in the range of B~C °C, the speed is reduced by 4 rps at each 20 seconds.
 - (2) When the indoor heat exchanger temperature is in the range of C~D °C, the speed is reduced by 8 rps at each 20 seconds. When the temperature is D °C or higher continues for 1 minute, the compressor is stopped.
 - (3) When the indoor heat exchanger temperature is in the range of A~B °C, if the compressor command speed is been maintained and the operation has continued for more than 20 seconds at the same speed, it returns to the normal heating operation.
 - (4) Indoor blower retains the fan tap when it enters in the high pressure control. Outdoor blower is operated in accordance with the speed.

● **Temperature list**

	Unit : °C			
	A	B	C	D
RPSmin < 90	45	52	57	58
90 < RPSmin < 108	45 ~ 43	52 ~ 45	57 ~ 48	56.5
108 ≤ RPSmin	45 ~ 43	52 ~ 45	57 ~ 48	51.5

Note (1) RPSmin: The lower one between the outdoor speed and the compressor command speed.


(g) Heating overload protective control

1) **Indoor unit side**

- a) **Operating conditions :** When the outdoor air temperature (TH2) is 17°C or higher continues for 30 seconds while the compressor command speed other than 0 rps.
- b) **Detail of operation :** The indoor fan is stepped up by 1 speed step. (Upper limit 10th speed)
- c) **Reset conditions :** The outdoor air temperature (TH2) is lower than 16°C.

2) **Outdoor unit side**

- a) **Operating conditions :** When the outdoor air temperature (TH2) is 13°C or 17°C or higher continues for 30 seconds while the compressor command speed other than 0 rps.
- b) **Detail of operation**
 - i) Taking the upper limit of compressor command speed range at 90 rps or 50 rps, if the output speed obtained with the fuzzy calculation exceeds the upper limit, the upper limit value is maintained.
 - ii) The lower limit of compressor command speed is set to 30 rps or 40 rps and even if the calculated result becomes lower than that after fuzzy calculation, the speed is kept to 30 rps or 40 rps. However, when the thermo becomes OFF, the speed is reduced to 0 prs.
 - iii) Inching prevention control is activated and inching prevention control is carried out with the minimum speed set at 30 rps or 40 rps.
- c) **Reset conditions:** The outdoor air temperature (TH2) is lower than 11°C.




(h) Heating low outdoor temperature protective control

1) **Operating conditions:** When the outdoor air temperature (TH2) is lower than 4°C or higher continues for 30 seconds while the compressor command speed is other than 0 rps.

2) **Detail of operation:** The lower limit compressor command speed is change as shown in the figure below.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



3) **Reset conditions:** When either of the following condition is satisfied.

- a) The outdoor air temperature (TH2) becomes 6°C.
- b) The compressor command speed is 0 rps.


(i) Compressor overheat protection

1) **Purpose:** It is designed to prevent deterioration of oil, burnout of motor coil and other trouble resulting from the compressor overheat.

2) **Detail of operation**

a) Speeds are controlled with temperature detected by the sensor (TH3) mounted on the discharge pipe.

(Example) Fuzzy



- Notes
- (1) When the discharge pipe temperature is in the range of 105~115°C, the speed is reduced by 4 rps.
 - (2) When the discharge pipe temperature is raised and continues operation for 20 seconds without changing, then the speed is reduced again by 4 rps.
 - (3) If the discharge pipe temperature is in the range of 95~105°C even when the compressor command speed is maintained for 180 second when the temperature is in the range of 95~105°C, the speed is raised by 1 rps and kept at that speed for 180 second. This process is repeated until the command speed is reached.
 - (4) Lower limit speed

Model	Item	Cooling	Heating
		Lower limit speed	25 rps

b) If the temperature of 115°C is detected by the sensor on the discharge pipe, then the compressor will stop immediately. When the discharge pipe temperature drops and the time delay of 3 minutes is over, the unit starts again within 1 hour but there is no start at the third time.

(j) Current safe

1) **Purpose:** Current is controlled not to exceed the upper limit of the setting operation current.

2) **Detail of operation:** Input current to the converter is monitored with the current sensor fixed on the printed circuit board of the outdoor unit and, if the operation current value reaches the limiting current value, the compressor command speed is reduced.

If the mechanism is actuated when the compressor command speed is less than 30 rps, the compressor is stopped immediately. Operation starts again after a delay time of 3 minutes.

(k) Current cut

- 1) **Purpose:** Inverter is protected from overcurrent.
- 2) **Detail of operation:** Output current from the inverter is monitored with a shunt resistor and, if the current exceeds the setting value, the compressor is stopped immediately. Operation starts again after a delay time of

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

This is a function for determining when there is trouble with the outdoor unit during air conditioning.

The compressor is stopped if any one of the following in item 1), 2) is satisfied. Once the unit is stopped by this function, it is not restarted.

- 1) When the input current is measured at 1 A or less for 3 continuous minutes or more.
- 2) If the outdoor unit sends a 0 rps signal to the indoor unit 3 times or more within 20 minutes of the power being turned on.

(m) Indoor fan motor protection

When the air conditioner is operating and the indoor fan motor is turned ON, if the indoor fan motor has operated at 300 rpm or under for more than 30 seconds, the unit enters first in the stop mode and then stops the entire system.

(n) Serial signal transmission error protection

- 1) **Purpose:** Prevents malfunction resulting from error on the indoor ↔ outdoor signals.
- 2) **Detail of operation:** If the compressor is operating and a serial signal cannot be received from the indoor control with outdoor control having serial signals continues for 7 minute and 35 seconds, the compressor is stopped.
After the compressor has been stopped, it will be restarted after the compressor start delay if a serial signal can be received again from the indoor control.

(o) Rotor lock

If the motor for the compressor does not turn after it has been started, it is determined that a compressor lock has occurred and the compressor is stopped.

(p) Outdoor fan motor protection

If the outdoor fan motor has operated at 75 rpm or under for more than 30 seconds, the compressor and fan motor are stopped.

(q) Outdoor fan control at low outdoor temperature

(i) Cooling

- 1) **Operating conditions:** When the outdoor air temperature (TH2) is 22°C or lower continues for 30 seconds while the compressor command speed is other than 0 rps.
- 2) **Detail of operation:** After the outdoor fan operates at A speed for 60 seconds; the corresponding outdoor heat exchanger temperature shall implement the following controls.

● Value of A

	Outdoor fan
Outdoor temperature > 10°C	2nd speed
Outdoor temperature ≤ 10°C	1st speed

- a) Outdoor heat exchanger temperature (TH1) ≤ 22°C
After the outdoor fan speed drops (down) to 1 speed for 60 seconds; if the outdoor heat exchanger temperature is lower than 22°C, gradually reduce the outdoor fan speed by 1 speed. (Lower limit 1st speed)
- b) 22°C < Outdoor heat exchanger temperature (TH1) ≤ 40°C
After the outdoor fan speed maintains at A speed for 20 seconds; if the outdoor heat exchanger temperature is 22°C~40°C, maintain outdoor fan speed.
- c) Outdoor heat exchanger temperature (TH1) > 40°C
After the outdoor fan speed rises (up) to 1 speed for 60 seconds; if the outdoor heat exchanger temperature is higher than 40°C, gradually increase outdoor fan speed by 1 speed. (Upper limit 3rd speed)

- 3) Reset conditions:** When either of the following conditions is satisfied
- a) The outdoor air temperature (TH2) is 24°C or higher.
 - b) The compressor command speed is 0 rps.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

seconds while the

compressor command speed is other than 0 rps.

- 2) Detail of operation:** The outdoor fan is stepped up by 1 speed step. (Upper limit 7th speed)
- 3) Reset conditions:** When either of the following conditions is satisfied
 - a) The outdoor air temperature (TH2) is 5°C or higher.
 - b) The compressor command speed is 0 rps.

(q) Refrigeration cycle system protection

1) Starting conditions

- a) When 5 minutes have elapsed after the compressor ON or the completion of the defrost control
- b) Other than the defrost control
- c) When, after meeting the conditions of a) and b) above, the compressor speed, indoor air temperature (Th1) and indoor heat exchanger temperature (Th2) have met the conditions in the following table for 5 minutes:

Operation mode	Compressor speed (N)	Indoor air temperature (Th1)	Indoor air temperature (Th1)/ Indoor heat exchanger temperature (Th2)
Cooling	$40 \leq N$	$10 \leq Th1 \leq 40$	$Th1 - 4 < Th2$
Heating	$40 \leq N$	$0 \leq Th1 \leq 40$	$Th2 < Th1 + 6$

2) Contents of control

- a) When the conditions of 1) above are met, the compressor stops.
- b) Error stop occurs when the compressor has stopped 3 times within 60 minutes.

3) Resetting condition

When the compressor has been turned OFF

10 MAINTENANCE DATA

(1) Cautions

(a) If you are disassembling and checking an air conditioner, be sure to turn off the power before beginning. When working

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

n working on an
work only after

discharging this electrical charge (to DC 10 V or lower).

(b) When taking out printed circuit boards, be sure to do so without exerting force on the circuit boards or package components.

(c) When disconnecting and connecting connectors, take hold of the connector housing and do not pull on the lead wires.

(2) Items to check before troubleshooting

(a) Have you thoroughly investigated the details of the trouble which the customer is complaining about?

(b) Is the air conditioner running? Is it displaying any self-diagnosis information?

(c) Is a power supply with the correct voltage connected?

(d) Are the control lines connecting the indoor and outdoor units wired correctly and connected securely?


(e) Is the outdoor unit's service valve open?

(3) Troubleshooting procedure (If the air conditioner does not run at all)


If the air conditioner does not run at all, diagnose the trouble using the following troubleshooting procedure. If the air conditioner is running but breaks down, proceed to troubleshooting step (4).

Important When all the following conditions are met, we say that the air conditioner will not run at all.

- (a) The RUN light does not light up.
- (b) The flaps do not open.
- (c) The indoor unit fan motors do not run.
- (d) The self-diagnosis display does not function.



(4) Troubleshooting procedure (If the air conditioner runs)



Note (1) Even in cases where only intermittent stop data are generated, the air conditioning system is normal. However, if the same protective operation recurs repeatedly (3 or more times), it will lead to customer complaints. Judge the conditions in comparison with the contents of the complaints.

(5) Self-diagnosis table

When this air conditioner performs an emergency stop, the reason why the emergency stop occurred is displayed by the flashing of display lights. If the air conditioner is operated using the remote controller 3 minutes or more after the emergency stop, the trouble display stops and the air conditioner resumes operation. ⁽¹⁾

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

Flashing pattern	Light	Display	Reason	Causes	Notes
1 time flash	ON	—	Heat exchanger sensor 1 error	<ul style="list-style-type: none"> Broken heat exchanger sensor 1 wire, poor connector connection Indoor PCB is faulty 	When a heat exchanger sensor 1 wire disconnection is detected while operation is stopped. (If a temperature of -28°C or lower is detected for 15 seconds, it is judged that the wire is disconnected.) (Not displayed during operation.)
2 time flash	ON	—	Room temperature sensor error	<ul style="list-style-type: none"> Broken room temperature sensor wire, poor connector connection Indoor PCB is faulty 	When a room temperature sensor wire disconnection is detected while operation is stopped. (If a temperature of -45°C or lower is detected for 15 seconds, it is judged that the wire is disconnected.) (Not displayed during operation.)
3 time flash	ON	—	Heat exchanger sensor 2 error	<ul style="list-style-type: none"> Broken heat exchanger sensor 2 wire, poor connector connection Indoor PCB is faulty 	When a heat exchanger sensor 2 wire disconnection is detected while operation is stopped. (If a temperature of -28°C or lower is detected for 15 seconds, it is judged that the wire is disconnected.) (Not displayed during operation.)
6 time flash	ON	E 16	Indoor fan motor error	<ul style="list-style-type: none"> Defective fan motor, poor connector connection 	When conditions for turning the indoor unit's fan motor on exist during air conditioner operation, an indoor unit fan motor speed of 300 rpm or lower is measured for 30 seconds or longer. (The air conditioner stops.)
Keeps flashing	1 time flash	E 38	Outdoor air temperature sensor error	<ul style="list-style-type: none"> Broken outdoor air temp. sensor wire, poor connector connection Outdoor PCB is faulty 	-55°C or lower is detected for 5 seconds continuously 3 times within 40 minutes after initial detection of this anomalous temperature. Or -55°C or higher is detected for within 20 seconds after power ON. (The compressor is stopped.)
Keeps flashing	2 time flash	E 37	Outdoor heat exchanger sensor error	<ul style="list-style-type: none"> Broken heat exchanger sensor wire, poor connector connection Outdoor PCB is faulty 	-55°C or lower is detected for 5 seconds continuously 3 times within 40 minutes after initial detection of this anomalous temperature. Or -55°C or higher is detected for within 20 seconds after power ON. (The compressor is stopped.)
Keeps flashing	4 time flash	E 39	Discharge pipe sensor error	<ul style="list-style-type: none"> Broken discharge pipe sensor wire, poor connector connection Outdoor PCB is faulty 	-25°C or lower is detected for 5 seconds continuously 3 times within 40 minutes after initial detection of this anomalous temperature. (The compressor is stopped.)
ON	1 time flash	E 42	Current cut	<ul style="list-style-type: none"> Compressor locking, open phase on compressor output, short circuit on power transistor, service valve is closed 	The compressor output current exceeds the set value during compressor start. (The air conditioner stops.)
ON	2 time flash	E 59	Trouble of outdoor unit	<ul style="list-style-type: none"> Broken compressor wire Compressor blockage 	When there is an emergency stop caused by trouble in the outdoor unit, or the input current value is found to be lower than the set value. (The air conditioner stops.)
ON	3 time flash	E 58	Current safe stop	<ul style="list-style-type: none"> Overload operation Overcharge Compressor locking 	When the compressor command speed is lower than the set value and the current safe has operated. (the compressor stops)
ON	4 time flash	E 51	Power transistor error	<ul style="list-style-type: none"> Broken power transistor 	When the power transistor is judged breakdown while compressor starts. (The compressor is stopped.)
ON	5 time flash	E 36	Over heat of compressor	<ul style="list-style-type: none"> Gas shortage, defective discharge pipe sensor, service valve is closed 	When the value of the discharge pipe sensor exceeds the set value. (The air conditioner stops.)
ON	6 time flash	E 5	Error of signal transmission	<ul style="list-style-type: none"> Defective power supply, Broken signal wire, defective indoor/outdoor PCB 	When there is no signal between the indoor PCB and outdoor PCB for 10 seconds or longer (when the power is turned on), or when there is no signal for 7 minute 35 seconds or longer (during operation)(the compressor is stopped).
ON	7 time flash	E 48	Outdoor fan motor error	<ul style="list-style-type: none"> Defective fan motor, poor connector connection 	When the outdoor unit's fan motor speed continues for 30 seconds or longer at 75 rpm or lower. (3 times) (The air conditioner stops.)
ON	Keeps flashing	E 35	Cooling high pressure protection	<ul style="list-style-type: none"> Overload operation, overcharge Broken outdoor heat exchange sensor wire Service valve is closed 	When the value of the outdoor heat exchanger sensor exceeds the set value.
2 time flash	2 time flash	E 60	Rotor lock	<ul style="list-style-type: none"> Defective compressor Open phase on compressor Defective outdoor PCB 	If the compressor motor's magnetic pole positions cannot be correctly detected when the compressor starts. (The air conditioner stops.)
5 time flash	ON	E 47	Active filter voltage error	<ul style="list-style-type: none"> Defective active filter 	When the wrong voltage connected for the power supply. When the outdoor PCB is faulty.
7 time flash	ON	E 57	Refrigeration cycle system protective control	<ul style="list-style-type: none"> Service valve is closed. Refrigerant is insufficient 	When refrigeration cycle system protective control operates.
—	—	E 1	Error of wired remote controller wiring	<ul style="list-style-type: none"> Broken wired remote controller wire, defective indoor PCB 	The wired remote controller wire Y is open. The wired remote controller wires X and Y are reversely connected. Noise is penetrating the wired remote controller lines. The wired remote controller or indoor PCB is faulty. (The communications circuit is faulty.)

Notes (1)The air conditioner cannot be restarted using the remote controller for 3 minutes after operation stops.

(2)The wired remote controller is optional parts.

(6) Service mode (Trouble mode access function)


This air conditioner is capable of recording error displays and protective stops (service data) which have occurred in the past. If self-diagnosis displays cannot be confirmed, it is possible to get a grasp of the conditions at the time trouble occurred by checking these service data.

(a) Explanation of terms

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>


Service mode	The service mode is the mode where service data are displayed by flashing of the display lights when the operations in item (b) below are performed with the indoor controller.
Service data	These are the contents of error displays and protective stops which occurred in the past in the air conditioner system. Error display contents and protective stop data from past anomalous operations of the air conditioner system are saved in the indoor unit controller's non-volatile memory (memory which is not erased when the power goes off). There are two types of data, self-diagnosis data and stop data, described below.
Self-diagnosis data	These are the data which display the reason why a stop occurred when an error display (self-diagnosis display) occurred in an indoor unit. Data are recorded for up to 5 previous occurrences. Data which are older than the 5th previous occurrence are erased. In addition, data on the temperature of each sensor (room temperature, indoor heat exchanger, outdoor heat exchanger, outdoor air temperature, discharge pipe), remote controller information (operation switching, fan speed switching) are recorded when trouble occurs, so more detailed information can be checked.
Stop data	These are the data which display the reason by a stop occurred when the air conditioning system performed protective stops, etc. in the past. Even if stop data alone are generated, the system restarts automatically. (After executing the stop mode while the display is normal, the system restarts automatically.) Data for up to 10 previous occasions are stored. Data older than the 10th previous occasion are erased. (Important) In cases where transient stop data only are generated, the air conditioner system may still be normal. However, if the same protective stop occurs frequently (3 or more times), it could lead to customer complaints.

(b) Service mode display procedure



*3: To count the number of flashes in the service mode, count the number of flashes after the light lights up for 1.5 second initially (start signal). (The time that the light lights up for 1.5 second (start signal) is not counted in the number of flashes.)

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



*4: When in the service mode, when the remote controller settings (operation switching, fan speed switching, temperature setting) are set as shown in the following table and sent to the air conditioner unit, the unit switches to display of service data.

1) Self-diagnosis data

What are Self-These are control data (reasons for stops, temperature at each sensor, remote controller information) diagnosis Data? from the time when there were error displays (abnormal stops) in the indoor unit in the past. Data from up to 5 previous occasions are stored in memory. Data older than the 5th previous occasion are erased. The temperature setting indicates how many occasions previous to the present setting the error display data are and the operation switching and fan speed switching data show the type of data.

Remote controller setting		Contents of output data
Operation switching	Fan speed switching	
Cooling	MED	Displays the reason for stopping display in the past (error code).
	HI	Displays the room temperature sensor temperature at the time the error code was displayed in the past.
	AUTO	Displays the indoor heat exchanger sensor temperature at the time the error code was displayed in the past.
Heating	LO	Displays the remote controller information at the time the error code was displayed in the past.
	MED	Displays the outdoor air temperature sensor temperature at the time the error code was displayed in the past.
	HI	Displays the outdoor heat exchanger sensor temperature at the time the error code was displayed in the past.
	AUTO	Displays the discharge pipe sensor temperature at the time the error code was displayed in the past.

Remote controller setting	Indicates the number of occasions previous to the present the error display data are from.
Temperature setting	
21°C	1 time previous (previous time)
22°C	2 times previous
23°C	3 times previous
24°C	4 times previous
25°C	5 times previous

Only for indoor heat exchanger sensor 2

Remote controller setting	Indicates the number of occasions previous to the present the error display data are from.
Temperature setting	
26°C	1 time previous (previous time)
27°C	2 times previous
28°C	3 times previous
29°C	4 times previous
30°C	5 times previous

(Example)

Remote controller setting			Displayed data
Operation switching	Fan speed switching	Temperature setting	
Все каталоги и инструкции здесь: http://splitoff.ru/tehn-doc.html			error was displayed.
Cooling	MED	22°C	Displays the reason for the stop (error code) 2 times previous when an error was displayed.
		23°C	Displays the reason for the stop (error code) 3 times previous when an error was displayed.
		24°C	Displays the reason for the stop (error code) 4 times previous when an error was displayed.
		25°C	Displays the reason for the stop (error code) 5 times previous when an error was displayed.

2) Stop data

Remote controller setting			Displayed data
Operation switching	Fan speed switching	Temperature setting	
Cooling	LO	21°C	Displays the reason for the stop (stop code) the previous time when the air conditioner was stopped by protective stop control.
		22°C	Displays the reason for the stop (stop code) 2 times previous when the air conditioner was stopped by protective stop control.
		23°C	Displays the reason for the stop (stop code) 3 times previous when the air conditioner was stopped by protective stop control.
		24°C	Displays the reason for the stop (stop code) 4 times previous when the air conditioner was stopped by protective stop control.
		25°C	Displays the reason for the stop (stop code) 5 times previous when the air conditioner was stopped by protective stop control.
		26°C	Displays the reason for the stop (stop code) 6 times previous when the air conditioner was stopped by protective stop control.
		27°C	Displays the reason for the stop (stop code) 7 times previous when the air conditioner was stopped by protective stop control.
		28°C	Displays the reason for the stop (stop code) 8 times previous when the air conditioner was stopped by protective stop control.
		29°C	Displays the reason for the stop (stop code) 9 times previous when the air conditioner was stopped by protective stop control.
		30°C	Displays the reason for the stop (stop code) 10 times previous when the air conditioner was stopped by protective stop control.


(c) **Error code, stop code table** (Assignment of error codes and stop codes is done in common for all models.)

Number of flashes when in service mode		Stop code or Error code	Error content	Cause	Occurrence conditions	Error display	Auto recovery
RUN light (10's digit)	TIMER light (1's digit)						
Все каталоги и инструкции здесь: http://splitoff.ru/tehn-doc.html							
	flash	05	seconds (if communications have recovered)	Power supply cables and signal lines are improperly wired. Indoor or outdoor PCB are faulty.	communications signals from either the outdoor unit or the indoor unit being detected correctly.	○	—
3 time flash	5 time flash	35	Cooling high pressure control	Cooling overload operation. Outdoor unit fan speed drops. Outdoor heat exchanger sensor is short circuit.	When the outdoor heat exchanger sensor's value exceeds the set value.	○ (5 times)	○
	6 time flash	36	Compressor overheat 115°C	Refrigerant is insufficient. Discharge pipe sensor is faulty. Service valve is closed.	When the discharge pipe sensor's value exceeds the set value.	○ (2 times)	○
	7 time flash	37	Outdoor heat exchanger sensor is abnormal	Outdoor heat exchanger sensor wire is disconnected. Connector connections are poor. Outdoor PCB is faulty.	-55°C or lower is detected for 5 seconds continuously 3 times within 40 minutes after initial detection of this anomalous temperature. Or -55°C higher is detected for 5 seconds continuously within 20 seconds after power ON.	○ (3 times)	○
	8 time flash	38	Outdoor air temperature sensor is abnormal	Outdoor air temperature sensor wire is disconnected. Connector connections are poor. Outdoor PCB is faulty.	-55°C or lower is detected for 5 seconds continuously 3 times within 40 minutes after initial detection of this anomalous temperature. Or -55°C higher is detected for 5 seconds continuously within 20 seconds after power ON.	○ (3 times)	○
	9 time flash	39	Discharge pipe sensor is abnormal (anomalous stop)	Discharge pipe sensor wire is disconnected. Connector connections are poor. Outdoor PCB is faulty.	-25°C or lower is detected for 5 seconds continuously 3 times within 40 minutes after initial detection of this anomalous temperature.	○ (3 times)	○
4 time flash	2 time flash	42	Current cut	Compressor lock. Compressor wiring short circuit. Compressor output is open phase. Outdoor PCB is faulty. Service valve is closed. Electronic expansion valve is faulty. Compressor is faulty.	Compressor start fails 42 times in succession and the reason for the final failure is current cut.	○ (2 times)	○
	7 time flash	47	Active filter voltage error	Defective active filter	When the wrong voltage connected for the power supply. When the outdoor PCB is faulty.	○	—
	8 time flash	48	Outdoor unit's fan motor is abnormal	Outdoor fan motor is faulty. Connector connections are poor. Outdoor PCB is faulty.	When a fan speed of 75 rpm or lower continues for 30 seconds or longer.	○ (3 times)	○
5 time flash	1 time flash	51	Short circuit in the power transistor (high side) Current cut circuit breakdown	Outdoor PCB is faulty. Power transistor is damaged.	When it is judged that the power transistor was damaged at the time the compressor started.	○	—
	7 time flash	57	Refrigeration cycle system protective control	Service valve is closed. Refrigerant is insufficient.	When refrigeration cycle system protective control operates.	○ (3 times)	○
	8 time flash	58	Current safe	Refrigerant is overcharge. Compressor lock. Overload operation.	When there is a current safe stop during operation.	—	○
	9 time flash	59	Compressor wiring is unconnection Voltage drop Low speed protective control	Compressor wiring is disconnected. Power transistor is damaged. Power supply construction is defective. Outdoor PCB is faulty. Compressor is faulty.	When the current is 1A or less at the time the compressor started. When the power supply voltage drops during operation. When the compressor command speed is lower than 32 rps for 60 minutes.	○	○
6 time flash	OFF	60	Rotor lock	Compressor is faulty. Compressor output is open phase. Electronic expansion valve is faulty. Overload operation. Outdoor PCB is faulty.	After the compressor starts, when the compressor stops due to rotor lock.	○ (2 times)	○
	1 time flash	61	Connection lines between the indoor and outdoor units are faulty	Connection lines are faulty. Indoor or outdoor PCB are faulty.	When 10 seconds passes after the power is turned on without communications signals from the indoor or outdoor unit being detected correctly.	○	—
	2 time flash	62	Serial transmission error	Indoor or outdoor PCB are faulty. Noise is causing faulty operation.	When 7 minute 35 seconds passes without communications signals from either the outdoor unit or the indoor unit being detected correctly.	○	—
8 time flash	OFF	80	Indoor unit's fan motor is abnormal	Indoor fan motor is faulty. Connector connections are poor. Indoor PCB is faulty.	When the indoor unit's fan motor is detected to be running at 300 rpm or lower speed with the fan motor in the ON condition while the air conditioner is running.	○	—
	2 time flash	82	Indoor heat exchanger sensor is abnormal (anomalous stop)	Indoor heat exchanger sensor wire is disconnected. Connector connections are poor.	When a temperature of -28°C or lower is sensed continuously for 40 minutes during heating operation. (the compressor stops).	○	—
	4 time flash	84	Anti-condensation control	High humidity condition. Humidity sensor is faulty.	Anti-condensation prevention control is operating.	—	○
	5 time flash	85	Anti-frost control	Indoor unit fan speed drops. Indoor heat exchanger sensor is broken wire.	When the anti-frost control operates and the compressor stops during cooling operation.	—	○
	6 time flash	86	Heating high pressure control	Heating overload operation. Indoor unit fan speed drops. Indoor heat exchanger sensor is short circuit.	When high pressure control operates during heating operation and the compressor stops.	—	○

Note (1) The number of flashes when in the Service Mode do not include the 1.5 second period when the lights light up at first (starting signal). (See the example shown below.)

- In the case of current cut (example: stop code “42”)
 - The RUN light (10's digit) flashes 4 times and the TIMER light (1's digit) flashes 2 times.
 - $4 \times 10 + 2 \times 1 = 42 \rightarrow$ From the table, read the instructions for error code 42, “current cut”.

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



- (2) Error display:
- Is not displayed. (automatic recovery only)
 - Displayed.
- If there is a () displayed, the error display shows the number of times that an auto recovery occurred for the same reason has reached the number of times in ().
- If no () is displayed, the error display shows that the trouble has occurred once.
- (3) Auto Recovery:
- Does not occur
 - Auto recovery occurs.

(d) Remote controller information tables

1) Operation switching

Display pattern when in service mode RUN light (Operation switching)	Operation switching when there is an abnormal stop
0	AUTO
1	DRY
2	COOL
3	FAN
4	HEAT


2) Fan speed switching

Display pattern when in service mode TIMER light (Fan speed switching)	Fan speed switching when there is an abnormal stop
0	AUTO
2	HI
3	MED
4	LO
6	HI POWER
7	ECONO

* If no data are recorded (error code is normal), the information display in the remote controller becomes as follows.

Remote controller setting	Display when error code is normal.
Operation switching	AUTO
Fan speed switching	AUTO

(Example): Operation switching, fan speed switching, cooling HI



(e) Room temperature sensor, indoor heat exchanger sensor, outdoor air temperature sensor, outdoor heat exchanger sensor table

Units: °C


Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

		TIMER light									
		0	1	2	3	4	5	6	7	8	9
Buzzer sound	(10's digit)										
Yes (sounds for 0.1 second)	6	-60	-61	-62	-63	-64					
	5	-50	-51	-52	-53	-54	-55	-56	-57	-58	-59
	4	-40	-41	-42	-43	-44	-45	-46	-47	-48	-49
	3	-30	-31	-32	-33	-34	-35	-36	-37	-38	-39
	2	-20	-21	-22	-23	-24	-25	-26	-27	-28	-29
	1	-10	-11	-12	-13	-14	-15	-16	-17	-18	-19
	0		-1	-2	-3	-4	-5	-6	-7	-8	-9
No (does not sound)	0	0	1	2	3	4	5	6	7	8	9
	1	10	11	12	13	14	15	16	17	18	19
	2	20	21	22	23	24	25	26	27	28	29
	3	30	31	32	33	34	35	36	37	38	39
	4	40	41	42	43	44	45	46	47	48	49
	5	50	51	52	53	54	55	56	57	58	59
	6	60	61	62	63	64	65	66	67	68	69
	7	70	71	72	73	74	75	76	77	78	79
	8	80	81	82	83	84	85	86	87	88	89
	9	90	91	92	93	94	95	96	97	98	99

* If no data are recorded (error code is normal), the display for each sensor becomes as shown below.

Sensor name	Sensor value displayed when the error code is normal
Room temperature sensor	-64°C
Indoor heat exchanger sensor	-64°C
Outdoor air temperature sensor	-64°C
Outdoor heat exchanger sensor	-64°C

(Example) Room temperature, indoor heat exchanger, outdoor air temperature, outdoor heat exchanger: “-9°C”



(f) Discharge pipe sensor table

Units: °C

TIMER light (1's digit)

7 8 9

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>


Buzzer sound														
Yes (sounds for 0.1 second)	3	-60	-62	-64										
	2	-40	-42	-44	-46	-48	-50	-52	-54	-56	-58			
	1	-20	-22	-24	-26	-28	-30	-32	-34	-36	-38			
	0	/	-2	-4	-6	-8	-10	-12	-14	-16	-18			
No (does not sound)	0	0	2	4	6	8	10	12	14	16	18			
	1	20	22	24	26	28	30	32	34	36	38			
	2	40	42	44	46	48	50	52	54	56	58			
	3	60	62	64	66	68	70	72	74	76	78			
	4	80	82	84	86	88	90	92	94	96	98			
	5	100	102	104	106	108	110	112	114	116	118			
	6	120	122	124	126	128	130	132	134	136	138			
	7	140	142	144	146	148	150							

* If no data are recorded (error code is normal), the display for each sensor becomes as shown below.

Sensor name	Sensor value displayed when the error code is normal
Discharge pipe sensor	-64°C

(Example) Discharge pipe temperature: "122°C"

* In the case of discharge pipe data, multiply the reading value by 2. (Below, 61 x 2 = "122°C")



Service data record form

Customer		Model	
Date of investigation			
Machine name			

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>


температура (setting)	уровень (switching)	тип (sensor switching)	описание (description)	размер (1/8" (16.0))	размер (1/4" (20.0))	размер (3/8" (24.0))	размер (1/2" (31.5))	размер (3/4" (47.5))	размер (1" (63.5))	размер (1 1/4" (95.0))	размер (1 1/2" (111.8))	размер (1 3/4" (139.7))	размер (2" (177.8))	размер (2 1/4" (215.7))	размер (2 1/2" (253.7))	размер (2 3/4" (291.6))	размер (3" (381.0))	размер (3 1/4" (463.5))	размер (3 1/2" (508.0))	размер (3 3/4" (595.0))	размер (4" (762.0))	размер (4 1/4" (863.5))	размер (4 1/2" (914.0))	размер (4 3/4" (1016.0))	размер (5" (1270.0))	размер (5 1/4" (1371.5))	размер (5 1/2" (1422.0))	размер (5 3/4" (1519.0))	размер (6" (1524.0))	размер (6 1/4" (1625.5))	размер (6 1/2" (1676.0))	размер (6 3/4" (1773.0))	размер (7" (1778.0))	размер (7 1/4" (1879.5))	размер (7 1/2" (1930.0))	размер (7 3/4" (1981.0))	размер (8" (2032.0))	размер (8 1/4" (2133.5))	размер (8 1/2" (2184.0))	размер (8 3/4" (2281.0))	размер (9" (2286.0))	размер (9 1/4" (2387.5))	размер (9 1/2" (2438.0))	размер (9 3/4" (2535.0))	размер (10" (2540.0))	размер (10 1/4" (2641.5))	размер (10 1/2" (2692.0))	размер (10 3/4" (2789.0))	размер (11" (2794.0))	размер (11 1/4" (2895.5))	размер (11 1/2" (2946.0))	размер (11 3/4" (3043.0))	размер (12" (3048.0))	размер (12 1/4" (3149.5))	размер (12 1/2" (3200.0))	размер (12 3/4" (3297.0))	размер (13" (3302.0))	размер (13 1/4" (3403.5))	размер (13 1/2" (3454.0))	размер (13 3/4" (3551.0))	размер (14" (3556.0))	размер (14 1/4" (3657.5))	размер (14 1/2" (3708.0))	размер (14 3/4" (3805.0))	размер (15" (3810.0))	размер (15 1/4" (3911.5))	размер (15 1/2" (3962.0))	размер (15 3/4" (4059.0))	размер (16" (4064.0))	размер (16 1/4" (4165.5))	размер (16 1/2" (4216.0))	размер (16 3/4" (4313.0))	размер (17" (4318.0))	размер (17 1/4" (4419.5))	размер (17 1/2" (4470.0))	размер (17 3/4" (4567.0))	размер (18" (4572.0))	размер (18 1/4" (4673.5))	размер (18 1/2" (4724.0))	размер (18 3/4" (4821.0))	размер (19" (4826.0))	размер (19 1/4" (4927.5))	размер (19 1/2" (4978.0))	размер (19 3/4" (5075.0))	размер (20" (5080.0))	размер (20 1/4" (5181.5))	размер (20 1/2" (5232.0))	размер (20 3/4" (5329.0))	размер (21" (5334.0))	размер (21 1/4" (5435.5))	размер (21 1/2" (5486.0))	размер (21 3/4" (5583.0))	размер (22" (5588.0))	размер (22 1/4" (5689.5))	размер (22 1/2" (5740.0))	размер (22 3/4" (5837.0))	размер (23" (5842.0))	размер (23 1/4" (5943.5))	размер (23 1/2" (5994.0))	размер (23 3/4" (6091.0))	размер (24" (6096.0))	размер (24 1/4" (6197.5))	размер (24 1/2" (6248.0))	размер (24 3/4" (6345.0))	размер (25" (6350.0))	размер (25 1/4" (6451.5))	размер (25 1/2" (6502.0))	размер (25 3/4" (6599.0))	размер (26" (6604.0))	размер (26 1/4" (6705.5))	размер (26 1/2" (6756.0))	размер (26 3/4" (6853.0))	размер (27" (6858.0))	размер (27 1/4" (6959.5))	размер (27 1/2" (7010.0))	размер (27 3/4" (7107.0))	размер (28" (7112.0))	размер (28 1/4" (7213.5))	размер (28 1/2" (7264.0))	размер (28 3/4" (7361.0))	размер (29" (7366.0))	размер (29 1/4" (7467.5))	размер (29 1/2" (7518.0))	размер (29 3/4" (7615.0))	размер (30" (7620.0))	размер (30 1/4" (7721.5))	размер (30 1/2" (7772.0))	размер (30 3/4" (7869.0))	размер (31" (7874.0))	размер (31 1/4" (7975.5))	размер (31 1/2" (8026.0))	размер (31 3/4" (8123.0))	размер (32" (8128.0))	размер (32 1/4" (8229.5))	размер (32 1/2" (8280.0))	размер (32 3/4" (8377.0))	размер (33" (8382.0))	размер (33 1/4" (8483.5))	размер (33 1/2" (8534.0))	размер (33 3/4" (8631.0))	размер (34" (8636.0))	размер (34 1/4" (8737.5))	размер (34 1/2" (8788.0))	размер (34 3/4" (8885.0))	размер (35" (8890.0))	размер (35 1/4" (8991.5))	размер (35 1/2" (9042.0))	размер (35 3/4" (9139.0))	размер (36" (9144.0))	размер (36 1/4" (9245.5))	размер (36 1/2" (9296.0))	размер (36 3/4" (9393.0))	размер (37" (9398.0))	размер (37 1/4" (9499.5))	размер (37 1/2" (9550.0))	размер (37 3/4" (9647.0))	размер (38" (9652.0))	размер (38 1/4" (9753.5))	размер (38 1/2" (9804.0))	размер (38 3/4" (9901.0))	размер (39" (9906.0))	размер (39 1/4" (10007.5))	размер (39 1/2" (10058.0))	размер (39 3/4" (10155.0))	размер (40" (10160.0))	размер (40 1/4" (10261.5))	размер (40 1/2" (10312.0))	размер (40 3/4" (10409.0))	размер (41" (10414.0))	размер (41 1/4" (10515.5))	размер (41 1/2" (10566.0))	размер (41 3/4" (10663.0))	размер (42" (10668.0))	размер (42 1/4" (10769.5))	размер (42 1/2" (10820.0))	размер (42 3/4" (10917.0))	размер (43" (10922.0))	размер (43 1/4" (11023.5))	размер (43 1/2" (11074.0))	размер (43 3/4" (11171.0))	размер (44" (11176.0))	размер (44 1/4" (11277.5))	размер (44 1/2" (11328.0))	размер (44 3/4" (11425.0))	размер (45" (11430.0))	размер (45 1/4" (11531.5))	размер (45 1/2" (11582.0))	размер (45 3/4" (11679.0))	размер (46" (11684.0))	размер (46 1/4" (11785.5))	размер (46 1/2" (11836.0))	размер (46 3/4" (11933.0))	размер (47" (11938.0))	размер (47 1/4" (12039.5))	размер (47 1/2" (12090.0))	размер (47 3/4" (12187.0))	размер (48" (12192.0))	размер (48 1/4" (12293.5))	размер (48 1/2" (12344.0))	размер (48 3/4" (12441.0))	размер (49" (12446.0))	размер (49 1/4" (12547.5))	размер (49 1/2" (12598.0))	размер (49 3/4" (12695.0))	размер (50" (12700.0))	размер (50 1/4" (12801.5))	размер (50 1/2" (12852.0))	размер (50 3/4" (12949.0))	размер (51" (12954.0))	размер (51 1/4" (13055.5))	размер (51 1/2" (13106.0))	размер (51 3/4" (13203.0))	размер (52" (13208.0))	размер (52 1/4" (13309.5))	размер (52 1/2" (13360.0))	размер (52 3/4" (13457.0))	размер (53" (13462.0))	размер (53 1/4" (13563.5))	размер (53 1/2" (13614.0))	размер (53 3/4" (13711.0))	размер (54" (13716.0))	размер (54 1/4" (13817.5))	размер (54 1/2" (13868.0))	размер (54 3/4" (13965.0))	размер (55" (13970.0))	размер (55 1/4" (14071.5))	размер (55 1/2" (14122.0))	размер (55 3/4" (14219.0))	размер (56" (14224.0))	размер (56 1/4" (14325.5))	размер (56 1/2" (14376.0))	размер (56 3/4" (14473.0))	размер (57" (14478.0))	размер (57 1/4" (14579.5))	размер (57 1/2" (14630.0))	размер (57 3/4" (14727.0))	размер (58" (14732.0))	размер (58 1/4" (14833.5))	размер (58 1/2" (14884.0))	размер (58 3/4" (14981.0))	размер (59" (14986.0))	размер (59 1/4" (15087.5))	размер (59 1/2" (15138.0))	размер (59 3/4" (15235.0))	размер (60" (15240.0))	размер (60 1/4" (15341.5))	размер (60 1/2" (15392.0))	размер (60 3/4" (15489.0))	размер (61" (15494.0))	размер (61 1/4" (15595.5))	размер (61 1/2" (15646.0))	размер (61 3/4" (15743.0))	размер (62" (15748.0))	размер (62 1/4" (15849.5))	размер (62 1/2" (15900.0))	размер (62 3/4" (16007.0))	размер (63" (16012.0))	размер (63 1/4" (16113.5))	размер (63 1/2" (16164.0))	размер (63 3/4" (16261.0))	размер (64" (16266.0))	размер (64 1/4" (16367.5))	размер (64 1/2" (16418.0))	размер (64 3/4" (16515.0))	размер (65" (16520.0))	размер (65 1/4" (16621.5))	размер (65 1/2" (16672.0))	размер (65 3/4" (16769.0))	размер (66" (16774.0))	размер (66 1/4" (16875.5))	размер (66 1/2" (16926.0))	размер (66 3/4" (17023.0))	размер (67" (17028.0))	размер (67 1/4" (17129.5))	размер (67 1/2" (17180.0))	размер (67 3/4" (17277.0))	размер (68" (17282.0))	размер (68 1/4" (17383.5))	размер (68 1/2" (17434.0))	размер (68 3/4" (17531.0))	размер (69" (17536.0))	размер (69 1/4" (17637.5))	размер (69 1/2" (17688.0))	размер (69 3/4" (17785.0))	размер (70" (17790.0))	размер (70 1/4" (17891.5))	размер (70 1/2" (17942.0))	размер (70 3/4" (18039.0))	размер (71" (18044.0))	размер (71 1/4" (18145.5))	размер (71 1/2" (18196.0))	размер (71 3/4" (18293.0))	размер (72" (18298.0))	размер (72 1/4" (18399.5))	размер (72 1/2" (18450.0))	размер (72 3/4" (18547.0))	размер (73" (18552.0))	размер (73 1/4" (18653.5))	размер (73 1/2" (18704.0))	размер (73 3/4" (18801.0))	размер (74" (18806.0))	размер (74 1/4" (18907.5))	размер (74 1/2" (18958.0))	размер (74 3/4" (19055.0))	размер (75" (19060.0))	размер (75 1/4" (19161.5))	размер (75 1/2" (19212.0))	размер (75 3/4" (19309.0))	размер (76" (19314.0))	размер (76 1/4" (19415.5))	размер (76 1/2" (19466.0))	размер (76 3/4" (19563.0))	размер (77" (19568.0))	размер (77 1/4" (19669.5))	размер (77 1/2" (19720.0))	размер (77 3/4" (19817.0))	размер (78" (19822.0))	размер (78 1/4" (19923.5))	размер (78 1/2" (19974.0))	размер (78 3/4" (20071.0))	размер (79" (20076.0))	размер (79 1/4" (20177.5))	размер (79 1/2" (20228.0))	размер (79 3/4" (20325.0))	размер (80" (20330.0))	размер (80 1/4" (20431.5))	размер (80 1/2" (20482.0))	размер (80 3/4" (20579.0))	размер (81" (20584.0))	размер (81 1/4" (20685.5))	размер (81 1/2" (20736.0))	размер (81 3/4" (20833.0))	размер (82" (20838.0))	размер (82 1/4" (20939.5))	размер (82 1/2" (20990.0))	размер (82 3/4" (21087.0))	размер (83" (21092.0))	размер (83 1/4" (21193.5))	размер (83 1/2" (21244.0))	размер (83 3/4" (21341.0))	размер (84" (21346.0))	размер (84 1/4" (21447.5))	размер (84 1/2" (21498.0))	размер (84 3/4" (21595.0))	размер (85" (21600.0))	размер (85 1/4" (21701.5))	размер (85 1/2" (21752.0))	размер (85 3/4" (21849.0))	размер (86" (21854.0))	размер (86 1/4" (21955.5))	размер (86 1/2" (22006.0))	размер (86 3/4" (22103.0))	размер (87" (22108.0))	размер (87 1/4" (22209.5))	размер (87 1/2" (22260.0))	размер (87 3/4" (22357.0))	размер (88" (22362.0))	размер (88 1/4" (22463.5))	размер (88 1/2" (22514.0))	размер (88 3/4" (22611.0))	размер (89" (22616.0))	размер (89 1/4" (22717.5))	размер (89 1/2" (22768.0))	размер (89 3/4" (22865.0))	размер (90" (22870.0))	размер (90 1/4" (22971.5))	размер (90 1/2" (23022.0))	размер (90 3/4" (23119.0))	размер (91" (23124.0))	размер (91 1/4" (23225.5))	размер (91 1/2" (23276.0))	размер (91 3/4" (23373.0))	размер (92" (23378.0))	размер (92 1/4" (23479.5))	размер (92 1/2" (23530.0))	размер (92 3/4" (23627.0))	размер (93" (23632.0))	размер (93 1/4" (23733.5))	размер (93 1/2" (23784.0))	размер (93 3/4" (23881.0))	размер (94" (23886.0))	размер (94 1/4" (23987.5))	размер (94 1/2" (24038.0))	размер (94 3/4" (24135.0))	размер (95" (24140.0))	размер (95 1/4" (24241.5))	размер (95 1/2" (24292.0))	размер (95 3/4" (24389.0))	размер (96" (24394.0))	размер (96 1/4" (24495.5))	размер (96 1/2" (24546.0))	размер (96 3/4" (24643.0))	размер (97" (24648.0))	размер (97 1/4" (24749.5))	размер (97 1/2" (24800.0))	размер (97 3/4" (24897.0))	размер (98" (24902.0))	размер (98 1/4" (25003.5))	размер (98 1/2" (25054.0))	размер (98 3/4" (25151.0))	размер (99" (25156.0))	размер (99 1/4" (25257.5))	размер (99 1/2" (25308.0))	размер (99 3/4" (25405.0))	размер (100" (25410.0))	размер (100 1/4" (25511.5))	размер (100 1/2" (25562.0))	размер (100 3/4" (25659.0))	размер (101" (25664.0))	размер (101 1/4" (25765.5))	размер (101 1/2" (25816.0))	размер (101 3/4" (25913.0))	размер (102" (25918.0))	размер (102 1/4" (26019.5))	размер (102 1/2" (26070.0))	размер (102 3/4" (26167.0))	размер (103" (26172.0))	размер (103 1/4" (26273.5))	размер (103 1/2" (26324.0))	размер (103 3/4" (26421.0))	размер (104" (26426.0))	размер (104 1/4" (26527.5))	размер (104 1/2" (26578.0))	размер (104 3/4" (26675.0))	размер (105" (26680.0))	размер (105 1/4" (26781.5))	размер (105 1/2" (26832.0))	размер (105 3/4" (26929.0))	размер (106" (26934.0))	размер (106 1/4" (27035.5))	размер (106 1/2" (27086.0))	размер (106 3/4" (27183.0))	размер (107" (27188.0))	размер (107 1/4" (27289.5))	размер (107 1/2" (27340.0))	размер (107 3/4" (27437.0))	размер (108" (27442.0))	размер (108 1/4" (27543.5))	размер (108 1/2" (27594.0))	размер (108 3/4" (27691.0))	размер (109" (27696.0))	размер (109 1/4" (27797.5))	размер (109 1/2" (27848.0))	размер (109 3/4" (27945.0))	размер (110" (27950.0))	размер (110 1/4" (28051.5))	размер (110 1/2" (28102.0))	размер (110 3/4" (28199.0))	размер (111" (28204.0))	размер (111 1/4" (28305.5))	размер (111 1/2" (28356.0))	размер (111 3/4" (28453.0))	размер (112" (28458.0))	размер (112 1/4" (28559.5))	размер (112 1/2" (28610.0))	размер (112 3/4" (28707.0))	размер (113" (28712.0))	размер (113 1/4" (28813.5))	размер (113 1/2" (28864.0))	размер (113 3/4" (28961.0))	размер (114" (28966.0))	размер (114 1/4" (29067.5))	размер (114 1/2" (29118.0))	размер (114 3/4" (29215.0))	размер (115" (29220.0))	размер (115 1/4" (29321.5))	размер (115 1/2" (29372.0))	размер (115 3/4" (29469.0))	размер (116" (29474.0))	размер (116 1/4" (29575.5))	размер (116 1/2" (29626.0))	размер (116 3/4" (29723.0))	размер (117" (29728.0))	размер (117 1/4" (29829.5))	размер (117 1/2" (29880.0))	размер (117 3/4" (29977.0))	размер (118" (29982.0))	размер (118 1/4" (30083.5))	размер (118 1/2" (30134.0))	размер (118 3/4" (30231.0))	размер (119" (30236.0))	размер (119 1/4" (30337.5))	размер (119 1/2" (30388.0))	размер (119 3/4" (30485.0))	размер (120" (30490.0))	размер (120 1/4" (30591.5))	размер (120 1/2" (30642.0))	размер (120 3/4" (30739.0))	размер (121" (30744.0))	размер (121 1/4" (30845.5))	размер (121 1/2" (30896.0))	размер (121 3/4" (30993.0))	размер (122" (30998.0))	размер (122 1/4" (31099.5))	размер (122 1/2" (31150.0))	размер (122 3/4" (31247.0))	размер (123" (31252.0))	размер (123 1/4" (31353.5))	размер (123 1/2" (31404.0))	размер (123 3/4" (31501.0))	размер (124" (31506.0))	размер (124 1/4" (31607.5))	размер (124 1/2" (31658.0))	размер (124 3/4" (31755.0))	размер (125" (31760.0))	размер (125 1/4" (31861.5))	размер (125 1/2" (31912.0))	размер (125 3/4" (32009.0))	размер (126" (3
-----------------------	---------------------	------------------------	------------------------	----------------------	----------------------	----------------------	----------------------	----------------------	--------------------	------------------------	-------------------------	-------------------------	---------------------	-------------------------	-------------------------	-------------------------	---------------------	-------------------------	-------------------------	-------------------------	---------------------	-------------------------	-------------------------	--------------------------	----------------------	--------------------------	--------------------------	--------------------------	----------------------	--------------------------	--------------------------	--------------------------	----------------------	--------------------------	--------------------------	--------------------------	----------------------	--------------------------	--------------------------	--------------------------	----------------------	--------------------------	--------------------------	--------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	---------------------------	---------------------------	---------------------------	-----------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	------------------------	----------------------------	----------------------------	----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-------------------------	-----------------------------	-----------------------------	-----------------------------	-----------------

(7) Inspection procedures corresponding to detail of trouble


Sensor error

[Broken sensor wire, connector poor connection]


Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



◆ Discharge pipe sensor temperature characteristics




◆ Sensor temperature characteristics (Room temp., indoor heat exchanger temp., outdoor heat exchanger temp., outdoor air temp.)



Indoor fan motor error

[Defective fan motor, connector poor connection, defective indoor PCB]




Notes (1) See pages 68 for the fan motor and indoor PCB check procedure.
 (2) After making sure the fan motor and indoor PCB are normal, connect the connectors and confirm that the fan motor is turning.
 (If power is turned on while one or the other is broken down, it could cause the other to break down also.)

Current cut


[Compressor lock, Compressor wiring short circuit, Compressor output is open phase, Outdoor PCB is faulty, Service valve is closed, EEV is faulty, Compressor faulty.]

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



Current safe stop


[Overload operation, compressor lock, overcharge]



Over heat of compressor


[Gas shortage, defective discharge pipe sensor]

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>




Error of signal transmission

[Wiring error including power cable, defective indoor/ outdoor PCB]




Trouble of outdoor unit

[Insufficient refrigerant amount, Faulty power transistor, Broken compressor wire]
 [Service valve close, Defective EEV, Defective outdoor PCB]



Outdoor fan motor error

[Defective fan motor, connector poor connection, defective outdoor PCB]




Notes (1) See pages 71 for the fan motor and outdoor PCB check procedure.
 (2) After making sure the fan motor and outdoor PCB are normal, connect the connectors and confirm that the fan motor is turning.
 (If power is turned on while one or the other is broken down, it could cause the other to break down also.)

Rotor lock

[Defective compressor, defective outdoor PCB]

Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>



↓ YES
Inspect compressor.

- Check compressor wiring visually.
 - Check insulation resistance. (1 MΩ or over)
 - Check coil wire resistance.
- See page 64.

⌋ If check results are normal, compressor is locked.

(8) Phenomenon observed after shortcircuit, wire breakage on sensor


(a) Indoor unit

Sensor	Operation mode	Phenomenon	
		Shortcircuit	Disconnected wire
Room temperature sensor	Cooling	Release of continuous compressor operation command.	Continuous compressor operation command is not released.
	Heating	Continuous compressor operation command is not released.	Release of continuous compressor operation command.
Heat exchanger sensor	Cooling	System can be operated normally.	Continuous compressor operation command is not released. (Anti-frosting)
	Heating	High pressure control mode (Compressor stop command)	Hot keep (Indoor fan stop)
Humidity sensor ⁽¹⁾	Cooling	Refer to the table below.	Refer to the table below.
	Heating	Normal system operation is possible.	

■ Humidity sensor operation

Failure mode	Control input circuit resding	Air conditioning system operation
Disconnected wire	① Disconnected wire	Humidity reading is 0% Anti-condensation control is not done.
	② Disconnected wire	
	①② Disconnected wire	
Short Circuit	① and ② are shot circuited	Humidity reading is 100% Anti-condensation control keep doing.

Remark: Do not perform a continuity check of the humidity sensor with a tester. If DC current is applied, it could damage the sensor.




(b) Outdoor unit

Sensor	Operation mode	Phenomenon	
		Shortcircuit	Disconnected wire
Heat exchanger sensor	Cooling	System can be operated normally.	Compressor stop.
	Heating	Defrosting is not performed.	Defrosting is performed for 10 minutes at approx. 45 (models 50, 60 : 35) minutes.
Outdoor air temperature sensor	Cooling	System can be operated normally.	Compressor stop.
	Heating	Defrosting is not operated.	Defrosting is performed for 10 minutes at approx. 45 (models 50, 60 : 35) minutes.
Discharge pipe sensor	All modes	Compressor overload protection is disabled. (Can be operated.)	Compressor stop

(9) Checking the indoor electrical equipment

(a) Indoor PCB check procedure



Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>


(b) Indoor unit fan motor check procedure

This is a diagnostic procedure for determining if the indoor unit's fan motor or the indoor PCB is broken down.

1) Indoor PCB output check

- a) Turn off the power.
- b) Remove the front panel, then disconnect the fan motor lead wire connector.
- c) Turn on the power. If the unit operates when the ON/OFF button is pressed, if trouble is detected after the voltages in the following figure are output for approximately 30 seconds, it means that the indoor PCB is normal and the fan motor is broken down.

If the voltages in the following figure are not output at connector pins No. ①, ④ and ⑤, the indoor PCB has failed and the fan motor is normal.



Measuring point	Resistance when normal
① - ③	DC 308~336V
④ - ③	DC 15V
⑤ - ③	DC several V (4~6V)
⑥ - ③	DC several V (4~6V)

2) Fan motor resistance check

Measuring point	Resistance when normal
① - ③ (Red - Black)	20 MΩ or higher
④ - ③ (White - Black)	20 MΩ or higher

- Notes (1) Remove the fan motor and measure it without power connected to it.
 (2) If the measured value is below the value when the motor is normal, it means that the fan motor is faulty.

(C) Power transistor inspection procedure


[Use a tester with a needle indicator for the inspection. (Do not use a digital tester. Check in the AC 300 volt range.)]

(1) If there is a self-diagnosis display, inspect the compressor system (burns, wiring mistakes, etc.) If no problems are found, check the output of the power transistor.


Все каталоги и инструкции здесь: <http://splitoff.ru/tehn-doc.html>

outdoor unit are normal.

it board for the



(10) How to make sure of wireless remote controller



◆ Check point of outdoor unit

⚠ CAUTION- HIGH VOLTAGE


High voltage is produced in the control box. Don't touch electrical parts in the control box for 5 minutes after the unit is stopped.

Color symbol

BK	Black
BR	Brown
OR	Orange
RD	Red
WH	White
Y	Yellow
Y/G	Yellow/Green

Power source
 1 Phase
 220-240V 50Hz

Indoor unit



◆ Inspection power transistor
 Remove the fasten terminal and test output voltage

◆ Inspection of outdoor fan motor
 See page 71.

◆ Inspection of electronic expansion valve
 See page 71.

◆ Inspection of resistance value of sensor
 Remove the connector and check the resistance value.
 See the section of sensor characteristics on page 63.


◆ Power source and serial signal inspection

- ① to ⑧: AC 220/230/240V
- ① to ②: AC 220/230/240V
- ② to ③: Normal if the voltage oscillates between DC 0 and approx. 20V

(a) Inspection of electronic expansion valve

Electronic expansion valve operates for approx. 10 seconds after the power on, in order to determine its aperture. Check the operating sound and voltage during the period of time. (Voltage cannot be checked during operation in which only the aperture change occurs.)

- 1) If it is heard the sound of operating electronic expansion valve, it is almost normal.
- 2) If the operating sound is not heard, check the output voltage.



- 3) If voltage is detected, the outdoor PCB is normal.
- 4) If the expansion valve does not operate (no operating sound) while voltage is detected, the expansion valve is defective.

• Inspection of electronic expansion valve as a separate unit

Measure the resistance between terminals with an analog tester.

Measuring point	Resistance when normal
1-6	46 ± 4Ω (at 20°C)
1-4	
1-3	
1-5	

(b) Outdoor unit fan motor check procedure


- When the outdoor unit fan motor error is detected, diagnose which of the outdoor unit fan motor or outdoor PCB is defective.
- Diagnose this only after confirming that the indoor unit is normal.

1) Outdoor PCB output check

- a) Turn off the power.
- b) Disconnect the outdoor unit fan motor connector CNFAN.
- c) When the indoor unit is operated by inserting the power supply plug and pressing (ON) the backup switch for more than 5 seconds, if the voltage of pin No. ② in the following figure is output for 30 seconds at 20 seconds after turning “ON” the backup switch, the outdoor PCB is normal but the fan motor is defective.

If the voltage is not detected, the outdoor PCB is defective but the fan motor is normal.

Note (1) The voltage is output 3 times repeatedly. If it is not detected, the indoor unit displays the error message.



2) Fan motor resistance check

Measuring point	Resistance when normal
⑥ - ④ (Red - Blue)	20 MΩ or higher
③ - ④ (White - Blue)	20 KΩ or higher

- Notes (1) Remove the fan motor and measure it without power connected to it.
 (2) If the measured value is below the value when the motor is normal, it means that the fan motor is faulty.



11. OPTIONAL PARTS

11.1 Installation of wired remote controller (RC-E4)

PJA012D729A 

Read together with indoor unit's installation manual.



⚠ WARNING

- Fasten the wiring to the terminal securely and hold the cable securely so as not to apply unexpected stress on the terminal.
Loose connection or hold will cause abnormal heat generation or fire. 
- Make sure the power supply is turned off when electric wiring work.
Otherwise, electric shock, malfunction and improper running may occur. 

⚠ CAUTION

- DO NOT install the remote controller at the following places in order to avoid malfunction.


(1) Places exposed to direct sunlight	(4) Hot surface or cold surface enough to generate condensation
(2) Places near heat devices	(5) Places exposed to oil mist or steam directly
(3) High humidity places	(6) Uneven surface


- DO NOT leave the remote controller without the upper case.
In case the upper case needs to be detached, protect the remote controller with a packaging box or bag in order to keep it away from water and dust. 

Accessories	Remote controller, wood screw (ø3.5×16) 2 pieces
Prepare on site	Remote controller cord (2 cores) the insulated thickness in 1mm or more. [In case of embedding cord] Electrical box, M4 screw (2 pieces) [In case of exposing cord] Cord clamp (if needed)


Installation procedure

- ① Open the cover of remote controller, and remove the screw under the buttons without fail.
- ② Remove the upper case of remote controller.
Insert a flat-blade screwdriver into the dented part of the upper part of the remote controller, and wrench slightly.



[In case of embedding cord]


- ③ Embed the electrical box and remote controller cord beforehand.
- ④ Prepare two M4 screws (recommended length is 12-16mm) on site, and install the lower case to electrical box. Choose either of the following two positions in fixing it with screws.




- ⑤ Connect the remote controller cord to the terminal block.
Connect the terminal of remote controller (X,Y) with the terminal of indoor unit (X,Y). (X and Y are no polarity)
- ⑥ Install the upper case as before so as not to catch up the remote controller cord, and tighten with the screws.

[In case of exposing cord]

- ③ You can pull out the remote controller cord from left upper part or center upper part.
Cut off the upper thin part of remote controller lower case with a nipper or knife, and grind burrs with a file etc.
- ④ Install the lower case to the flat wall with attached two wooden screws.




- ⑤ Connect the remote controller cord to the terminal block.
 Connect the terminal of remote controller (X,Y) with the terminal of indoor unit (X,Y).
 (X and Y are no polarity)
 Wiring route is as shown in the right diagram depending on the pulling out direction.



The wiring inside the remote controller case should be within 0.3mm² (recommended) to 0.5mm².
 The sheath should be peeled off inside the remote controller case.
 The peeling-off length of each wire is as below.

Pulling out from upper left	Pulling out from upper center
X wiring : 215mm	X wiring : 170mm
Y wiring : 195mm	Y wiring : 190mm




- ⑥ Install the upper case as before so as not to catch up the remote controller cord, and tighten with the screws.
 ⑦ In case of exposing cord, fix the cord on the wall with cord clamp so as not to slack.

Installation and wiring of remote controller

- ① Wiring of remote controller should use 0.3mm² × 2 core wires or cables. (on-site configuration)
 ② Maximum prolongation of remote controller wiring is 600 m.
 If the prolongation is over 100m, change to the size below.
 But, wiring in the remote controller case should be under 0.5mm². Change the wire size outside of the case according to wire connecting. Waterproof treatment is necessary at the wire connecting section. Be careful about contact failure.
- | | |
|------------|------------------------------------|
| 100 - 200m |0.5mm ² × 2 cores |
| Under 300m |0.75mm ² × 2 cores |
| Under 400m |1.25mm ² × 2 cores |
| Under 600m |2.0mm ² × 2 cores |

Master/ slave setting when more than one remote controllers are used

A maximum of two remote controllers can be connected to one indoor unit (or one group of indoor units.)




Set SW1 to "Slave" for the slave remote controller. It was factory set to "Master" for shipment.
 Note: The setting "Remote controller thermistor enabled" is only selectable with the master remote controller in the position where you want to check room temperature.
 The air conditioner operation follows the last operation of the remote controller regardless of the master/ slave setting of it.

The indication when power source is supplied

When power source is turned on, the following is displayed on the remote controller until the communication between the remote controller and indoor unit settled.


Master remote controller : " WAIT M"
 Slave remote controller : " WAIT S"

At the same time, a mark or a number will be displayed for two seconds first.
 This is the software's administration number of the remote controller, not an error cord.



※ The left mark is only an example. Other marks may appear.

When remote controller cannot communicate with the indoor unit for half an hour, the below indication will appear.
 Check wiring of the indoor unit and the outdoor unit etc.



The range of temperature setting

When shipped, the range of set temperature differs depending on the operation mode as below.

Heating : 16~30°C (55~86°F)

Except heating (cooling, fan, dry, automatic) : 18~30°C (62~86°F)

Upper limit and lower limit of set temperature can be changed with remote controller.

Upper limit setting: valid during heating operation. Possible to set in the range of 20 to 30°C (68 to 86°F).

Lower limit setting: valid except heating (automatic, cooling, fan, dry) Possible to set in the range of 18 to 26°C (62 to 79°F).

When you set upper and lower limit by this function, control as below.


1. When ② TEMP RANGE SET, remote controller function of function setting mode is "INDN CHANGE" (factory setting),
 [If upper limit value is set]
 During heating, you cannot set the value exceeding the upper limit.
 [If lower limit value is set]
 During operation mode except heating, you cannot set the value below the lower limit.
2. When ② TEMP RANGE SET, remote controller function of function setting mode is "NO INDN CHANGE"
 [If upper limit value is set]
 During heating, even if the value exceeding the upper limit is set, upper limit value will be sent to the indoor unit.
 But, the indication is the same as the temperature set.
 [If lower limit value is set]
 During except heating, even if the value lower than the lower limit is set, lower limit value will be sent to the indoor unit.
 But, the indication is the same as the temperature set.

How to set upper and lower limit value

1. Stop the air-conditioner, and press (○) (SET) and (↔) (MODE) button at the same time for over three seconds .
 The indication changes to "FUNCTION SET ▼".
2. Press (▼) button once, and change to the "TEMP RANGE ▲" indication.
3. Press (○) (SET) button, and enter the temperature range setting mode.
4. Select "UPPER LIMIT ▼" or "LOWER LIMIT ▲" by using (▲) (▼) button.
5. Press (○) (SET) button to fix.
6. When "UPPER LIMIT ▼" is selected (valid during heating)
 - ① Indication: "👉 ▼ ^ SET UP" → "UPPER 30°C ▼"
 - ② Select the upper limit value with temperature setting button (▼) (▲) . Indication example: "UPPER 26°C ▼ ^" (blinking)
 - ③ Press (○) (SET) button to fix. Indication example: "UPPER 26°C" (Displayed for two seconds)
 After the fixed upper limit value displayed for two seconds, the indication will return to "UPPER LIMIT ▼".
7. When "LOWER LIMIT ▲" is selected (valid during cooling, dry, fan, automatic)
 - ① Indication: "👉 ▼ ^ SET UP" → "LOWER 18°C ▲"
 - ② Select the lower limit value with temperature setting button (▼) (▲) . Indication example: "LOWER 24°C ▼ ^" (blinking)
 - ③ Press (○) (SET) button to fix. Indication for example: "LOWER 24°C" (Displayed for two seconds)
 After the fixed lower limit value displayed for two seconds, the indication will return to "LOWER LIMIT ▼".
8. Press (ON/OFF) button to finish.

• It is possible to finish by pressing (ON/OFF) button on the way, but unfinished change of setting is unavailable.

• During setting, if you press (↺) (RESET) button, you return to the previous screen.



The functional setting

● The initial function setting for typical using is performed automatically by the indoor unit connected, when remote controller and indoor unit are connected.
 As long as they are used in a typical manner, there will be no need to change the initial settings.
 If you would like to change the initial setting marked "○", set your desired setting as for the selected item.
 The procedure of functional setting is shown as the following diagram.

[Flow of function setting]

- Start : Stop air-conditioner and press "○" (SET) and "MODE" buttons at the same time for over three seconds.
- Finalize : Press "○" (SET) button.
- Reset : Press "RESET" button.
- Select : Press "▲" "▼" button.
- End : Press "ON/OFF" button.

Record and keep the setting

Consult the technical data etc. for each control details

It is possible to finish above setting on the way, and unfinished change of setting is unavailable.
 "○": Initial settings
 "※": Automatic criterion

Stop air-conditioner and press "○" (SET) + "MODE" buttons at the same time for over three seconds.

FUNCTION SET ▼

FUNCTION ▼ (Remote controller function)

Function	setting																									
※ 01 GRILLE T↓ SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">↑↓ INVALID</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>50Hz ZONE ONLY</td> <td></td> <td rowspan="2">When you use at 50Hz area</td> </tr> <tr> <td>60Hz ZONE ONLY</td> <td></td> </tr> </table>	↑↓ INVALID	○		50Hz ZONE ONLY		When you use at 50Hz area	60Hz ZONE ONLY		When you use at 60Hz area																
↑↓ INVALID	○																									
50Hz ZONE ONLY		When you use at 50Hz area																								
60Hz ZONE ONLY																										
02 AUTO RUN SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">AUTO RUN ON</td> <td style="width: 5%; text-align: center;">※</td> <td style="width: 45%;"></td> </tr> <tr> <td>AUTO RUN OFF</td> <td style="width: 5%; text-align: center;">※</td> <td>Automatic operation is impossible</td> </tr> </table>	AUTO RUN ON	※		AUTO RUN OFF	※	Automatic operation is impossible																			
AUTO RUN ON	※																									
AUTO RUN OFF	※	Automatic operation is impossible																								
03 TEMP SW	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">VALID</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>INVALID</td> <td style="width: 5%; text-align: center;">○</td> <td>Temperature setting button is not working</td> </tr> </table>	VALID	○		INVALID	○	Temperature setting button is not working																			
VALID	○																									
INVALID	○	Temperature setting button is not working																								
04 MODE SW	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">VALID</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>INVALID</td> <td style="width: 5%; text-align: center;">○</td> <td>Mode button is not working</td> </tr> </table>	VALID	○		INVALID	○	Mode button is not working																			
VALID	○																									
INVALID	○	Mode button is not working																								
05 ON/OFF SW	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">VALID</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>INVALID</td> <td style="width: 5%; text-align: center;">○</td> <td>On/Off button is not working</td> </tr> </table>	VALID	○		INVALID	○	On/Off button is not working																			
VALID	○																									
INVALID	○	On/Off button is not working																								
06 FAN SPEED SW	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">VALID</td> <td style="width: 5%; text-align: center;">※</td> <td style="width: 45%;"></td> </tr> <tr> <td>INVALID</td> <td style="width: 5%; text-align: center;">※</td> <td>Fan speed button is not working</td> </tr> </table>	VALID	※		INVALID	※	Fan speed button is not working																			
VALID	※																									
INVALID	※	Fan speed button is not working																								
07 LOUVER SW	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">VALID</td> <td style="width: 5%; text-align: center;">※</td> <td style="width: 45%;"></td> </tr> <tr> <td>INVALID</td> <td style="width: 5%; text-align: center;">※</td> <td>Louver button is not working</td> </tr> </table>	VALID	※		INVALID	※	Louver button is not working																			
VALID	※																									
INVALID	※	Louver button is not working																								
08 TIMER SW	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">VALID</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>INVALID</td> <td style="width: 5%; text-align: center;">○</td> <td>Timer button is not working</td> </tr> </table>	VALID	○		INVALID	○	Timer button is not working																			
VALID	○																									
INVALID	○	Timer button is not working																								
※ 09 SENSOR SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">SENSOR OFF</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;">Remote thermistor is not working.</td> </tr> <tr> <td>SENSOR ON</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working.</td> </tr> <tr> <td>SENSOR +3.0℃</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working, and to be set for producing +3.0℃ increase in temperature.</td> </tr> <tr> <td>SENSOR +2.0℃</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working, and to be set for producing +2.0℃ increase in temperature.</td> </tr> <tr> <td>SENSOR +1.0℃</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working, and to be set for producing +1.0℃ increase in temperature.</td> </tr> <tr> <td>SENSOR -1.0℃</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working, and to be set for producing -1.0℃ increase in temperature.</td> </tr> <tr> <td>SENSOR -2.0℃</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working, and to be set for producing -2.0℃ increase in temperature.</td> </tr> <tr> <td>SENSOR -3.0℃</td> <td style="width: 5%; text-align: center;">○</td> <td>Remote thermistor is working, and to be set for producing -3.0℃ increase in temperature.</td> </tr> </table>	SENSOR OFF	○	Remote thermistor is not working.	SENSOR ON	○	Remote thermistor is working.	SENSOR +3.0℃	○	Remote thermistor is working, and to be set for producing +3.0℃ increase in temperature.	SENSOR +2.0℃	○	Remote thermistor is working, and to be set for producing +2.0℃ increase in temperature.	SENSOR +1.0℃	○	Remote thermistor is working, and to be set for producing +1.0℃ increase in temperature.	SENSOR -1.0℃	○	Remote thermistor is working, and to be set for producing -1.0℃ increase in temperature.	SENSOR -2.0℃	○	Remote thermistor is working, and to be set for producing -2.0℃ increase in temperature.	SENSOR -3.0℃	○	Remote thermistor is working, and to be set for producing -3.0℃ increase in temperature.	
SENSOR OFF	○	Remote thermistor is not working.																								
SENSOR ON	○	Remote thermistor is working.																								
SENSOR +3.0℃	○	Remote thermistor is working, and to be set for producing +3.0℃ increase in temperature.																								
SENSOR +2.0℃	○	Remote thermistor is working, and to be set for producing +2.0℃ increase in temperature.																								
SENSOR +1.0℃	○	Remote thermistor is working, and to be set for producing +1.0℃ increase in temperature.																								
SENSOR -1.0℃	○	Remote thermistor is working, and to be set for producing -1.0℃ increase in temperature.																								
SENSOR -2.0℃	○	Remote thermistor is working, and to be set for producing -2.0℃ increase in temperature.																								
SENSOR -3.0℃	○	Remote thermistor is working, and to be set for producing -3.0℃ increase in temperature.																								
10 AUTO RESTART	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">INVALID</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>VALID</td> <td style="width: 5%; text-align: center;">○</td> <td></td> </tr> </table>	INVALID	○		VALID	○																				
INVALID	○																									
VALID	○																									
※ 11 VENT LINK SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">NO VENT</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>VENT LINK</td> <td style="width: 5%; text-align: center;">○</td> <td>In case of Single split series, by connecting ventilation device to CNT of the indoor printed circuit board (in case of VRF series, by connecting it to CND of the indoor printed circuit board), the operation of ventilation device is linked with the operation of indoor unit.</td> </tr> <tr> <td>NO VENT LINK</td> <td style="width: 5%; text-align: center;">○</td> <td>In case of Single split series, by connecting ventilation device to CNT of the indoor printed circuit board (in case of VRF series, by connecting it to CND of the indoor printed circuit board), you can operate /stop the ventilation device independently by (VENT) button.</td> </tr> </table>	NO VENT	○		VENT LINK	○	In case of Single split series, by connecting ventilation device to CNT of the indoor printed circuit board (in case of VRF series, by connecting it to CND of the indoor printed circuit board), the operation of ventilation device is linked with the operation of indoor unit.	NO VENT LINK	○	In case of Single split series, by connecting ventilation device to CNT of the indoor printed circuit board (in case of VRF series, by connecting it to CND of the indoor printed circuit board), you can operate /stop the ventilation device independently by (VENT) button.																
NO VENT	○																									
VENT LINK	○	In case of Single split series, by connecting ventilation device to CNT of the indoor printed circuit board (in case of VRF series, by connecting it to CND of the indoor printed circuit board), the operation of ventilation device is linked with the operation of indoor unit.																								
NO VENT LINK	○	In case of Single split series, by connecting ventilation device to CNT of the indoor printed circuit board (in case of VRF series, by connecting it to CND of the indoor printed circuit board), you can operate /stop the ventilation device independently by (VENT) button.																								
12 TEMP RANGE SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">INDN CHANGE</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;">If you change the range of set temperature, the indication of set temperature will vary following the control.</td> </tr> <tr> <td>NO INDN CHANGE</td> <td style="width: 5%; text-align: center;">○</td> <td>If you change the range of set temperature, the indication of set temperature will not vary following the control, and keep the set temperature.</td> </tr> </table>	INDN CHANGE	○	If you change the range of set temperature, the indication of set temperature will vary following the control.	NO INDN CHANGE	○	If you change the range of set temperature, the indication of set temperature will not vary following the control, and keep the set temperature.																			
INDN CHANGE	○	If you change the range of set temperature, the indication of set temperature will vary following the control.																								
NO INDN CHANGE	○	If you change the range of set temperature, the indication of set temperature will not vary following the control, and keep the set temperature.																								
13 I/Z FAN	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">HI-MID-LO</td> <td style="width: 5%; text-align: center;">※</td> <td style="width: 45%;">Airflow of fan becomes of HI-MID-LO or the four speed of HI-MID-LO.</td> </tr> <tr> <td>HI-LO</td> <td style="width: 5%; text-align: center;">※</td> <td>Airflow of fan becomes of HI-LO.</td> </tr> <tr> <td>HI-MID</td> <td style="width: 5%; text-align: center;">※</td> <td>Airflow of fan becomes of HI-MID.</td> </tr> <tr> <td>1 FAN SPEED</td> <td style="width: 5%; text-align: center;">※</td> <td>Airflow of fan is fixed at one speed.</td> </tr> </table>	HI-MID-LO	※	Airflow of fan becomes of HI-MID-LO or the four speed of HI-MID-LO .	HI-LO	※	Airflow of fan becomes of HI-LO .	HI-MID	※	Airflow of fan becomes of HI-MID .	1 FAN SPEED	※	Airflow of fan is fixed at one speed.													
HI-MID-LO	※	Airflow of fan becomes of HI-MID-LO or the four speed of HI-MID-LO .																								
HI-LO	※	Airflow of fan becomes of HI-LO .																								
HI-MID	※	Airflow of fan becomes of HI-MID .																								
1 FAN SPEED	※	Airflow of fan is fixed at one speed.																								
14 POSITION	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">4 POSITION STOP</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;">If you change the remote controller function "14 POSITION", you must change the indoor function "04 POSITION" accordingly.</td> </tr> <tr> <td>FREE STOP</td> <td style="width: 5%; text-align: center;">○</td> <td>You can select the louver stop position in the four. The louver can stop at any position.</td> </tr> </table>	4 POSITION STOP	○	If you change the remote controller function "14 POSITION", you must change the indoor function "04 POSITION" accordingly.	FREE STOP	○	You can select the louver stop position in the four. The louver can stop at any position.																			
4 POSITION STOP	○	If you change the remote controller function "14 POSITION", you must change the indoor function "04 POSITION" accordingly.																								
FREE STOP	○	You can select the louver stop position in the four. The louver can stop at any position.																								
15 MODEL TYPE	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">HEAT PUMP</td> <td style="width: 5%; text-align: center;">※</td> <td style="width: 45%;"></td> </tr> <tr> <td>COOLING ONLY</td> <td style="width: 5%; text-align: center;">※</td> <td></td> </tr> </table>	HEAT PUMP	※		COOLING ONLY	※																				
HEAT PUMP	※																									
COOLING ONLY	※																									
16 EXTERNAL CONTROL SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">INDIVIDUAL</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;">If you input signal into CNT of the indoor printed circuit board from external, the indoor unit will be operated independently according to the input from external.</td> </tr> <tr> <td>FOR ALL UNITS</td> <td style="width: 5%; text-align: center;">○</td> <td>If you input into CNT of the indoor printed circuit board from external, all units which connect to the same remote controller are operated according to the input from external.</td> </tr> </table>	INDIVIDUAL	○	If you input signal into CNT of the indoor printed circuit board from external, the indoor unit will be operated independently according to the input from external.	FOR ALL UNITS	○	If you input into CNT of the indoor printed circuit board from external, all units which connect to the same remote controller are operated according to the input from external.																			
INDIVIDUAL	○	If you input signal into CNT of the indoor printed circuit board from external, the indoor unit will be operated independently according to the input from external.																								
FOR ALL UNITS	○	If you input into CNT of the indoor printed circuit board from external, all units which connect to the same remote controller are operated according to the input from external.																								
17 ROOM TEMP INDICATION SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">INDICATION OFF</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>INDICATION ON</td> <td style="width: 5%; text-align: center;">○</td> <td>In normal working indication, indoor unit temperature is indicated instead of airflow. (Only the master remote controller can be indicated.)</td> </tr> </table>	INDICATION OFF	○		INDICATION ON	○	In normal working indication, indoor unit temperature is indicated instead of airflow. (Only the master remote controller can be indicated.)																			
INDICATION OFF	○																									
INDICATION ON	○	In normal working indication, indoor unit temperature is indicated instead of airflow. (Only the master remote controller can be indicated.)																								
18 INDICATION	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">INDICATION ON</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;"></td> </tr> <tr> <td>INDICATION OFF</td> <td style="width: 5%; text-align: center;">○</td> <td>Heating preparation indication should not be indicated.</td> </tr> </table>	INDICATION ON	○		INDICATION OFF	○	Heating preparation indication should not be indicated.																			
INDICATION ON	○																									
INDICATION OFF	○	Heating preparation indication should not be indicated.																								
19 ℃/°F SET	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">℃</td> <td style="width: 5%; text-align: center;">○</td> <td style="width: 45%;">Temperature indication is by degree C</td> </tr> <tr> <td>°F</td> <td style="width: 5%; text-align: center;">○</td> <td>Temperature indication is by degree F</td> </tr> </table>	℃	○	Temperature indication is by degree C	°F	○	Temperature indication is by degree F																			
℃	○	Temperature indication is by degree C																								
°F	○	Temperature indication is by degree F																								

Note (1) ※ The mark cannot use SRK series.

ON/OFF button (finished)

Note 1: The initial setting marked "※" is decided by connected indoor and outdoor unit, and is automatically defined as following table.

Function No.	Item	Default	Model
Remote controller function02	AUTO RUN SET	AUTO RUN ON	"Auto-RUN" mode selectable indoor unit.
		AUTO RUN OFF	Indoor unit without "Auto-RUN" mode
Remote controller function06	FAN SPEED SW	VALID	Indoor unit with two or three step of air flow setting
		INVALID	Indoor unit with only one of air flow setting
Remote controller function07	LOUVER SW	VALID	Indoor unit with automatically swing louver
		INVALID	Indoor unit without automatically swing louver
Remote controller function13	I/U FAN	HI-MID-LO	Indoor unit with three step of air flow setting
		HI-LO	Indoor unit with two step of air flow setting
		HI-MID	
		1 FAN SPEED	Indoor unit with only one of air flow setting
Remote controller function15	MODEL TYPE	HEAT PUMP	Heat pump unit
		COOLING ONLY	Exclusive cooling unit

Note 3: As for plural indoor unit, set indoor functions to each master and slave indoor unit.

But only master indoor unit is received the setting change of indoor unit function "05 EXTERNAL INPUT" and "06 PERMISSION / PROHIBITION".

(Indoor unit function) I/U FUNCTION ▲ Indoor unit No. are indicated only when plural indoor units are connected.

Function	setting	
※ 02 FAN SPEED SET	STANDARD	※
	HIGH SPEED 1	※
	HIGH SPEED 2	
※ 03 FILTER SIGN SET	INDICATION OFF	
	TYPE 1	○
	TYPE 2	
	TYPE 3	
	TYPE 4	
04 POSITION	POSITION STOP	○
	FREE STOP	
05 EXTERNAL INPUT	LEVEL INPUT	○
	PULSE INPUT	
06 OPERATION PERMISSION/PROHIBITION	INVALID	○
	VALID	
※ 07 EMERGENCY STOP	INVALID	○
	VALID	
※ 08 ※ SP OFFSET	OFFSET +3.0℃	
	OFFSET +2.0℃	
	OFFSET +1.0℃	
	NO OFFSET	○
※ 09 RETURN AIR TEMP	OFFSET +2.0℃	
	OFFSET +1.5℃	
	OFFSET +1.0℃	
	NO OFFSET	○
※ 10 ※ FAN CONTROL	OFFSET -1.0℃	
	OFFSET -1.5℃	
	OFFSET -2.0℃	
	NO OFFSET	○
※ 11 FROST PREVENTION TEMP	LOW FAN SPEED	○
	SET FAN SPEED	
	INTERMITTENCE	
	FAN OFF	
※ 12 FROST PREVENTION CONTROL	TEMP HIGH	
	TEMP LOW	○
※ 13 DRAIN PUMP LINK	FAN CONTROL ON	○
	FAN CONTROL OFF	
※ 14 ※ FAN REMAINING	※○ AND※	○
	※○ AND※AND※	
	※○ AND※	
	※○ AND※	
※ 15 ※ FAN REMAINING	NO REMAINING	○
	0.5 HOUR	
	1 HOUR	
	6 HOUR	
※ 16 ※ FAN INTERMITTENCE	NO REMAINING	○
	0.5 HOUR	
	2 HOUR	
	6 HOUR	
※ 17 PRESSURE CONTROL	NO REMAINING	○
	20minOFF 5minON	
	5minOFF 5minON	
※ 17 PRESSURE CONTROL	STANDARD	※
	TYPE1	※

Note2: Fan setting of "HIGH SPEED"

Fan tap	Indoor unit air flow setting					
	STANDARD	PHI - Hi - Me - Lo	Hi - Me - Lo	Hi - Lo	Hi - Me	
FAN SPEED SET	HIGH SPEED1, 2	PHI - PHI - Hi - Me	PHI - Hi - Me	PHI - Me	PHI - Hi	

Initial function setting of some indoor unit is "HIGH SPEED".
4 speed is not able to be set with wireless remote controller.

The filter sign is indicated after running for 180 hours.

The filter sign is indicated after running for 600 hours.

The filter sign is indicated after running for 1000 hours.

The filter sign is indicated after running for 1000 hours, then the indoor unit will be stopped by compulsion after 24 hours.

If you change the indoor function "04 POSITION", you must change the remote controller function "14 POSITION" accordingly. You can select the louver stop position in the four. The louver can stop at any position.

Permission/prohibition control of operation will be valid.

With the VRF series, it is used to stop all indoor units connected with the same outdoor unit immediately. When stop signal is inputted from remote on-off terminal "CNT-6", all indoor units are stopped immediately.

To be reset for producing +3.0°C increase in temperature during heating.
To be reset for producing +2.0°C increase in temperature during heating.
To be reset for producing +1.0°C increase in temperature during heating.

To be reset producing +2.0°C increase in return air temperature of indoor unit.
To be reset producing +1.5°C increase in return air temperature of indoor unit.
To be reset producing +1.0°C increase in return air temperature of indoor unit.

To be reset producing -1.0°C increase in return air temperature of indoor unit.
To be reset producing -1.5°C increase in return air temperature of indoor unit.
To be reset producing -2.0°C increase in return air temperature of indoor unit.

When heating thermostat is OFF, to be operated with low fan speed. (or with ultra low fan speed in case of some models)
When heating thermostat is OFF, to be operated with set fan speed.

When heating thermostat is OFF, fan speed is operated intermittently.
When heating thermostat is OFF, the fan is stopped.
When the remote thermostat is working, "FAN OFF" is set automatically.
Do not set "FAN OFF" when the indoor unit's thermostat is working.

Change of indoor heat exchanger temperature to start frost prevention control.

Working only with the Single split series.

To control frost prevention, the indoor fan tap is raised.

Drain pump is run during cooling and dry.
Drain pump is run during cooling, dry and heating.
Drain pump is run during cooling, dry, heating and fan.
Drain pump is run during cooling, dry and fan.


After cooling is stopped, the fan does not perform extra operation.
After cooling is stopped, the fan perform extra operation for half an hour.
After cooling is stopped, the fan perform extra operation for an hour.
After cooling is stopped, the fan perform extra operation for six hours.


After heating is stopped or heating thermostat is OFF, the fan does not perform extra operation.
After heating is stopped or heating thermostat is OFF, the fan perform extra operation for half an hour.
After heating is stopped or heating thermostat is OFF, the fan perform extra operation for two hours.
After heating is stopped or heating thermostat is OFF, the fan perform extra operation for six hours.

During heating is stopped or heating thermostat is OFF, the fan perform intermittent operation for five minutes with low fan speed after twenty minutes' OFF.
During heating is stopped or heating thermostat is OFF, the fan perform intermittent operation for five minutes with low fan speed after five minutes' OFF.

Connected "OA Processing" type indoor unit, and is automatically defined.

How to set function


1. Stop air-conditioner and press **(SET)** **(MODE)** buttons at the same time for over three seconds, and the "FUNCTION SET ▼" will be displayed.
 
2. Press **(SET)** button.
3. Make sure which do you want to set, "FUNCTION ▼" (remote controller function) or "I/U FUNCTION ▲" (indoor unit function).
4. Press **▲** or **▼** button.
Select "FUNCTION ▼" (remote controller function) or "I/U FUNCTION ▲" (indoor unit function).




5. Press **(SET)** button.

6. [On the occasion of remote controller function selection]


- ① "DATA LOADING" (Indication with blinking)
↓
Display is changed to "01 GRILLE ↑↓SET".
- ② Press **▲** or **▼** button.
"No. and function" are indicated by turns on the remote controller function table, then you can select from them. (For example)




- ③ Press **(SET)** button.
The current setting of selected function is indicated. (for example) "AUTO RUN ON" ← If "02 AUTO RUN SET" is selected



- ④ Press **▲** or **▼** button.
Select the setting.



- ⑤ Press **(SET)** button.
"SET COMPLETE" will be indicated, and the setting will be completed.
Then after "No. and function" indication returns, Set as the same procedure if you want to set continuously, and if to finish, go to 7.



7. Press **ON/OFF** button.

Setting is finished.

- It is possible to finish by pressing **ON/OFF** button on the way, but unfinished change of setting is unavailable.
- During setting, if you press **(RESET)** button, you return to the previous screen.
- Setting is memorized in the controller and it is saved independently of power failure.

[How to check the current setting]


When you select from "No. and function" and press set button by the previous operation, the "Setting" displayed first is the current setting.
(But, if you select "ALL UNIT ▼", the setting of the lowest number indoor unit is displayed.)

[On the occasion of indoor unit function selection]

- ① "DATA LOADING" (Blinking for 2 to 23 seconds to read the data)
↓
Indication is changed to "02 FAN SPEED SET".
Go to ②.


[Note]

(1) If plural indoor units are connected to a remote controller, the indication is "I/U 000" (blinking) ← The lowest number of the indoor unit connected is indicated.




- (2) Press **▲** or **▼** button.
Select the number of the indoor unit you are to set
If you select "ALL UNIT ▼", you can set the same setting with all unites.
- (3) Press **(SET)** button.


- ② Press **▲** or **▼** button.
"No. and function" are indicated by turns on the indoor unit function table, then you can select from them. (For example)




- ③ Press **(SET)** button.
The current setting of selected function is indicated. (For example) "STANDARD" ← If "02 FAN SPEED SET" is selected.



- ④ Press **▲** or **▼** button.
Select the setting.
- ⑤ Press **(SET)** button.
"SET COMPLETE" will be indicated, and the setting will be completed.
Then after "No. and function" indication returns, set as the same procedure if you want to set continuously, and if to finish, go to 7.



※ When plural indoor units are connected to a remote controller, press the **AIRCON NO.** button, which allows you to go back to the indoor unit selection screen. (example "I/U 000 ▲")



1: Starting button
2: Starting button
6-8: Indoor unit selection button
7: Finishing button

11.2 Interface kit (SC-BIKN-E)

RKZ012A088 

Accessories included in package


Be sure to check all the accessories included in package.

No.	Part name	Quantity
①	Indoor unit's connection cable (cable length: 1.8m)	1
②	Wood screws (for mounting the interface: $\phi 4 \times 25$)	2
③	Tapping screws (for the cable clamp and the interface mounting bracket)	3
④	Interface mounting bracket	1
⑤	Cable clamp (for the indoor unit's connection cable)	1


Safety precautions

Before use, please read these Safety Precautions thoroughly before installation.

- All the cautionary items mentioned below are important safety related items to be taken into consideration, so be sure to observe them at all times.

 **Warning** Incorrect installation could lead to serious consequences such as death, major injury or environmental destruction.

- Symbols used in these precautions

 Always go along these instruction.

- After completed installation, carry out trial operation to confirm no anomaly, and ask the user to keep this installation manual in a good place for future reference.


Warnings




- **Installation must be carried out by a qualified installer.**
If you install it by yourself, it may cause an electric shock, fire and personal injury, as a result of a system malfunction.
- **Install it in full accordance with the instruction manual.**
Incorrect installation may cause an electric shock, fire and personal injury.
- **Electrical work must be carried out by a qualified electrician in accordance with the technical standard for electrical equipment, the indoor wiring standard and this instruction manual.**
Incorrect installation may cause an electric shock, fire and personal injury.
- **Use the specific cables for wiring. And connect all the cables to terminals or connectors securely and clamp them with cable clamps in order for external forces not to be transmitted to the terminals directly.**
Incomplete connection may cause malfunction, and lead to heat generation and fire.
- **Use the original accessories and specified components for installation.**
If the parts other than those prescribed by us are used, it may cause an electric shock, fire and personal injury.

Connecting the indoor unit's connection cable to the interface

- ① Remove the upper case of the interface.
 - Remove 2 screws from the interface casing before removal of upper casing.
- ② Connect the indoor unit's connection cable to the interface.
 - Connect the connector of the indoor unit connection cable to the connector on the interface's circuit board.
- ③ Fix the indoor unit's connection cable with the cable clamp.
 - Cable can be brought in from the top or from the back.
 - Cut out the punch-outs for the connection cables running into the casing with cutter.
- ④ Connect the indoor unit's connection cable to the indoor control PCB.
 - Connect the indoor unit's connection cable to the indoor control PCB securely.
 - Clamp the connection cable to the indoor control box securely with the cable clamp provided as an accessory.
 - Regarding the cable connection to the indoor unit, refer to the instruction manual for indoor unit.



Name of each part of the interface



*Either the connection cables of super link E board (SC-ANDA-E) or of wired remote controller is connectable.

Switch	Setting	Function	Switch	Setting	Function
SW2-1	ON**	CNT level input	SW2-3	ON**	External input (CNT input)
	OFF	CNT Pulse input		OFF	Operation permission/prohibition (CNT input)
SW2-2	ON**	Wired remote controller : Valid	SW2-4	ON**	Heat pump
	OFF	Wired remote controller : Invalid		OFF	Cooling only


** Factory setting

Installation of the interface

- Install the interface within the range of the connection cable length (approximately 1.3m) from the indoor unit.
 - Be sure not to extend the connection cable on site. If the connection cable is extended, malfunction may occur.
 - Fix the interface on the wall, pillar or the like.
- **DO NOT** install the interface and wired remote controller at the following places.
- Places exposed to direct sunlight
 - Places near heating devices
 - High humidity places
 - Surfaces where are enough hot or cold to generate condensation
 - Places exposed to oil mist or steam directly
 - Uneven surface


Mounting the interface directly on a wall

- ① Mount the lower casing of the interface on a flat surface with wood screws provided as standard accessory.
- ② Mount the upper casing.




Recessing the interface in the wall

- ① Recess the electrical box (locally procured) and connection cables in the wall.
- ② Mount the lower casing of the interface to the electrical box with M4 screws (locally procured).
- ③ Mount the upper casing.



Mounting the interface with the mounting bracket

- ① Mount the mounting bracket to the interface with tapping screws provided as standard accessory.
- ② Mount the mounting bracket on wall or the like with wood screws provided as standard accessory.
- ③ Mount the mounting bracket to a wall surface, etc. using the wood screws provided.




Installation check items

- Are the connection cables connected securely to the terminal blocks and connectors?
- Are the thickness and length of the connection cables conformed with the standard?

Functions of CNT connector

It is available to operate the air conditioning unit and to monitor the operation status with the external control unit (remote display) by sending the input/output signal through CNT connector on the indoor control PCB.

- ① Connect a external remote control unit (locally procured) to CNT terminal.
- ② In case of the pulse input, switch OFF the DIP switch SW2-1 on the interface PCB.
- ③ When setting operation permission/prohibition mode, switch OFF the DIP switch SW2-3 on the interface PCB.




Input/Output	Function	Output signal		Content
		Relay	ON/OFF	
Output 1	Operation output	XR ₁	ON	During air-conditioner operation
Output 2	Heating output	XR ₂	ON	During heating operation
Output 3	Compressor operation output	XR ₃	ON	During compressor running
Output 4	Malfunction output	XR ₄	ON	During anomalous stop

- XR₁-4 are for the DC 12V relay
- XR₅ is a DC 12/24V or AC 220~240V relay
- CNT connector (local) maker, model

Connector	Molex	5264-06
Terminals	Molex	5263T

Input/Output	Function	SW2-1		SW2-3		Air-Conditioner	Operation by Remote Controller		
		Setting	Setting	Input signal	Content				
Input	External control input	ON*	Level input	ON*	Level	OFF→ON ON→OFF	External input	ON OFF	Allowed
				OFF	Level	OFF→ON ON→OFF	Operation permission Operation prohibition	OFF OFF	
		OFF	Pulse input	ON*	Pulse	OFF→ON	External input	OFF→ON ON→OFF	Allowed
				OFF	Level	OFF→ON ON→OFF	Operation permission Operation prohibition	ON OFF	


* Factory setting




Connection of super link E board

Regarding the connection of super link E board, refer to the instruction manual of super link E board. For electrical work, power supply for all of units in the super link system must be turned OFF.

- ① Switch ON the DIP switch SW2-2 (Factory setting: ON) on the interface PCB.
Caution: Wireless remote controller attached to the indoor unit can be used in parallel, after connecting the wired remote controller. However, some of functions other than the basic functions such as RUN/STOP, Temperature Setting, etc. may not work properly and may have a mismatch between the display and the actual behavior.



- ② Wiring connection between the interface and the super link E board.



No.	Names of recommended signal wires
1	Shielded wire
2	Vinyl cabtyre round cord
3	Vinyl cabtyre round cable
4	Vinyl insulated wire/vinyl sheathed cable for control

Within 200 m 0.5 mm² × 2 cores
 Within 300 m 0.75 mm² × 2 cores
 Within 400 m 1.25 mm² × 2 cores
 Within 600 m 2.0 mm² × 2 cores

- ③ Clamp the connection cables with cable clamps.


Connection of wired remote controller

Regarding the connection of wired remote controller, refer to the instruction manual of wired remote controller.

- ① Switch ON the DIP switch SW2-2 (Factory setting : ON) on the interface PCB.

Caution: Wireless remote controller attached to the indoor unit can be used in parallel, after connecting the wired remote controller. However, some of functions other than the basic functions such as RUN/STOP, Temperature Setting, etc. may not work properly and may have a mismatch between the display and the actual behavior.

- ② Wiring connection between the interface and the wired remote controller.




Installation and wiring of wired remote controller

- Install the wired remote controller with reference to the attached instruction manual of wired remote controller.
 - 0.3mm² × 2-core cable should be used for the wiring of wired remote controller.
 - Maximum length of wiring is 600m.
If the length of wiring exceeds 100m, change the size of cable as mentioned below.
100m-200m: 0.5mm² × 2-core, 300m or less: 0.75mm² × 2-core, 400m or less: 1.25mm² × 2-core, 600m or less: 2.0mm² × 2-core
However, cable size connecting to the terminal of wired remote controller should not exceed 0.5mm². Accordingly if the size of connection cable exceeds 0.5mm², be sure to downsize it to 0.5mm² at the nearest section of the wired remote controller and waterproof treatment should be done at the connecting section in order to avoid contact failure.
 - Don't use the multi-core cable to avoid malfunction.
 - Keep the wiring of wired remote controller away from grounding (Don't touch it to any metal frame of building, etc.).
 - Connect the connection cables to the terminal blocks of the wired remote controller and the interface securely (no polarity).
- ③ Clamp the connection cables with cable clamps.

Control of multiple units by a single wired remote controller

Multiple units (up to 16) can be controlled by a single wired remote controller. In this case, all units connected with a single wired remote controller will operate under the same mode and same setting temperature.

- ① Connect all the interface with 2-core cables of wired remote controller line.
- ② Set the address of indoor unit for remote controller communication from "0" to "F" with the rotary switch SW1 on the interface PCB.
- ③ After turning the power ON, the address of indoor unit can be displayed by pressing [AIR CON] button on the wired remote controller. Make sure all indoor units connected are displayed in order by pressing [▲] or [▼] button.



Master/Slave setting wired when 2 of wired remote controller are used

Maximum two wired remote controller can be connected to one indoor unit (or one group of indoor units)

- ① Set the DIP switch SW1 on the wired remote controller to "Slave" for the slave remote controller. (Factory setting : Master)
○ Caution : Remote controller sensor is invalid.


- When using the wireless remote controller in parallel with the wired remote controller; Temperature setting range should be changed with the wired remote controller (The set temperature may not be displayed correctly on the wireless remote controller, unless change of temperature setting range is done.) Changing procedure of temperature setting range is as follows.

How to set upper and lower limit of temperature sting range

1. Stop the air-conditioner, and press [○] (SET) and [▽] (MODE) button at the same time for 3 seconds or more.
The indication changes to "FUNCTION SET ▼"
2. Press [▼] button once, and change to the "TEMP RANGE ▲" indication.
3. Press [○] (SET) button, and enter the temperature range setting mode.
4. Confirm that the "Upper limit ▼" is shown on the display.
5. Press [○] (SET) button to fix.
6. ① Indication: "▽ ▲ SET UP" → "UPPER 28°C ▼ ▲"
② Select the upper limit value 30°C with temperature setting button [□]. "UPPER 30°C ▼" (blinking)
③ Press [○] (SET) button to fix. "UPPER 30°C" (Displayed for two seconds)
After the fixed upper limit value displayed for two seconds, the indication will return to "UPPER LIMIT ▼".
7. Press [▼] button once, "LOWER LIMIT ▲" is selected, press [○] (SET) button to fix.
① Indication: "▽ ▲ SET UP" → "LOWER 20°C ▼ ▲"
② Select the lower limit value 18°C with temperature setting button [□]. "LOWER 18°C ▲" (blinking)
③ Press [○] (SET) button to fix. "LOWER 18°C" (Displayed for two seconds)
After the fixed lower limit value displayed for two seconds, the indication will return to "LOWER LIMIT ▼"
8. Press [ON/OFF] button to finish.

Temperature setting range

Mode	Temperature setting range	Upper limit	Lower limit
Heating	16-30°C	20-30°C	16-26°C
Other than heating (Cooling, Fan, Dry, Auto)	18-30°C		



- It is possible to quit in the middle by pressing [ON/OFF] button, but the change of setting is incompleted.
- During setting, if pressing [RESET] button, it returns to the previous screen.

11.3 Super link E board (SC-ADNA-E)

PJZ012D029F

- Read and understand the instructions completely before starting installation.
- Refer to the instructions for both indoor and outdoor units.

Safety precautions

- Carefully read "Safety precautions" first. Follow the instructions for installation.
- Precautions are grouped into "Warning⚠" and "Caution⚠". The "Warning⚠" group includes items that may lead to serious injury or death if not observed. The items included in the "Caution⚠" group also may lead to serious results under certain conditions. Both groups are crucial for safety installation. Read and understand them carefully.
- After installation, conduct the test operation of the device to check for any abnormalities. Describe how to operate the device to the customer following the installation instruction manual. Instruct the customer to keep this installation instruction for future reference.

⚠Warning

- This device should be installed by the dealer where you purchase the device or a licensed professional shop. If the device is incorrectly installed by the customer, it may result in electric shock or fire.
- Install the device carefully following the installation instruction. If the device is incorrectly installed, it may result in electric shock or fire.
- Use the accessory parts and specified parts for installation. If any parts that do not match the specifications are used, it may result in electric shock or fire.
- A person with the electrical service certification should conduct the service based on the "Technical standards for electrical facilities", "Electrical Wiring Code", and the installation instruction. If the work is done incorrectly, it may result in electric shock or fire.
- Wiring should be securely connected using the specified types of wire. No external force on the wire should be applied to any terminals. If a secure connection is not achieved, it may result in electric shock or fire.











⚠Caution

- Provide ground connection.
The ground line should never be connected to the gas supply piping, the water supply piping, the lightning conductor rod, nor the telephone ground. If the grounding is improper, it may result in electric shock.
- Do not install the device in the following locations.
 1. Where there is mist/spray of oil or steam such as kitchens.
 2. Where there is corrosive gases such as sulfurous acid gas.
 3. Where there is a device generating electromagnetic waves.
These may interfere with the control system resulting in the device becoming uncontrollable.
 4. Where flammable volatile materials such as paint thinner and gasoline may exist or where they are handled. This may cause a fire.

1 Application

Indoor-to-outdoor three core communication specification type 3 (since October 2007)


2 Accessories

			 M4x8L 2 pieces
			
φ4x8L 2 pieces	To secure the print board and the metal box Made of nylon 4 pieces		

5 Connection Outline

Note for setting the address

- Set the address between 00 and 47 for the previous Super Link connection and between 000 and 127 for the new Super Link connection. (*1)
- Do not set the address overlapping with those of the other devices in the network. (The default is 000)



(*1) Whether the actual link is either the new Super Link or the previous Super Link depends on the models of the connected outdoor and indoor units. Consult the agent or the dealer.

3 Function

Allowing the center console SL1N-E, SL2NA-E, and SL3N-AE/BE to control and monitor the commercial air conditioning unit.

4 Control switching

Settings can be changed by the switch SW3 on the SL E board as in the following.

Switch	Symbol	Switch	Remarks
SW3	1	ON	Master
		OFF (default)	Slave
	2	ON	Fixed previous protocol
		OFF (default)	Automatic adjustment of Super Link protocol
	3	ON	Indicates the forced operation stop when abnormality has occurred.
		OFF (default)	Indicates the status of running/stop as it is, when abnormality has occurred.
	4	ON	The hundredth address activated "1"
		OFF (default)	The hundredth address activated "0"

Signal line specification

Communication method	Previous Super Link	New Super Link
Line type	MVVS	MVVS
Line diameter	0.75 - 1.25mm ²	0.75/1.25mm ²
Signal line (total length)	up to 1000m	up to 1500/1000m (*2)
Signal line (maximum length)	up to 1000m	up to 1000m


(*2) Up to 1500 m for 0.75 mm², and up to 1000 m for 1.25 mm².

Do not use 2.0 mm². It may cause an error.


(*3) Connect grounding on both ends of the shielding wire.

For the grounding method, refer to the section "[6] Installation".

- (1) Set the Super Link network address with SW1 (tens place), SW2 (ones place), and SW3 (hundreds place).
- (2) Set the SL E board SW3-1 to be ON (Master) when using this without any remote controller (no wired remote controller nor wireless remote controller).
- (3) Set up the plural master/slave device using the dip switches on the indoor unit board.
- (4) Set up the remote controller master/slave device using the slide switch on the remote controller board.
- (5) Set up "0" to "F" using the address rotary switch on the indoor unit board when controlling the indoor unit with the multiple remote controller.




Connect grounding. Connect grounding for the power line to Ground ①, and grounding for the signal line to Ground ② or to the Ground on the indoor unit control box.



2. When connecting to the indoor unit control box (ceiling-concealed type and FDT type only):

- (1) Mount the SL E board in the control box using the locking supports.
- (2) Remove 6 bands from the box and put the wiring through the bands to be secured.




Electrical shock hazard! Make sure to turn the power off for servicing. Be cautious so that no abnormal force should be applied to the wiring. Do not let the SL E board hung by the wiring. Do not damage the board with a screw driver. The board is sensitive to static electricity. Release the static electricity of your body before servicing. (you can do this by touching the control board which is grounded).

Location of installation


Install the device at the location where there are no electromagnetic waves nor where there is water and dust. The specified temperature range of the device is 0 to 40°C. Install the device at the location where the ambient temperature stays within the range. If it exceeds the specification, make sure to provide solution such as installing a cooling fan. When used outside of the range, it may cause abnormal operation.

6 Installation


1. When using the metal box (mounted on the indoor unit / mounted on the back of the remote controller):
 - (1) Mount the SL E board in the metal box using the locking supports.
 - (2) Wiring should go through the provided grommet since then through the wiring to the hole on the Metal box. Secure the grommet after inserting the grommet into the Metal box as shown in below figure, then tie the wiring at the outlet of the unit using a binding band.



▲ When installed outside the indoor unit, put the metal cover on.



▲ When installed on the back of the remote controller, mount it directly on the remote controller bottom case.



7 Indicator display

Check the LED 3 (green) and LED 2 (red) on the SL E board for flashing.

SL E board LEDs		Inspection mode	Display on the integrated network control device
Red	Green		
Off	Flashing	Normal communication	
Off	Off	<ul style="list-style-type: none"> Disconnection in the remote controller communication line (X or Y) Short-circuit in the remote controller communication line (between X and Y) Faulty indoor unit remote controller power Faulty remote controller communication circuit Faulty CPU on SL E board 	No corresponding unit number
One flash	Flashing	<ul style="list-style-type: none"> Disconnection in the Super Link signal line (A or B) Short-circuit in the Super Link signal line (between A and B) Faulty Super Link signal circuit 	
Two flashes	Flashing	<ul style="list-style-type: none"> Faulty address setting for the SL E board (Set up the address for previous SL E board : more than 48 new SL E board : more than 128) 	
Three flashes	Flashing	<ul style="list-style-type: none"> SL E board parent not set up when used without a remote controller Faulty remote controller communication circuit 	E1
Four flashes	Flashing	<ul style="list-style-type: none"> Address overlapping for the SL E board and the Super Link network connected indoor unit 	E2
Off	Flashing	<ul style="list-style-type: none"> Number of connected devices exceeds the specification for the multiple indoor unit control 	E10

PJZ012D029C

INVERTER WALL MOUNTED TYPE RESIDENTIAL AIR-CONDITIONERS



Air-Conditioning & Refrigeration Systems Headquarters
16-5, 2-chome, Kounan, Minato-ku, Tokyo, 108-8215, Japan
Fax : (03) 6716-5926

Because of our policy of continuous improvement, we reserve the right to make changes in all specifications without notice.

© Copyright MITSUBISHI HEAVY INDUSTRIES, LTD.



Большая библиотека технической документации
<http://splitoff.ru/tehn-doc.html>
каталоги, инструкции, сервисные мануалы, схемы.